



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 587-06-E

Manufacturer: Lennox Hearth Products, 1110 W. Taft Avenue, Orange, CA 92865

Trade Name(s): Lennox Hearth Products

Product: Outdoor gas-fired decorative fireplace

Pertinent Code Section(s): 27-800, RS 14-2 (ANSI Z223)

Prescribed Test(s): RS 14-6 (ANSI Z21.50 – 1982, Z21.88)

Laboratory: O.T.L.

Test Report(s): Certificate #116-F-41-5 dated September 11, 2006.

Description: Gas-fired decorative fireplace appliance designed to provide supplemental heating and to enhance the aesthetics of an outdoor room. Each of the below listed units are equipped with electric ignition.

Model No.	Gas Input Rating (Btu/hr)
E360DG	50,000
E420DG	50,000

Terms and Conditions: The above-described gas-fired fireplaces are accepted for operation under the following conditions:

1. Units are for outdoor installation.
2. Units shall use natural gas only with combustion air and required ventilation air provided.
3. Unit shall be installed in accordance with Section 27-879 of the New York City Building Code.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 10/25/17
Examined By [Signature]