



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 609-06-E

Manufacturer: Roberts-Gordon, Inc., 120 William Street, Buffalo, N.Y. 14240

Trade Name(s): Combat®, Weather-Rite™, Rapid™, Bananza®, Blackheat™, Heat-Rite™

Product: Gas-fired unit heaters

Pertinent Code Section(s): 27-800, 27-826, RS 14-2 (ANSI Z223.1)

Prescribed Test(s): RS 14-6 (ANSI Z83.6)

Laboratory: CSA International

Test Report(s): CSA File 1811197 dated January 9, 2007

Description: Gas-fired unit heaters, model UHA(S) series, designed for commercial and industrial indoor suspended mounting within the area to be heated. Unit is comprised of a main burner, heat exchanger assembly, an ignition system comprised of electronic igniter and flame sensor, combination gas control and temperature limit control. Units, with model numbers and input heating ratings, are listed below:

Model No.	Input Heating Rating (BTUH)
UHA(S), (B, BN, RP, WR, V) UHA(S) 30	30,000
UHA(S), (B, BN, RP, WR, V) UHA(S) 45	45,000
UHA(S), (B, BN, RP, WR, V) UHA(S) 60	60,000
UHA(S), (B, BN, RP, WR, V) UHA(S) 75	75,000
UHA(S), (B, BN, RP, WR, V) UHA(S) 100	100,000
UHA(S), (B, BN, RP, WR, V) UHA(S) 125	125,000
UHA(S), (B, BN, RP, WR, V) UHA(S) 150	150,000
UHA(S), (B, BN, RP, WR, V) UHA(S) 175	175,000

UHA(S), (B, BN, RP, WR, V) UHA(S) 200	200,000
UHA(S), (B, BN, RP, WR, V) UHA(S) 225	225,000
UHA(S), (B, BN, RP, WR, V) UHA(S) 250	250,000
UHA(S), (B, BN, RP, WR, V) UHA(S) 300	300,000
UHA(S), (B, BN, RP, WR, V) UHA(S) 350	350,000
UHA(S), (B, BN, RP, WR, V) UHA(S) 400	400,000

Note: Suffixes represent different trade names.

Terms and Conditions: The above units are accepted with the following conditions:

1. Units shall be installed for commercial and industrial indoor overhead applications only.
2. Units shall be fired on natural gas only.
3. Minimum installed clearances from combustible construction shall be in accordance with RS 14-15 of the New York City Building Code.
4. Combustion air and required ventilation air provided according to the New York City Building Code and manufacturer's instructions.
5. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
6. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
7. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance May 17, 2007

Examined By Simon Derk Hutson