

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, F.A.I.A., Commissioner
MEA 62-05-E

Report of Material and Equipment Acceptance Division

Manufacturer – System Sensor, Unincorporated Division of Honeywell International Inc., 3825 Ohio Avenue, St. Charles, Illinois 60174.

Trade Name – System Sensor.

Product – Fire Alarm Equipment.

Pertinent Code Sections – RS 17-3, RS 4-6 (886-89-BCR).

Tests – UL 38.

Laboratories - Underwriters Laboratories Inc.

Test Reports – UL File S8911, Project 04NK16146, issued October 29, 2004, revised November 19, 2004.

Description – Fire Alarm Pull Boxes.

Model	Description
20-1063	Fire Alarm Pull Boxes
20-1064	Fire Alarm Pull Boxes

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992. The Bureau of Fire Prevention has no objections Letter dated February 24, 2005, F.P. Index No. 0502039.

Recommendations - That the above units be accepted on condition that:

1. The models 20-1063 and 20-1064 non-metallic pull boxes shall be mounted to an approved outlet box or back box of metallic construction.
2. All uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and Reference Standard 17-3. Further, the installation shall be in accordance with the manufacturer's recommendation, NFPA 72 and the UL Standard.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance

Examined by

May 26, 2005
