



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 62-05-E Vol. 3

**Manufacturer:** System Sensor, Unincorporated Div. Of Honeywell Int'l. Inc., 3825 Ohio Avenue, St. Charles, IL 60174

**Trade Name(s):** Fike Protection Systems

**Product:** Fire alarm equipment

**Pertinent Code Section(s):** RS 17-3, RS 4-6 (886-89-BCR)

**Prescribed Test(s):** UL 38

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** UL File S8911, Project 04NK16146, issued October 29, 2004, revised January 3, 2007

**Description:** Fire alarm pull boxes.

Model No.	Description
20-1343	Fire Alarm Pull Boxes
20-1344	

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated January 26, 2007, F.P. Index #0701025.

**Terms and Conditions:** The above units are accepted on condition that:

1. The above units shall be used only in fire suppression system installations for manual release of fire suppression agent/s.
2. These non-metallic pull boxes shall be mounted to an approved outlet box or back box of metallic construction.
3. All uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17 and Reference Standard 17-3.
4. Units shall be installed in accordance with the manufacturer's recommendation, NFPA 72 and UL standard.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance March 6, 2007

Examined By Donald [Signature]