



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 63-05-E Vol. 2

Manufacturer: System Sensor, Unicorp. Div. Of Honeywell, 3825 Ohio Avenue, St. Charles, IL 60174

Trade Name(s): Honeywell

Product: Fire alarm equipment

Pertinent Code Section(s): RS 17-3, RS 4-6 (886-89-BCR), Subchapter 17

Test(s): UL 521

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): Multiple Listing Correlation Sheet File No. S751, issued June 20, 2005.

Description: Honeywell's detector as listed below:

System Sensor Model No.	Honeywell Model No.	Description
ED-TI	TC908A1000	Heat Detector (135°F – 155°F)

Terms and Conditions: The above unit is accepted on condition that:

1. All uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and Reference Standard 17-3.
2. The installation shall be in accordance with the manufacturer's recommendation, NFPA 72 and the UL Standard. These products shall be used only with compatible, listed and approved control panels and accessories.

3. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance December 14, 2006

Examined by Donald [Signature]