



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Robert D. LiMandri, Acting Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 64-08-M

Manufacturer: Hope's Windows, Inc.
84 Hopkins Avenue
Jamestown, N.Y. 14702-0580

Trade Name(s): Hope's Window, Inc.

Product: Fire-rated curtain wall assembly, 60-minute
MEA Index #310-190 – Wall Assembly

Pertinent Code Section(s): 27-329, 27-342

Prescribed Test(s): RS 5-6 (ASTM E152, UL 10C)

Laboratory: Intertek ETL Semko

Test Report(s): Intertek #3094054-001 dated August 17, 2006.

Description: 60-minute fire-rated curtain wall assembly, model **CW60-F**.

60-minute full scale vertical fire test conducted on an 11'-10½" (142½") (3619.5mm) x 9'-0" (108") (2743.2mm) high, non-load bearing curtain wall assembly.

Frame: 11'-10½" (142½") (3619.5mm) x 9'-0" (108") (2743.2mm) high outside dimension, 12-gauge hollow metal profile.

Glazing: 2-1/16" (52 mm) thick Pyrobel laminated glass.

Terms and Conditions: The above-described 60-minute fire-rated curtain wall assembly is accepted with the following conditions:

1. Wall assembly shall have the fire-resistance ratings indicated when used where combustible or non-combustible construction is required in accordance with the New York City Building Code
2. This acceptance does not include structural adequacy or wall design, which must be provided by a professional engineer or registered architect for particular structure for compliance with Building Code.
3. Installation shall comply with the New York City Building Code and Intertek Testing Services Project No. 30992988, as specified above.
4. All shipments and deliveries of such material shall be provided with a certificate or label certifying that the material shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance July 31, 2008

Examined By Simon Derphidam