



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 67-02-E Vol.10

Manufacturer: Notifier, 12 Clintonville Road, Northford, CT 06473-1653.

Trade Name(s): Honeywell.

Product: Fire Alarm Equipment.

Pertinent Code Section(s): Reference Standard RS 17, RS 4-6 (886-89-BCR), Subchapter 17.

Test(s): UL Standard 38.

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL multiple listing file S749 issued March 14, 2005

Description – Fire Alarm Equipment as listed below.

Honeywell Model No.	Notifier Model No.	Description
XLS-MPS	NBG-12LX	Fire Alarm Pull Box

Terms and Conditions: That the above units are accepted on condition that all uses, configurations, arrangements, and functions, applications and installations shall comply with the New York City Building Code, specifically Subchapter 17, and Reference Standard 17-3, NFPA 72, the UL Listing, UL 38 Standard, the manufacturer's instructions, the Fire Department rules, and the New York City Electrical Code. The referenced product shall be used only with listed and approved fire control panels and accessories. The compatibility must be specified or determined by a UL test report or the Engineer of Record.

All shipments and deliveries of such equipment shall be provided with a metal tag suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance April 25, 2006

Examined by Donald J. [Signature]