



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 67-02-E Vol. 12

Manufacturer: Honeywell International Inc.,
12 Clintonville Road, Northford, CT 06472-1653

Trade Name(s): Ansul, Inc.

Product: Fire alarm pull station

Pertinent Code Section(s): 27-958 thru 27-977, RS 17-5

Test(s): §27-969 (UL Standard 38)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL multiple listing file S2247 issued
September 21, 2007

Description: The Ansul, Inc. model, Agent Release Pull Station, is multiple-listed with Notifier's NBG-12LR (MEA 67-02-E).

Ansul, Inc. Model No.	Notifier Model No.	Description
AP-NBG-12LR	NBG-12LR	Agent Release Pull Station

Terms and Conditions: The above units are accepted on condition that:

1. All uses, configurations, arrangements, and functions, applications and installations shall comply with the New York City Building Code, specifically Subchapter 17, and Reference Standards RS 17-3 and RS 17-5, the UL listing, the manufacturer's instructions, the Fire Department rules, and the New York City Electrical Code.
2. The referenced product shall be used only with listed and approved fire-control panels and accessories. The compatibility must be specified or determined by a UL test report or the Engineer of Record.
3. All shipments and deliveries of such equipment shall be provided with a metal tag suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance December 4, 2007
Examined By Donald [Signature]