



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 67-02-E Vol. IX

Manufacturer: Notifier, 12 Clintonville Road, Northford, CT 06472-1001.

Trade Name(s): Silent Knight.

Product: Fire Alarm Pull Box.

Pertinent Code Section(s): 27-958 thru 27-977, RS 17-5 ANSI/NFiPA/No. 72.

Test(s): RS 17-5 ANSI/NiPA No. 72, UL 38.

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL multiple listing file S6012 issued July 21, 2000, revised July 7, 2005.

Description – The silent Knight Model IDP-PULL-DA dual action addressable pull station is multiple listed with Notifier’s Model NBG-12LX (MEA67-02-E). For use with compatible MEA listed Silent Knight fire alarm control units. The IDP-PULL-DA shall be suitable for surface mounting on matching back box Model SB-10 or semi-flush mounting on a standard single gang, double gang or 4” (10.16cm) square electric box.

Silent Knight Model No.	Notifier Model No.	Description
IDP-PULL-DA	NBG-12LX	Manual Pull Station

Terms and Conditions: That the above units are accepted on condition that all uses, configurations, arrangements, and functions, applications and installations shall comply with the New York City Building Code, specifically Subchapter 17, and Reference Standard 17-3, NFPA 72, the UL Listing, UL 38 Standard, the manufacturer's instructions, the Fire Department rules, and the New York City Electrical Code. The referenced product shall be used only with listed and approved fire control panels and accessories. The compatibility must be specified or determined by a UL test report or the Engineer of Record.

All shipments and deliveries of such equipment shall be provided with a metal tag suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance November 7, 2005

Examined by Donald Gottfried (SD)