

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, F.A.I.A., Commissioner

**MEA 68-04-E
Report of Materials and Equipment Acceptance Division**

Manufacturer – The Connerton Company, 1131 E. Wakeham Avenue, Santa Ana, CA 92705.

Trade Name – Connerton.

Product – Gas fired commercial griddle appliance.

Pertinent Code Section(s) – 27-800, 27-826, RS 14-2 (ANSI Z223.1).

Prescribed Tests – RS 14-6 (ANSI Z83.11).

Laboratory – CSA International.

Test Report – No. 1399876 dated March 17, 2004.

Description – Gas fired commercial kitchen equipment (griddle), as tabulated below.

Unit comprises main burner, pilot burner, thermocouples, safety shut off device, pressure regulator and manual valve.

Model No.	Input Rating BTU /hr
CG-(12,18)-(M/T)	1 @ 22,000
CG-(24,30)-(M/T)	2 @ 22,000
CG-(36,42)-(M/T)	3 @ 22,000
CG-48-(M/T)	4 @ 22,000
CG-60-(M/T)	5 @ 22,000
CG-72-(M/T)	6 @ 22,000
CEG-12, 17-(M/T)	1 @ 22,000
CEG-22, 27-(M/T)	2 @ 22,000
CEG-32, 37-(M/T)	3 @ 22,000
CEG-42, 47-(M/T)	4 @ 22,000
CEG-52, 57-(M/T)	5 @ 22,000

Note: Minimum installed clearances from combustible construction shall be as follows: back – 6 inches; sides – 4 inches.

Recommendation - That the above commercial cooking equipment, be accepted, when fired by natural gas only, under the following conditions:

- 1. Units shall be installed in accordance with manufacturer's instructions, National Fuel Gas Code, and New York City Electrical Code requirements.**
- 2. The installation shall not interfere with combustion air, accessibility for operation and servicing.**
- 3. Adequate supply of fresh air shall be provided into room or space enclosing equipment for unit ventilation and combustion requirements.**
- 4. Special precautions regarding exhaust fans in the vicinity of the equipment may be required to prevent interference with operation of the equipment.**
- 5. Gas line tubing and fitting connectors shall permit flexibility for such use.**
- 6. All gas line connections shall be made and equipment gas input settings shall be set by the licensed plumber installing unit.**
- 7. All work provided by the installer from the point gas utility company main line service termination to the equipment shall be subject to approval by the plumbing inspector.**
- 8. All shipments and deliveries of such equipment shall be accompanied by a certificate or label certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.**
- 9. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.**

Final Acceptance 5/28/04

Examined by Shyam K. [Signature]