



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 7-05-E Vol. 2

**Manufacturer:** System Sensor, 3825 Ohio Avenue, St. Charles, IL 60174

**Trade Name(s):** Honeywell

**Product:** Fire alarm equipment

**Pertinent Code Section(s):** RS 17-3, RS 4-6 (886-89-BCR), Subchapter 17.

**Test(s):** UL 268

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** Multiple Listing File No. S1196, issued June 1, 2005, revised April 26, 2006.

### Description:

Honeywell Model No.	System Sensor Model No.	Description
TC906A1002	ED-PI	Photoelectric Smoke Detector
TC906A1010	ED-PTI	Combination Smoke/Heat Detector
TC906D1006	ED-DPI	Photoelectric Smoke Detector

**Terms and Conditions:** The above equipment is accepted provided that:

1. All uses, locations, and installations comply with Article 17, Reference Standard RS-17 of the New York City Building Code, and the Electrical Code of the City of New York, applicable Fire Prevention Directives, and the manufacturer's instructions.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance December 14, 2006  
Examined by Donald [Signature]