

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

**Patricia J. Lancaster, F.A.I.A., Commissioner
MEA 70-04-E**

Report of Material and Equipment Acceptance Division

Manufacturer – The Connerton Company, 1131 E. Wakeham Avenue, Santa Ana, CA 92705.

Trade Name(s) – Connerton.

Product – Gas fired commercial hot plates.

Pertinent Code Section(s) - 27-800, 27-826, RS 14-2 (ANSI Z223.1).

Prescribed Test(s) -RS 14-6 (ANSI Z83.11).

Laboratory – CSA International.

Test Report(s) – No. 1399876 dated March 17, 2003.

Description – Gas fired commercial kitchen equipment, hot plates, as tabulated below. Unit comprises main burner, pilot burner, thermocouples, safety shut off device, pressure regulator and manual valve.

Model No.	Input Ratings
CHP-(212,224)	2 @ 28,000
CHP-(424,448)	4 @ 28,000
CHP-112	1 @ 28,000
CHP-336	3 @ 28,000
CHP-636	6 @ 28,000
CHP-848	8 @ 28,000

Note: Minimum installed clearances for combustible construction shall be as follows: back – 8 inches; sides – 8 inches.

Recommendation - That the above commercial cooking equipment, be accepted, when fired by natural gas only, under the following conditions:

- 1. Units shall be installed in accordance with manufacturer's instructions and National Fuel Gas Code and New York City Building Code requirements.**
- 2. The installation shall not interfere with combustion air, accessibility for operation and serving.**

3. Adequate supply of fresh air shall be provided into room or space enclosing equipment for unit ventilation and combustion requirements.
4. Special precautions regarding exhaust fans in the vicinity of the equipment may be required to prevent interference with operation of the equipment.
5. Gas line tubing and fitting connectors shall permit flexibility for such use.
6. All gas line connections shall be made and equipment gas input settings shall be set by the licensed plumber installing unit.
7. All work provided by the installer from the point of gas utility company main line service termination to the equipment shall be subject to approval by the plumbing inspector.
8. All shipments and deliveries of such equipment shall be provided with a laboratory label and a permanent tag , suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.
9. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance 5/28/04

Examined By Saya W. Prasad