

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, F.A.I.A., Commissioner

**MEA 72-05-M
Report of Material and Equipment Acceptance Division**

Manufacturer- Quiet Solution Inc., 522 Almanor Avenue, Sunnyvale California 94685.

Trade Name- Quiet Rock QR-530.

Product- Wall panel for interior finish acceptance.

Pertinent Code Section(s)- 27-348.

Prescribed Test(s)- RS 5-2 (ASTM E84), Toxicity.

Laboratory- Southwest Research Laboratories Inc.

Test Report- SWRI project No. 01.16935.02.027 dated February 2005 and No. 01.10932.01.096 dated February 7, 2005.

Description- "QuietRock QR-530 is an engineered drywall panel composed of gypsum, viscoelastic polymers and proprietary sound isolation layers. The panels hang and finish using standard drywall techniques, but employ constrained layer damping to dissipate acoustic energy and provide superior noise isolation."

Flame Spread Rating – 10 Smoke Density – 20

Recommendation – That the above described wall panel be accepted as conforming with interior finish Class A requirements and as having the smoke developed rating as indicated above. Upon exposure to fire the material did not produce products of decomposition or combustible that were more toxic than those given off by wood or paper when decomposing or burning under comparable conditions. All shipments and deliveries of the above described material shall be accompanied by a certificate or label certifying that the material shipped or delivered is equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the building Code.

Final Acceptance April 25/05
Examined By S. D. [Signature]