



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 76-05-E

Manufacturer: System Sensor, Unincorporated Division of Honeywell International Inc., 3825 Ohio Avenue, St. Charles, Illinois 60174.

Trade Name(s): System Sensor.

Product: Fire Alarm Equipment.

Pertinent Code Section(s): RS 17-3, RS 4-6 (886-89-BCR).

Test(s): S4011, S5512.

Laboratory: Underwriters Laboratories Inc.

Test Report(s): UL File S4011 Vol. 2, issued April 3, 2001, revised September 28, 2004, project 01NK8352.

Description – Fire Alarm Pull Boxes.

Model	Description
CH24MC, CH24MCW	Chime/Strobes

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992. The Bureau of Fire Prevention has no objections Letter dated March 11, 2005, F.P. Index No. 0503004.

Terms and Conditions: That the above units be accepted on condition that:

1. All uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Building Code, and Reference Standard 17-3C. Further, the installation shall be in accordance with the manufacturer's recommendation, NFPA 72 and the UL Standard.
2. These notification appliances shall be used only with listed and approved control panels and accessories with which the compatibility has been determined to be acceptable by the Engineer of Record or a UL test report.

All shipments and deliveries of such equipment shall be provided with a metal tag suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance April 5, 2006
Examined by Donald [Signature]