

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner

**MEA 78-00-E
Report of Material and Equipment Acceptance Division**

Manufacturer – Metal-Fab, Inc., P.O. Box 1138, Wichita, KS 67201.

Trade Name(s) – Metal-Fab, Inc.

Product – Special Gas Vents.

Pertinent Code Section(s) – 27-854, 27-855.

Prescribed Test(s) -RS 15-13 (UL 1738).

Laboratory – Underwriters Laboratories Inc.

Test Report(s) – File MH26687, dated January 28, 2000.

Description – Model Corr/Guard Special Gas Vent Assembly. Series "CGS" designates single wall system while "CG" designates double wall system. The vent system is manufactured in 6-in. (152 mm) through 24 in. (610 mm) ID for installation in vertical or horizontal orientations. It is a single wall vent or a double wall vent system.

This vent system is intended to be connected directly to the flue outlet of Category II, III and IV gas burning appliances, as defined by the National Flue Gas Code, ANSI Z223.1/NFPA 54. It is intended to be installed in accordance with requirements contained in the Standard for Chimney, Fireplaces, Vents and Solid Fuel Burning Appliances.

Vent system is intended for installation with Category II, III and IV gas burning appliances where the maximum continuous flue gas temperatures produced, do not exceed 480°F (249°C) or 550°F (288°C) as required by the manufacturer's installation instructions.

Recommendation - That the above described gas vent system be accepted for use in accordance with the Building Code and when installed following manufacturer's and listing laboratory's instructions and recommendations.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance

3/30/2000

Examined By

Stephen M. Masai