

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, F.A.I.A., Commissioner

**MEA 8-04-E
Report of Material and Equipment Acceptance Division**

Manufacturer - Notifier, 12 Clintonville Road, Northford, CT 06472-1001.

Trade Names – Notifier, ADT Security Services, Inc.; Honeywell International, Inc., and Johnson Controls, Inc.

Product - Fire Alarm Equipment.

Pertinent Code Section(s) - 27-958 through 27-977, RS 17-5 ANSI/NFiPA No. 72.

Test(s) - RS 17-5 ANSI/NFiPA No. 72; UL 864.

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL File S635, Volume 50, Sec. 3, Project 03NK25171, issued September 17, 2003, revised October 20, 2003, S635 Vol. 28, Sec. 1, issued February 9, 1988, Project 87NK6656/S2424, revised August 14, 2003, UL M/L sheets S232, issued May 28, 1992, revised October 13, 2003, S470 issued November 13, 2003, S1570 issued October 31, 1995, revised October 8, 2003, and S635 issued July 30, 2003.

Description - The Notifier's model LCD-160 is a 160 character liquid crystal display annunciator. The Notifier Model PRN-6 is an 80 character printer. The ADT Model ADT-PRN-6, the Honeywell Model XLS-PRN-6 and the Johnson Controls' Model JPRN-6 are all multiple listed with Notifier's Model PRN-6. The Notifier Model VEC-RM remote microphone is multiple listed with the Fire-Lite Alarms, Inc., Model FC-RM (MEA 297-01-E).

Company	Model	UL File#
Notifier	LCD-160 LCD Annunciator	S635, Vol. 50, Sec. 3
Notifier	PRN-6 Printer	S635, Vol. 28, Sec. 1
ADT Security Services, Inc.	ADT-PRN-6 Printer	M/L File No. S232
Honeywell International, Inc.	XLS-PRN-6 Printer	M/L File No. S470
Johnson Controls, Inc.	JPRN-6 Printer	M/L File No. S1570
Notifier	VEC-RM Remote Microphone	M/L File No. S635

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992. The Bureau of Fire Prevention has no objections Letter dated April 6, 2004, F.P. Index #0312040A.

Recommendation - That the above units be accepted on condition that all:

1. All controls of the fire alarm shall be removed from the annunciator Model LCD-160 except the alarm silencer.
2. The above referenced products shall be used only with approved or listed fire alarm panels and accessories with which the compatibility has been determined by the Engineer of Record or a UL test report.
3. All uses, configurations, arrangements and functions, application and installations shall comply with the provisions of the New York City Building Code, specifically Subchapter 17 and with the Reference Standard RS 17-3.

All shipments and deliveries of such equipment shall be provided with a metal tag suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance June 21, 2004
Examined by Donald [Signature]