



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 82-04-E Vol. 2

**Manufacturer:** Oakwood Air Limited, 34 Meridian Road, Etobicoke, Ontario Toronto M9W 4Z7

**Trade Name(s):** Heatwave

**Product:** Air Conditioning Units

**Pertinent Code Section(s):** 27-770, 27-777.

**Prescribed Test(s):** RS 13-6 (ANSI B9.1), RS 13-8 (UL 303), RS 13-11 (UI1995)

**Laboratory:** Entela Inc.

**Test Report(s):** No. FC38081-2, Dated June 7, 2002

**Description:** Air conditioning unit designed for indoor installation. R-22 is the refrigerant used for the system. Unit consists of compressor, water and air cooled condenser with water regulating valve and controls. Units, with model numbers, cooling capacities are listed below:

### WATER -COOLED VERTICAL AIR CONDITIONER

Existing/ Canada	New/USA	MTS	Voltage Ratings	Amperage	HZ	Tons
WPC150-3	WVTC1503	LVA150TSU2	280-230/3	70	60	12.5
WPC150-4	WVTC1504	LVA150YSU2	460/3	35	60	12.5
WPC150-5	WVTC1505	LVA150ZSU2	575/3	25	60	12.5

