

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

**Patricia J. Lancaster, F.A.I.A., Commissioner
MEA 84-04-E**

Report of Material and Equipment Acceptance Division

Manufacturer – Fire Products International, Ltd., 6988 Venture Street, BC Canada V4G 1H4.

Trade Name(s) – Regency.

Product – Factory built up-vent decorative gas appliances.

Pertinent Code Section(s) – 27-800, RS 14-2 (ANSI Z223.1).

Prescribed Test(s) – RS 14-6 (ANSI Z21.88, Z21.50a).

Laboratory – Intertek Testing Services.

Test Report(s) – No. 476-3048390 dated October 2003 Ed. 2, dated September 24, 2002, revised October 3, 2003.

Description – Factory built up-vent decorative gas appliances (fireplace) designed to provide supplemental heating and to enhance the aesthetics of a room.

Individual Products	Model Number(s)	Test Report #
All units below are Gas Units that are designed to look like woodburning fireplaces and woodstoves.		
Zero Clearance, Direct Vent Gas Fireplace Size: 31.5" H x 33.0" W x 12.75" D BTU: Max. 15,000 Btu/h - Min. 7,800 Btu/h	G33R-NG1, G33R-LP1	476-1759-3/01 Rev. 476-3048390-9/03
Zero Clearance, Direct Vent Freestanding Gas Stove Size: 22.5" H x 22.7" W x 16.44" D BTU: Max. 18,000 Btu/h - Min. 10,500 Btu/h	H15-NG, H15-LP	476-3044834-5/03
Zero Clearance, Direct Vent Gas Fireplace Size: 37.0" H x 36.0" W x 17.0" D BTU: Max. 26,000 Btu/h - Min. 13,100 Btu/h	G36D-NG, G36D-LP	476-3031977-7/02 Rev. 476-3048390-10/03
Zero Clearance, Direct Vent Gas Fireplace Size: 41.0" H x 48.0" W x 23.25" D BTU: Max. 51,000 Btu/h - Min. 26,000 Btu/h	P48-NG, P48-LP	476-3039066-4/03

Recommendation - That the above described factory-built fireplaces, be accepted for use for the installation of decorative heating appliances and burning of wood only, for supplemental heating and decorative purposes. The installation of the above described units shall be in accordance with listing laboratories specifications, manufacturer's supplied instructions and Section 27-848 of the Building Code. Furthermore, the unit shall be vented in accordance with Section 27-856 of the Building Code. All shipments and deliveries of such equipment shall be provided with a laboratory label and a permanent tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance 5/28/04

Examined By Shyam Prasad