



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 9-05-E Vol. 2

Manufacturer: System Sensor, 3825 Ohio Avenue, St. Charles, IL 60174
Trade Name(s): Honeywell
Product: Fire alarm equipment
Pertinent Code Section(s): RS 17-3, RS 4-6 (886-89-BCR), Subchapter 17.
Test(s): UL 864
Laboratory: Underwriters Laboratories, Inc.
Test Report(s): Multiple Listing File No. S1196, issued July 1, 2005, revised April 26, 2006.

Description: Honeywell's bases as listed below:

Table with 3 columns: Honeywell Model No., System Sensor Model No., Description. Rows include models 50001947-001 (EBI, Base) and 50001947-002 (EBFI, Base).

Terms and Conditions: The above equipment is accepted provided that all uses, locations, and installations shall comply with Article 17, Reference Standard RS-17 of the New York City Building Code, the Electrical Code of the City of New York, applicable Fire Prevention Directives, and the manufacturer's instructions.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance December 14, 2006
Examined by Donald [Signature]