

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

**Patricia J. Lancaster, F.A.I.A., Commissioner
MEA 95-04-E**

Report of Material and Equipment Acceptance Division

Manufacturer – System Sensor, A Division of Pittway, 3825 Ohio Avenue, St. Charles, IL 60174.

Trade Name – Notifier.

Product – Fire Alarm Equipment.

Pertinent Code Section(s) – RS 17-3, RS 4-6 (886-89-BCR).

Prescribed Test(s) – UL 864.

Laboratory – Underwriters Laboratories Inc.

Test Reports– UL File S911, Volume 109, Section 1, issued November 27, 2003, revised January 12, 2004.

Description – Notifier’s Signaling device module as listed below:

Model No.	Description
FSB-200 & FSB-200S	Beam Detectors

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992. The Bureau of Fire Prevention has no objections letter dated

Recommendation - That the above equipment, be accepted provided that all uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and with the Reference Standard RS 17-13. Further, the installation and spacing shall be in accordance with the manufacturer’s recommendation, NFPA 72 and UL Standard. Periodic maintenance and sensitivity tests where required shall be conducted in accordance with the regulations of Fire Department.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance July 29, 2004

Examined By Donald J. [Signature]