



NYC Department of Buildings
 280 Broadway, New York, NY 10007
 Patricia Lancaster, FAIA, Commissioner
 (212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 96-05-E

Manufacturer: Central Fireplace, 20502, 160th Street Green, Bush, MN 56726.

Trade Name(s): Central Fireplace.

Product: Gas fired vented decorative fireplace appliance

Pertinent Code Section(s): 27-800, RS 14-2 (ANSI Z223).

Prescribed Test(s): RS 14-6 (ANSI Z21.88).

Laboratory: OMNI-Test Laboratories.

Test Report(s): 117-S-03b-5, 117-S-05c-5, 117-S-06b-5, 117-S-08c-5, 117-S-09d-5, 117-S-11-5.

Description – Gas fired decorative fireplace appliance design to provide supplemental heating and to enhance the aesthetics of a room. units are equipped with electric ignition.

Individual Products	Model Number(s)
CF-32	CF32-VER-1LP, CF32-ITA-1LP
CF-3036MV	CF3036MVT-NG, CF3036MVT-LP
CF-3036MVB	CF3036MVB-T-NG, CF3036MVB-T-LP
CF-22 DVI	CF22DVI-NG, CF22DVI-LP

Terms and Conditions: That the above described gas fired vented appliance be accepted for decorative heating operation on natural gas only, for indoor installation only with combustible air and required ventilation air provided. Venting of the above equipment is subject to Section 27-879 of the Building Code. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation. All shipments and deliveries of such equipment shall be provided with a metal tag permanently affixed to the units and suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance 2/16/05
 Examined by Sharon Rosen