



DEPARTMENT OF BUILDINGS

EXECUTIVE OFFICES
120 WALL STREET, NEW YORK, N.Y. 10005

CHARLES M. SMITH, Jr., R.A., Commissioner
248-8811

December 26, 1984

Mr. Gordon H. Smith
Gordon H. Smith Corporation
200 Madison Avenue
New York, N.Y. 10016

Re: Rules and Regulations
Relating to the Design and
Installation of Curtain
Wall and Panel Wall
(Non-Load Bearing Exterior
Wall) Systems.

Dear Mr. Smith:

This is in response to your letter to me, dated November 26, 1984, inquiring whether or not conventionally constructed field laid-up masonry walls fall within the scope of the above rules and regulations.

Please be advised that such panel walls are subject to controlled inspection pursuant to Section C26-106.3 of The Administrative (Building) Code and the subject rules.

Very truly yours,

Irving Polsky, P.E.

Irving Polsky, P.E.
Executive Engineer

IP/lw

cc: I.E. Minkin, P.E., Deputy Commissioner
Boro Supts.

2007