



DEPARTMENT OF BUILDINGS

EXECUTIVE OFFICES
120 WALL STREET, NEW YORK, N.Y. 10005

ROBERT ESNARD, R.A. Commissioner
248-8811

February 3,, 1984

Ms. Beverly L. Turell
Business Promotion Coordinator
Mayor's Office of Business Development
17 John Street
New York, New York 10038

Re: Exterior Rolling Shutters

Dear Ms. Turell:

I have reviewed your letter of January 26, and the accompanying advertising brochure accompanying same, and you are advised as follows:

1. Exterior rolling shutters are subject to limitations on projections beyond the street line in Article 4 of the Building Code (copy enclosed).
2. Exterior rolling shutters are not permissible over the secondary means of egress.
3. Exterior rolling shutters are subject to combustibility limitations of Article 5 of the Building Code (abstract enclosed).

If you have any questions in regard to this response and the enclosures, I suggest that you schedule an appointment with our Executive Engineer, Mr. Irving Polsky (248-8777) to pursue this matter further.

Sincerely,

A handwritten signature in black ink, appearing to read "Irving E. Minkin".

Irving E. Minkin, P.E.
Deputy Commissioner

IEM:ow
cc: Executive Engineer Polsky

1971