

HOUSING AND DEVELOPMENT ADMINISTRATION  
DEPARTMENT OF BUILDINGS


DIRECTIVE #9 of 1974

DEPARTMENTAL MEMORANDUM

DATE: May 21, 1974

TO: Borough Superintendents  
FROM: Thomas V. Burke, P.E., Director of Operations  
SUBJECT: SPRINKLERS IN TOILET ROOMS  
LOCAL LAW #5/1973

In existing office buildings, 100 ft. or more in height, sprinklers may be omitted from toilet rooms when complete sprinkler protection is provided in accordance with Section C26-504.1(c)(5) or when the building is completely sprinklered throughout.



Thomas V. Burke, P.E.  
Director of Operations

TVB:JWS:ASR

cc: Comm. Walsh  
Deputy Comm. Jenkins  
Assistant Comm. Parascandola  
Kenneth Patton, Real Estate Board  
Mayor's Advisory Council on  
Building and Construction  
Executive Staff  
Fire Chief John T. O'Hagan