



DEPARTMENT OF BUILDINGS

EXECUTIVE OFFICES

40 HUDSON STREET, NEW YORK, N.Y. 10013

RUDOLPH J. RINALDI, Commissioner

312-6100

May 6, 1991

Mr. Paul Rudolph
Benjamin Electrical Engineering Works, Inc.
589 Broadway
New York, New York 10012

Strobe
Re: Warning Devices in Sub-Systems
Reference Standard RS 4-6


Dear Mr. Rudolph:

This is in response to your letter dated April 29, 1991 regarding the requirements of LL58/87 for strobes in the above reference sub-systems.

When Balon for suppression or pre-action sprinkler system or any other similar system in computer, library or any room is installed and if such system requires an audible alarm in such spaces to alert the occupants for evacuation of these areas, the emergency warning system shall include both audible and visual alarms as per section 4.26 of RS4-6.

Therefore, the strobe shall be required as a warning device in these sub-systems.

Very truly yours,


Nalin T. Patel, P.E.
Director of Local Law Review

cc: George Sakona, P.E., Deputy Commissioner
Irving Polsky, P.E., Executive Engineer
Borough Commissioner
Chief Mansion, Fire Department
Henry Gitlitz, Fire Department

*ONLY FOR PROJECTS
2811
FILED BEFORE 12-31-14