

1 RCNY §43-04

CHAPTER 43 INSTALLATION OF SECURITY ITEMS IN MULTIPLE DWELLINGS

43-04 Installation of Lights in Rear Yards, Side Yards, Front Yards and Courts.

- (a) All electrical work shall be done in accordance with requirements and approval of the Department of Buildings.
- (b) The installation shall be a separate circuit or connected to the house line servicing the public halls.
- (c) The light or lights, shall be of at least 40 watts of incandescent or equivalent illumination.
- (d) The lights shall be so located as to adequately light all portions of the rear yards, side yards, front yards and courts.
- (e) Lights are not required in an inner court that is accessible only from the interior of the building and to which access is restricted for clean-out purposes.