



STANDARD CONSTRUCTION OPERATING PROCEDURE

**NEW YORK CITY DEPARTMENT OF
DESIGN + CONSTRUCTION**
Division of Infrastructure
Bureau of Construction

SCOP..... : 08- 012W

CATEGORY..: CONSTRUCTION
Subcategory : WATER MAIN

**SUBJECT: NOTIFICATION PROCEDURE FOLLOWING
WATER MAIN SHUTDOWNS**

Keywords : Water Main Shutdown

APPROVED:

ORIGINAL SIGNED BY

Chief Construction Engineer - William Svilar, P.E.

Supersedes..... : N/A

Supplements..... : 01-001G, 04-012G, 04-014G

Sheet..... : 1 of 1

Issue Date..... : December 16, 2008

After the water main has been sanitized and flushed at the end of a workday on a project, a single valve is typically opened to restore water service to the consumers involved in the water main shutdown. After the water main has been re-activated, the Resident Engineer (RE) or his designated field personnel shall visit and check all affected properties to ensure that water service has been properly restored.

This policy is to be reviewed with the field staff at Pre-construction and Critical Phase Meetings and should be documented in the project records.