1. SUPPORTING DOCUMENTATION

The tables included in this section were referenced the Infrastructure Chapter: the average daily and average dry weather sewage flow from the North River Water Pollution Control Plant (provided by New York City Department of Environmental Protection); and calculated water usage and wastewater generation for the Multi-Use Facility and expanded Convention Center (provided by the designers of these facilities).

North River

f	SEWAG	
		,
	DAILY	DRY
MONTH	MGD	MGD
Oct-02	140	121
Nov-02	130	118
Dec-02	128	120
Jan-03	125	119
Feb-03	129	125
Mar-03	130	122
Apr-03	134	128
May-03	129	122
Jun-03	149	130
Jul-03	129	124
Aug-03	129	120
Sep-03	132	122
Average	132	123

WEST SIDE UTILITY LOADS

Wastewater Calculations															
petron crite		petrons		1		room/apariment criteria					employee criteria		employee load	Total wastewater	
Facility	opd per petron			GPD	GPD		gpd per room				gpd per employee		GPD	GPD	
Jeta Stadium (note 2)		5 7	75,000		375,000	n/a		n/a		0	20	2,500			
Convention Center Expension (note 1)		5	40000)[200,000	r/a		n/a		0	20		11,700		
Hotel	n/a	n/a			0		150		1500	225000	20	400	8,000	233,00	
rotals				<u> </u>								<u> </u>	<u> </u>	869,76	

Water Use Calculations																
	patron criteria	petro	ns	patron load		room/apartment criteria gpd per room		rooms	load	employee criteria gpd per employee	employees				Total Domestic	Peak Flowrate GPM
Facility	gpd per patron												GPD	GPD	GPD	
Jets Stadium (note 2)		5	75,000		375,000	r/a		n/a		20	2,500	50,000	425,000			
Convention Center Expension (note 1)		5	40000	\overline{v}_{-}	200,000	n/a		n/a		20		11,700				
Hotel	r/a	n/a			0	1	150	150	0 225000	20	400	8,000	233,000	134,400	367,400	120
Totale	<u> </u>	-				<u>. </u>			<u> </u>	 	<u> </u>		869,700	868,800	1,738,500	6,30

Note 1 - Utility loads are based on incremental increase of 70,000 to 110,000 patrons on a peak day. Note 2 - No credit has been taken for storm water reuse