



**City of New York Fire Department**  
**Bureau Of Fire Prevention**  
**9 Metro Tech Center**  
**Brooklyn, New York 11201-3857**

The below list of **Above Ground Diesel Tanks** includes those which have a current Certificate of Approval issued by this Department as of May 12, 2006

Company's Name	Model Number	Telephone Number	Testing Laboratory	Certificate of Approval Number	Remarks	C of A Status
Containment Solutions	NYC 20 PSI Max. 4000 Gal Cylindrical & Rectangular	(409) 756-7731	UL	4980	With Build-in UL Listed Catchment Basin	Active
Convault Inc.	NYC 20 PSI Max. 4000 Gal Cylindrical	(518) 475-0024	UL	4989	Catchment Basion NOT Approved As Yet	Expired
Convault Inc.	NYC 20 PSI Max. 4000 Gal Rectangular	(518) 475-0024	UL	5002	With Build-in UL Listed Catchment Basin	Active
Highland Tank Mfg	NYC 20 PSI Max. 4000 Gal Cylindrical Fireguard	(814) 893-5701	UL	4979	With Build-in UL Listed Catchment Basin	Active
Modern Welding	Cylindrical Fireguard NYC 20 PSI Max. 4000 Gal	(614) 344-9425	UL	5039	With Build-in UL Listed Catchment Basin	Active
The Fort Miller Co., Inc.	NYC 30 PSI Armor Cast Max. 4000 Gal Rectangular	(518) 695-5000	UL	4983	Renewed / With Build-in UL Listed Catchment	Expired

Active:	New Installations Permitted
Expired:	No New Installations Permitted
Pending:	Expired and Renewal in Process. No new installations permitted at this time



# INSTRUCTION FOR PROCESSING

**DOCUMENT NAME: Above Ground Diesel Tanks**

**FOR PERMIT INQUIRY, PLEASE CALL (718) 999-2457 OR (718) 999-2516**

PURPOSE OF DOCUMENT:	WHO SHOULD USE THIS DOCUMENT?
TO PROVIDE AFFECTED INDUSTRY REPRESENTATIVES WITH THE CURRENT CERTIFICATE OF APPROVAL LIST.	<b>INSTALLERS</b> OR AUTHORIZED <b>REPRESENTATIVES</b> WHO MUST <b>INSTALL</b> OR <b>REPLACE</b> PETROLEUM RELATED PRODUCTS.

NOTICE	PAYMENT INFORMATION
Being Listed by the FDNY <b>DOES NOT</b> convey any endorsement of any product by this agency and/or the City of New York.	IS PAYMENT REQUIRED? NO IF SO, WHEN?  NEW YORK CITY FIRE DEPARTMENT  DO NOT SEND CASH!!!!

SPECIAL INSTRUCTIONS	FOR FURTHER QUESTIONS, CONTACT:
For Product information, pricing or other similar questions, contact the manufacturer or their New York representatives.	New York City Fire Department Bureau of Fire Prevention Anthony Hsueh Senior Project Manager 9 Metro Tech Center #3N-15 Brooklyn, NY 11201