



## CONSTRUCTION CODES UPDATE PAGES

Attached are Construction Codes Update Pages. These pages reflect local laws enacted and ministerial administrative corrections made after July 1, 2008. Please note that the source of a particular update, the local law number, and year is indicated on each page. Please visit our [webpage](#) to ensure that your codes are complete and up to date as the City Council may periodically pass Local Laws that affect the Construction Codes.

### **Instructions:**

Please place each page, according to its page number found on the bottom right hand corner, into your Construction Codes books. The pages contain letters after the page number and should be placed in alphabetical order following the number, i.e. 5, 6, 6a, 6b, etc.

- Place Title Pages in the front of your Code books for easy reference.
- Note: If you have all four Construction Codes (Building, Mechanical, Plumbing & Fuel Gas), please make sure to insert updates made to the Administrative Provisions into each of the four Code books.

# CONSTRUCTION CODES UPDATE PAGES

## UPDATE # 62

**Source: Section 3616-02 of Title 1 of the Rules of City of New York, effective November 11, 2009.**

This update includes the following pages:

<b>BUILDING CODE</b>	
<b><u>Section</u></b>	<b><u>Page Number</u></b>
Appendix Q102	770b

## CONSTRUCTION CODES UPDATE PAGE

Source: Section 3616-02 of Title 1 of the Rules of City of New York, effective November 11, 2009.

**BUILDING CODE**

*Insert between pages 770a and 771 of your bound volume.*

**1 RCNY §3616-02****CHAPTER 3600****Appendices****§3616-02 National Fire Protection Association (“NFPA”) 13 amendment relating to closets and pantries.**

Pursuant to Section 28-103.19 of the New York City Administrative Code, Section 8.14.8.2 of reference standard NFPA 13 is hereby deleted and a new section 8.14.8.2 is added, to read as follows:

**8.14.8.2\*** Closets and Pantries. Sprinklers are not required in clothes closets, linen closets, and pantries within:

(1) Dwelling units in hotels and motels where the area of the closet or pantry does not exceed 24 ft<sup>2</sup> (2.2 m<sup>2</sup>), the least dimension does not exceed 3 ft (0.9 m), and the walls and ceilings are surfaced with noncombustible or limited-combustible materials; and

(2) Dwelling units in Group R occupancies other than hotels and motels where the area of the closet or pantry does not exceed 12 ft<sup>2</sup> (1.1 m<sup>2</sup>), the room or space upon which the closet or pantry opens is equipped with sprinklers designed to afford protection to the opening of the closet or pantry, and the walls and ceilings of the closet or pantry are surfaced with noncombustible or limited-combustible materials.