



JEFFREY D. FRIEDLANDER
First Assistant Corporation Counsel

**THE CITY OF NEW YORK
LAW DEPARTMENT**
100 CHURCH STREET
NEW YORK, N.Y. 10007-2601

(212) 788-0700
FAX: (212) 227-5641
jfriedla@law.nyc.gov

**CERTIFICATION OF
CORPORATION COUNSEL**

I hereby certify that the form of the enclosed local law (Local Law No. 101 of 2013, Council Int No. 1099-A of 2013) to be filed with the Secretary of State contains the correct text of the local law passed by the New York City Council and approved by the Mayor.

KM
RM

A large, stylized handwritten signature in black ink, appearing to read "Jeffrey D. Friedlander".

JEFFREY D. FRIEDLANDER

Acting Corporation Counsel

(Please Use This Form for Filing your Local Law with the Secretary of State)

Text of law should be given as amended. Do not include matter being eliminated and do not use italics or underlining to indicate new matter.

County of New York
City of New York

Local Law No. 101 of the year 2013

By Council Members Richards, Chin, James, Koo, Lander, Mendez, Recchia, Rose, Barron, Van Bramer, Gennaro, Rodriguez, Jackson and Williams.

A Local Law to amend the New York city building code and the New York city mechanical code, in relation to preventing wind damage to certain buildings and systems.

Be it enacted by the Council as follows:

Section 1. Section 1609.1.2 of the New York city building code, as amended by a local law of the city of New York for the year 2013 amending the administrative code of the city of New York, the New York city plumbing code, the New York city building code, the New York city mechanical code and the New York city fuel gas code, relating to bringing such codes up to date with the 2009 editions of the international building, mechanical, fuel gas and plumbing codes, as proposed in Intro. 1056, is amended to read as follows:

1609.1.2 [Reserved.] Protection from wind borne debris. The following buildings shall be protected with an impact-resistant covering or glazing in accordance with the Missile Levels and Wind Zones specified in ASTM E1886 and ASTM E1996 or other approved test methods and performance criteria:

1. Buildings in Structural Occupancy Category IV, as defined in Table 1604.5, located in Exposure C or D, as defined in Section 1609.4;

2. Buildings in Structural Occupancy Category III, as defined in Table 1604.5, located in Exposure D, as defined in Section 1609.4, where the glazing of such building encloses places of

assembly for 300 or more persons or areas of in-place shelter.

Exception: Glazing protection in accordance with Section 1609.1.2 shall not be required if the glazing is located more than 60 feet (18 288 mm) above the ground and more than 30 feet (9144 mm) above aggregate-surfaced roofs, including roofs with gravel or stone ballast located within 1,500 feet (457.2 m) of the building.

1609.1.2.1 Louvers. Louvers protecting intake and exhaust ventilation ducts not assumed to be open that are located within 30 feet (9144 mm) of grade shall meet the requirements of an approved impact-resisting standard or the large missile test of ASTM E 1996.

1609.1.2.2 Garage doors. Garage door glazed opening protection for wind-borne debris shall meet the requirements of an approved impact-resisting standard or ANSI/DASMA 115.

§ 2. Chapter 4 of the New York city mechanical code, as amended by a local law of the city of New York for the year 2013 amending the administrative code of the city of New York, the New York city plumbing code, the New York city building code, the New York city mechanical code and the New York city fuel gas code, relating to bringing such codes up to date with the 2009 editions of the international building, mechanical, fuel gas and plumbing codes, as proposed in Intro. 1056, is amended by adding a new section 401.6.1 to read as follows:

401.6.1 Wind-driven rain rating. All exterior louvers for building ventilation systems shall either:

1. Receive an A rating according to AMCA Standard 550 for wind-driven rain penetration for a 50 mile per hour (80.4 km/h) wind velocity with a rainfall rate of eight inches (203 mm) per hour; or
2. Be installed on a plenum configured to intercept any wind-driven rain penetrating the louver and to prevent the rain from entering the building ductwork system. Such plenum

shall be waterproofed and equipped with a drainage system to convey water penetrating the louver to storm or sanitary drains.

§ 3. Chapter 5 of the New York city mechanical code, as amended by a local law of the city of New York for the year 2013 amending the administrative code of the city of New York, the New York city plumbing code, the New York city building code, the New York city mechanical code and the New York city fuel gas code, relating to bringing such codes up to date with the 2009 editions of the international building, mechanical, fuel gas and plumbing codes, as proposed in Intro. 1056, is amended by adding a new section 501.2.2.1 to read as follows:

501.2.2.1 Wind-driven rain rating. All exterior louvers for building exhaust systems shall either:

1. Receive an A rating according to AMCA Standard 550 for wind-driven rain penetration for a 50 mile per hour (80.4 km/h) wind velocity with a rainfall rate of eight inches (203 mm) per hour; or

2. Be installed on a plenum configured to intercept any wind-driven rain penetrating the louver and to prevent the rain from entering the building ductwork system. Such plenum shall be waterproofed and equipped with a drainage system to convey water penetrating the louver to storm or sanitary drains.

§ 4. Chapter 35 of the New York city building code, as amended by a local law of the city of New York for the year 2013 amending the administrative code of the city of New York, the New York city plumbing code, the New York city building code, the New York city mechanical code and the New York city fuel gas code, relating to bringing such codes up to date with the 2009 editions of the international building, mechanical, fuel gas and plumbing codes, as proposed in

Intro. 1056, is amended by adding new reference standards ASTM E 1886, ASTM E 1996, and ANSI/DASMA 115 to read as follows:

ASTM

ASTM International 100 Barr Harbor Drive West Conshohocken, PA 19428-2959

<u>Standard Reference Number</u>	<u>Title</u>	<u>Referenced in code section number</u>
<u>E 1886-06</u>	<u>Standard Test Method for Performance of Exterior Windows, Curtain Walls, Doors, and Impact Protective Systems Impacted by Missile(s) and Exposed to Cyclic Pressure Differentials</u>	<u>1609.1.2</u>
<u>E 1996-09</u>	<u>Standard Specification for Performance of Exterior Windows, Curtain Walls, Doors, and Impact Protective Systems Impacted by Windborne Debris in Hurricanes</u>	<u>1609.1.2, 1609.1.2.1</u>

DASMA

Door and Access Systems Manufacturers Association International 1300 Summer Avenue Cleveland, OH 44115-2851

<u>Standard reference number</u>	<u>Title</u>	<u>Referenced in code section number</u>
<u>115-05</u>	<u>Standard Method for Testing Sectional Garage Doors and Rolling Doors: Determination of Structural Performance Under Missile Impact and Cyclic Wind Pressure</u>	<u>1609.1.2.2</u>

§ 5. Chapter 15 of the New York city mechanical code, as amended by a local law of the city of New York for the year 2013 amending the administrative code of the city of New York, the New York city plumbing code, the New York city building code, the New York city mechanical code and the New York city fuel gas code, relating to bringing such codes up to date with the 2009 editions of the international building, mechanical, fuel gas and plumbing codes, as proposed in Intro. 1056, is amended by adding new reference standard AMCA 550 as follows:

AMCA

Air Movement and Control Association International 30 West University Drive Arlington Heights, IL 60004

<u>Standard Reference Number</u>	<u>Title</u>	<u>Referenced in code section number</u>
<u>550-09</u>	<u>Test Method for High Velocity Wind Driven Rain Resistant Louvers</u>	<u>401.6.1, 501.2.2.1</u>

§ 6. This local law shall take effect on the same date as a local law of the city of New York for the year 2013 amending the administrative code of the city of New York, the New York city plumbing code, the New York city building code, the New York city mechanical code and the New York city fuel gas code, relating to bringing such codes up to date with the 2009 editions of the international building, mechanical, fuel gas and plumbing codes, as proposed in Intro. 1056, takes effect.

THE CITY OF NEW YORK, OFFICE OF THE CITY CLERK, s.s.:

I hereby certify that the foregoing is a true copy of a local law of The City of New York, passed by the Council on October 30, 2013 and approved by the Mayor on November 19, 2013.

A handwritten signature in black ink, appearing to read "Michael M. McSweeney", written over a horizontal line.

**MICHAEL M. McSWEENEY, City Clerk
Clerk of the Council.**