

ADVISORY BOARD CALENDAR

January 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
	15A0588CO	Requested approval for the electric service equipment proposed to be installed	Denied	\$0.00
Carry over from October 21, 2015 meeting. 1) Neutral disc not shown on one line. 2) Provide sequence of operation for GFI on double bonded switches. 3) Oversized protection on fire pump EM sync board. 4) No PE stamp.				
	16A0001	Requesting permission to install medium voltage MV-105 jacketed MC cable indoors in a cable tray and outdoors underground between buildings for a permanent installation	Denied	\$0.00
This installation does not comply with Sections 328.12(2) and 330.12(5) of the NYC Electrical Code.				
53625	16A0002	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Equipment grounding conductors for fire pump undersized. 2) Coordination study to be performed and stamped by a P.E. 3) Provide ground fault sequence, and verify GFI c/ 7 locations. 4) Size of bonding strap size. 3/29/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/27/18 - swap dwg # 1 of 7 & 2 of 7 Rev 2 7/30/18 - Fire alarm GEC is undersized T-250.66. 10/4/18 1) Fire alarm GEC is undersized-T250.66.(Item #1 not addressed from previous revision). 4/25/19 Swap dwg 1 of 7-Rev-3, 2 of 7-Rev-14, 4 of 7-Rev-0 and EJ-AB.RIS.01. 3/2/2020 Swap dwg # 1 of 7-Revision 5, dwg 2 of 7-Revision 17, dwg #3 of 7-Revision 3, dwg #4 of 7-Revision 2 and E-J505-RIS.01-Revision 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
53427	16A0006	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/1/17 - swap dwg 1 of 2 Rev 3, 2 of 2 rev 3				
	16A0011	Requested approval for the electric service equipment proposed to be installed	Administrative Closure	\$650.00
Provide short circuit calculation and rating for switchboard led. 5/24/16 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/17/16 This calendar number is void in lieu of submittal number 16A0541.				

ADVISORY BOARD CALENDAR

January 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53554	16A0013	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Correct note #5 or correct fuses. 2) Verify meter bank #s on each drawing. 2/25/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/27/17 - Swap dwg A rev 2, Dwg B Rev 3				
53407	16A0014	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/17/16 Swapped drawing A-Revision 1. 5/3/19 Swap dwg #A-Revision 3.				
	16A0015	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
Provide coordination between 1st and 2nd levels.				
53430	16A0018	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/28/17 - swap dwg 1 rev 1				
53421	16A0019	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

January 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
	16A0021	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Verify size of main bonding jumper. 2) If MI cable is terminated to switch lugs provide manufacturer's installation instructions for MI cable. 3) If MI cable is terminated to switch lugs provide manufacturer's installation instructions for MI cable. 4) Verify service entrance conductors to fire alarm service switch and ATS, 350 s terminated to 100 amp switch. 5) Service entrance conductors to DS-R7 undersized. 6) Coordination study not submitted and must be performed signed and sealed by a P.E. 7) Show conductor sizes between circuit breaker panels in MPP-PH1. 8) Slow length of transformer secondary conductors. 9) Co-gen #2s fused at 150 amps. 10) Incoming fault current not shown with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				
	16A0022	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
<p>1) Where is the service located in relation to incoming Con-ED cable. 2) Normal service and emergency system contained in the same room. 3) Entire emergency room to be shown. 4) Coordination study not provided. 5) Someone who designed installation to appear for next submittal.</p>				

ADVISORY BOARD CALENDAR

January 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
54231	16A0023	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Verify concrete encased service entrance conductors inside of Con ED end boxes. 2) Show how taps will be in trough. 3) MS-B through bus feeding 2500 and 1600 amp service switches undersized. 4) Section bus in TDP-2N--A., TDP-2N-B undersized. 5) Provide reduced neutral call for TDP-2N-B and TDP-2N-A. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6) TRX T-2 secondary switch must be provided with GFI. 7) TRX T-2 grpimd tp be pm "Y" side. 8) Verify 750 KVA venting clearance from wall 6" or 12". 8/18/16 Item 4 not addressed. 2) UL 2200 is for the genrator only not complete genset. Submitter is to provide the information not the Advisory as per submitters letter. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 11/29/16 This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/26/18 - swap dwg AB10 - 1 of 2 Rev 2 , AB 10-2 of 2, Rev 3, FP20-1 of 1 Rev 2, SB10 - 1 of 5 Rev 2, SB10 - 2 of 5 Rev 2</p>				
53431	16A0024	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/4/18 - Provide coordination between 1500A KRPC & upstream fuse. 3/8/18 - swap dwg AB50 1 of 1 Rev 1</p>				

ADVISORY BOARD CALENDAR

January 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
	16A0025	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Provide physical for substations 1 and 2. 2) Secondaries of transformers not bonded and grounded. 3) Remove disconnect switches on secondary side of fire pump transformers. 4) Fire pump service entrance conductors and feeders to fire pump transformers are undersized. 5) MVPC 1200 amp 480V switch not ground fault protected. 6) Confirm that no emergency system is required in this building. 7) coordination study not provided. 8) Is fire pump #4, explain GFS (typo) in service switch.</p>				
	16A0028	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
<p>1) What is new and what is existing? 2) This instalation was approved on 5/25/2011 Approval #50670. The additons on this drawing shall be bubbled.</p>				
53405	16A0029	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53404	16A0030	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/9/19 Swap dwg #A2-Revision 1. 7/23/19 1) Electrician license number is missing. 2) Provide coordination between 1200 A existing fuse & new 350 A A2D fuse. 3) Doors shall be open outward. 10/25/19 Swap dwg #A2-Revision 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 1/13/2020 Swap dwg A2-Revision 4, Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.. 2/24/2020 Swap dwg D-1512-27397-A2-Revision 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
53403	16A0031	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

January 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53434	16A0032	Requesting permission in a existing building that is undergoing a complete replacement of the fire alarm system due to damage from Hurricane Sandy to allow the use of Vitalink 2 hour fire rated MC cable due to extremely congested and complicated routing paths where the cables will be installed well above 8' off of the floor in Section 760,52(A) and 760.46 locations.	Approved	\$350.00
Code: 760.52 and 760.46. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53409	16A0033	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53829	16A0034	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Tapped conductor undersized. 5/20/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				
53410	16A0035	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53435	16A0036	Requesting permission to leave as installed due to extreme hardship to relocate a circuit breaker panel installed above the kitchen counter top.	Approved	\$350.00
Code: 110.26(A)(3) Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53411	16A0038	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

January 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53832	16A0039	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Show that 2nd fuses coordinate with main fuse. 5/23/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				
	16A0040	Requested approval for the electric service equipment proposed to be installed	Administrative Closure	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/7/16 This submittal void. See Cal. #53638. It had duplicate #53412.				
53413	16A0041	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/2/18 1) Provide coordination between 1200A A4BQ and upstream fuse 4000A KTV. 8/2/18 - swap dwg A Rev 1				
53773	16A0042	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>[1] Equipment cut sheets not complete, service switchboard and distribution boards. 2) Show conductor size and wiring method to load bank with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2/25/16 Rejected. Verify fire pump note. 3/15/16 Normal feeder for the fire pump rejected not fire rated. 4/21/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>				
53429	16A0044	Requesting permission utilize section 690.7(c) of the NEC to allow the installation of listed 1000 volt solar photovoltaic equipment, solar edge SE20KUS inverter, solar edge power optimizer P600 and P700 and solar bos source circuit combiners in a building located at 2791 University Avenue, Bronx, NY, 10468	Approved	\$0.00
OR Code: 110.2(B) (5) With the stipulation that this permission is for the usage of solar photovoltaic equipment only, installation is subject to field inspection.				

ADVISORY BOARD CALENDAR

January 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53420	16A0045	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53428	16A0046	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53656	16A0047	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 1) Primary of transformer bonded and grounded instead of secondary. 2) Transformer secondary to be bonded and grounded in one location only. 3) Add note on drawing showing compliance with 692.4(B), 692.65(B)(4) and 692.17. 4/18/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				
53425	16A0048	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: With the stipulation that signage is installed showing compliance with sections 692.4(B), 692.65(B)(4) and 692.17 Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				
53415	16A0049	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR With the stipulation that signage is installed showing compliance with sections 692.4(B), 692.17 and 692.65(B)(4). 3/21/16 Drawing Swapped ATL-D1512178-OP, Revision 2.				
53416	16A0050	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR With the stipulation that signage is installed showing compliance with sections 692.4(B), 692.17 and 692.65(B)(4). 3/21/16 Swapped drawing ATL-D 1512179-OP-Revision 2. 6/28/16 Swapped Drawing-OP-Revision 3.				

ADVISORY BOARD CALENDAR

January 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53797	16A0051	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 1) Primary of transformer bonded and grounded instead of secondary. 2) Add note on drawing showing compliance with 692.4(B), 692.65(B)(4), 692.17. 5/3/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				
	16A0052	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
OR Service bus undersized to add new 400 amp service switch.				
53655	16A0053	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Primary of transformer grounded and bonded instead of transformer secondary. 2) Add note on drawing showing compliance with 692.4(B), 692.65(B)(4) and 692.17. 4/18/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				
	16A0054	Requested approval for the electric service equipment proposed to be installed	Rejected	\$650.00
OR With the stipulation that signage is installed showing compliance with sections 692.4(B), 692.65(B)(4) and 692.17. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/21/16 Swapped Drawing ATL-D 1512175-OP, Revision 2. 5/23/16 Swapped drawing-OP-Revision 3. 10/26/16 Rejected Contractor changed. New filing required.				
53541	16A0060	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Correct note #5 on drawing to match 1 Line. 2/18/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/11/2017 - section 3 in switchboard # 2 & section 2 in switchboard # 1 vertical buses are undersized.7/26/17 - swap Dwg A rev 5, Dwg B rev 4				
53422	16A0062	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

January 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53423	16A0063	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/23/16 Swapped drawing 1-Revision 1.				
53432	16A0064	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/8/2017 - swap dwg rev 1				
53424	16A0065	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	16A0066	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Add note under emergency switchboard if 3 or 4 pole ATS' are being installed. 2) Provide full reduced neutral calculations with voltage drop calculations. 3) Verify amount of conductors in conduit for fire pump with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				
53419	16A0072	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/8/16 Swapped drawing #EAB-1589-A.1 10/24/17 - swap dwg EAB-1589-A.2 Rev 2 11/28/17 - Swap Dwg 1 Rev 3 - No more swaps				

ADVISORY BOARD CALENDAR

January 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53433	16A0074	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/25/16 Swapped drawing 1, Revision 1. 5/23/16 Swapped drawing 1-Revision 2.				
	16A0076	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
1) Drawing not in Advisory Board format. 2) Coordination study signed and stamped by a P.E. not submitted.				
53406	16A0077	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53408	16A0078	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/18/19 Swap Dwg A-Revision 2 12/18/19 Swap Dwg # A Rev-3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
53479	16A0086	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR 1) Equipment grounding conductor from transformer secondary to 400 amp switch undersized. 2) Transformer bonded and grounded on primary side of transformer. 3) Cover letter to request permission to install PV equipment above 600 volts. 4) This approval is limited to the final connection to 1000 KVA service only. 2/4/16 ok with the stipulations: 1) The equipment grounding from the transformer to the 400 amp disconnect switch is a 1/0 conductor. 2) 1000 VDC 23/28 and 36 KW string inverters for North America, Hyundai T1-Series Solar Modules, JAP6 72/300-320/3BB modules and locus LG Gate 360 commercial solar monitoring solution components are installed. 3) This approval is limited to the final connection to the 1000 KVA service and 1000 VDC equipment only. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/16/16 Rejected 1) Equipment grounding conductor between transformer secondary and 400 amp disconnect switch. 2) #4 AWG equipment grounding conductor between panelboard and transformer not identified. 3/25/16 Swapped drawing AB50-01-Revision 2 with the stipulation that the equipment grounding conductor from the transformer to the 400 amp switch is size 1/0 copper and EGC from 400 amp switch to main distribution board is 250 KCM copper.				

ADVISORY BOARD CALENDAR

January 13, 2016

Approval #	Submission #	Type of Request	Status	Fee
53480	16A0087	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR 1) Transformer bonded and grounded on primary side not secondary side. 2) Cover letter to request to request permission to install PV equipment over 600 volts. 3) This approval is limited to the final connection to 1000 KVA service only. 2/4/16 Job finalized. 2/4/16 ok with the stipulations: 1) 1000 VDC 23/28 and 36 KW string inverters for North America, Hyundai T1-Series Solar Modules, JAP6 72/300-320/3BB modules and Locus LG Gate 360 commercial solar monitoring solution components are installed. 2) This approval is limited to the final connection to the 1000 KVA service and 1000 VDC equipment only. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/16/16 Rejected. Drawings FP 50-01, Revision 1 and AB 50-01, Revision 1 were approved on 1/13/16. Received on 1/20/16 are FP50-01 Revision 0, and AB50-01, Revision 1 which are correct? 3/25/16 Swapped drawing AB50-01-Revision 2.</p>				