

ADVISORY BOARD CALENDAR

January 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	15A0588CO	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Brooklyn Navy Yard 63 Flushing Avenue, Bldg. #77 Brooklyn NY	Denied	\$0.00
Carry over from October 21, 2015 meeting. 1) Neutral disc not shown on one line. 2) Provide sequence of operation for GFI on double bonded switches. 3) Oversized protection on fire pump EM sync board. 4) No PE stamp.						
	16A0001	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requesting permission to install medium voltage MV-105 jacketed MC cable indoors in a cable tray and outdoors underground between buildings for a permanent installation	NYU Kimmel Pavilion 424 East 34th Street New York NY	Denied	\$0.00
This installation does not comply with Sections 328.12(2) and 330.12(5) of the NYC Electrical Code.						
53625	16A0002	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NYU Kimmel Pavilion 424 East 34th Street New York NY	Approved	\$650.00
1) Equipment grounding conductors for fire pump undersized. 2) Coordination study to be performed and stamped by a P.E. 3) Provide ground fault sequence, and verify GFI c/ 7 locations. 4) Size of bonding strap size. 3/29/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53427	16A0006	Zerem Electric Corp. 3011 Avenue L Brooklyn NY 11210	Requested approval for the electric service equipment proposed to be installed	100 Steuben Street Brooklyn NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0011	Hatzel & Buehler, Inc. 45 Broadway New York NY 10006	Requested approval for the electric service equipment proposed to be installed	SL Green 719 7th Avenue New York NY	Administrative Closure	\$650.00
Provide short circuit calculation and rating for switchboard led. 5/24/16 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/17/16 This calendar number is void in lieu of submittal number 16A0541.						

ADVISORY BOARD CALENDAR

January 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53554	16A0013	KNC Electric Inc. 187-27 Linden Blvd. St. Albans NY 11412	Requested approval for the electric service equipment proposed to be installed	267 Rogers Avenue Brooklyn NY	Approved	\$650.00
1) Correct note #5 or correct fuses. 2) Verify meter bank #s on each drawing. 2/25/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53407	16A0014	Meir Electrical Corp. 423 East 78th Street New York NY 10021	Requested approval for the electric service equipment proposed to be installed	American Jewish Committee 165 East 56th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/17/16 Swapped drawing A-Revision 1.						
	16A0015	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	919 3rd Avenue New York NY	On Hold	\$650.00
Provide coordination between 1st and 2nd levels.						
53430	16A0018	Right Away Electric, LLC 56-15 Andrews Avenue Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	504 Myrtle Avenue Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53421	16A0019	NYC Electrical Contracting Inc. 150 52nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	167 Graham Avenue Brooklyn NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

January 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0021	I.P. Electrical Inc. 143 30th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	320 West 36th Street New York NY	On Hold	\$650.00
<p>1) Verify size of main bonding jumper. 2) If MI cable is terminated to switch lugs provide manufacturer's installation instructions for MI cable. 3) If MI cable is terminated to switch lugs provide manufacturer's installation instructions for MI cable. 4) Verify service entrance conductors to fire alarm service switch and ATS, 350 s terminated to 100 amp switch. 5) Service entrance conductors to DS-R7 undersized. 6) Coordination study not submitted and must be performed signed and sealed by a P.E. 7) Show conductor sizes between circuit breaker panels in MPP-PH1. 8) Slow length of transformer secondary conductors. 9) Co-gen #2s fused at 150 amps. 10) Incoming fault current not shown with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
	16A0022	Nead Electric, Inc. 350 West 50th Street New York NY 10110	Requested approval for the electric service equipment proposed to be installed	375 Pearl Street New York NY	Denied	\$650.00
<p>1) Where is the service located in relation to incoming Con-ED cable. 2) Normal service and emergency system contained in the same room. 3) Entire emergency room to be shown. 4) Coordination study not provided. 5) Someone who designed installation to appear for next submittal.</p>						

ADVISORY BOARD CALENDAR

January 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
54231	16A0023	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	525 West 52nd Street New York NY	Approved	\$650.00

1) Verify concrete encased service entrance conductors inside of Con ED end boxes. 2) Show how taps will be in trough. 3) MS-B through bus feeding 2500 and 1600 amp service switches undersized. 4) Section bus in TDP-2N--A., TDP-2N-B undersized. 5) Provide reduced neutral call for TDP-2N-B and TDP-2N-A. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.

The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.

NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6) TRX T-2 secondary switch must be provided with GFI. 7) TRX T-2 grpmid tp be pm "Y" side. 8) Verify 750 KVA venting clearance from wall 6" or 12". 8/18/16 Item 4 not addressed. 2) UL 2200 is for the generator only not complete genset. Submitter is to provide the information not the Advisory as per submitters letter. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.

The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.

NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 11/29/16 This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.

The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.

NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.

Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.

53431	16A0024	Caruso & Sons Electrical Contracting, Inc. 412 City Island Avenue Bronx NY 10464	Requested approval for the electric service equipment proposed to be installed	25-20 BQE West Woodside NY 11377	Approved	\$650.00
-------	---------	--	--	-------------------------------------	----------	----------

Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.

ADVISORY BOARD CALENDAR

January 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0025	DeFalco Electric 25-54 22nd Street Astoria NY 11102	Requested approval for the electric service equipment proposed to be installed	111 West 57th Street New York NY	On Hold	\$650.00
1) Provide physical for substations 1 and 2. 2) Secondaries of transformers not bonded and grounded. 3) Remove disconnect switches on secondary side of fire pump transformers. 4) Fire pump service entrance conductors and feeders to fire pump transformers are undersized. 5) MVPC 1200 amp 480V switch not ground fault protected. 6) Confirm that no emergency system is required in this building. 7) coordination study not provided. 8) Is fire pump #4, explain GFS (typo) in service switch.						
	16A0028	Allan Briteway Electrical Contractors, Inc. 360 Lexington Avenue New York NY 10017	Requested approval for the electric service equipment proposed to be installed	Weill Cornell Medical College 413 East 69th Street New York NY	Denied	\$650.00
1) What is new and what is existing? 2) This instalation was approved on 5/25/2011 Approval #50670. The additons on this drawing shall be bubbled.						
53405	16A0029	Einstein Electrical Corporation 42-16 28th Avenue Astoria NY 11101	Requested approval for the electric service equipment proposed to be installed	Carlton Hotel 18 East 29th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53404	16A0030	Einstein Electrical Corporation 42-16 28th Avenue Astoria NY 11101	Requested approval for the electric service equipment proposed to be installed	Hampton House 404 East 79th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53403	16A0031	AMC Electrical Services, Inc. 140 18th Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	60 Hudson Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

January 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53434	16A0032	Jaros Baum & Bolles Consulting Engs 80 Pine Street New York NY 10005	Requesting permission in a existing building that is undergoing a complete replacement of the fire alarm system due to damage from Hurricane Sandy to allow the use of Vitalink 2 hour fire rated MC cable due to extremely congested and complicated routing paths where the cables will be installed well above 8' off of the floor in Section 760,52(A) and 760.46 locations.	55 Water Street New York NY	Approved	\$350.00

Code: 760.52 and 760.46. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.

53409	16A0033	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	60 Riverside Drive New York NY	Approved	\$650.00
-------	---------	---	--	-----------------------------------	----------	----------

OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.

53829	16A0034	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	300 East 39th Street New York NY	Approved	\$650.00
-------	---------	---	--	-------------------------------------	----------	----------

OR Tapped conductor undersized. 5/20/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements

53410	16A0035	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	250 West 50th Street New York NY	Approved	\$650.00
-------	---------	---	--	-------------------------------------	----------	----------

OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.

53435	16A0036	Philip A. Robinson, Lic. Electrician 235 Fifth Avenue Brooklyn NY 11215	Requesting permission to leave as installed due to extreme hardship to relocate a circuit breaker panel installed above the kitchen counter top.	50 East 72nd Street, Apt 10C New York NY	Approved	\$350.00
-------	---------	---	--	---	----------	----------

Code: 110.26(A)(3) Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.

ADVISORY BOARD CALENDAR

January 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53411	16A0038	Kleinknecht Electric Company, Inc. 252 West 37th Street, 9th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Verizon 12 East 49th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53832	16A0039	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Regeis Care Center 3200 Baychester Avenue Bronx NY	Approved	\$650.00
OR Show that 2nd fuses coordinate with main fuse. 5/23/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
	16A0040	Triple I Electrical Contracting, Inc. 64-05 34th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Steel Works 76 North 4th Street Brooklyn NY	Administrative Closure	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/7/16 This submittal void. See Cal. #53638.						
53413	16A0041	Campbell and Dawes Ltd. Electrical Contr 84-48 129th Street Kew Gardens NY 11415	Requested approval for the electric service equipment proposed to be installed	Vornado Realty Trust 608 5th Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

January 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53773	16A0042	Hellman Electric Corporation 855 Brush Avenue Bronx NY 10465	Requested approval for the electric service equipment proposed to be installed	P.S. 11Q 54-25 Skillman Avenue Woodside NY	Approved	\$650.00
<p>[1] Equipment cut sheets not complete, service switchboard and distribution boards. 2) Show conductor size and wiring method to load bank with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 2/25/6 Rejected. Verify fire pump note. 3/15/16 Normal feeder for the fire pump rejected not fire rated. 4/21/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>						
53429	16A0044	R.J. Russo Electric Co. 45-57 Bell Blvd. Bayside NY 11361	Requesting permission utilize section 690.7(c) of the NEC to allow the installation of listed 1000 volt solar photovoltaic equipment, solar edge SE20KUS inverter, solar edge power optimizer P600 and P700 and solar bos source circuit combiners in a building located at 2791 University Avenue, Bronx, NY, 10468	2791 University Avenue Bronx NY	Approved	\$0.00
OR Code: 110.2(B) (5) With the stipulation that this permission is for the usage of solar photovoltaic equipment only, installation is subject to field inspection.						
53420	16A0045	Metro Electrical Contractors, Inc. 100 Beard Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	110 Beard Street Brooklyn NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53428	16A0046	Patriot Electric Corp. 58-71 57th Road Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	Foot Locker 112 West 34th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

January 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53656	16A0047	J.V.C. Electric Service Corp. 3475 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	The Home Depot 92-30 168th Street Jamaica NY	Approved	\$650.00
OR 1) Primary of transformer bonded and grounded instead of secondary. 2) Transformer secondary to be bonded and grounded in one location only. 3) Add note on drawing showing compliance with 692.4(B), 692.65(B)(4) and 692.17. 4/18/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
53425	16A0048	J.V.C. Electric Service Corp. 3475 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	The Home Depot 124-04 31st Avenue Flushing NY	Approved	\$650.00
OR Disclaimer: With the stipulation that signage is installed showing compliance with sections 692.4(B), 692.65(B)(4) and 692.17 Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
53415	16A0049	J.V.C. Electric Service Corp. 3475 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	The Home Depot 2750 Veterans Road Staten Island NY	Approved	\$650.00
OR With the stipulation that signage is installed showing compliance with sections 692.4(B), 692.17 and 692.65(B)(4). 3/21/16 Drawing Swapped ATL-D1512178-OP, Revision 2.						
53416	16A0050	J.V.C. Electric Service Corp. 3475 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	The Home Depot 579 Gateway Drive Brooklyn NY	Approved	\$650.00
OR With the stipulation that signage is installed showing compliance with sections 692.4(B), 692.17 and 692.65(B)(4). 3/21/16 Swapped drawing ATL-D 1512179-OP-Revision 2. 6/28/16 Swapped Drawing-OP-Revision 3.						
53797	16A0051	J.V.C. Electric Service Corp. 3475 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	The Home Depot 11220 Rockaway Blvd. South Ozone Park NY	Approved	\$650.00
OR 1) Primary of transformer bonded and grounded instead of secondary. 2) Add note on drawing showing compliance with 692.4(B), 692.65(B)(4), 692.17. 5/3/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						

ADVISORY BOARD CALENDAR

January 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0052	J.V.C. Electric Service Corp. 3475 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	The Home Depot 2970 Cropsey Avenue Brooklyn NY	Pending	\$650.00
OR Service bus undersized to add new 400 amp service switch.						
53655	16A0053	J.V.C. Electric Service Corp. 3475 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	The Home Depot 131-35 Avery Avenue Flushing NY	Approved	\$650.00
1) Primary of transformer grounded and bonded instead of transformer secondary. 2) Add note on drawing showing compliance with 692.4(B), 692.65(B)(4) and 692.17. 4/18/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
	16A0054	J.V.C. Electric Service Corp. 3475 Victory Blvd. Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	The Home Depot 2501 Forest Avenue Staten Island NY	Rejected	\$650.00
OR With the stipulation that signage is installed showing compliance with sections 692.4(B), 692.65(B)(4) and 692.17. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/21/16 Swapped Drawing ATL-D 1512175-OP, Revision 2. 5/23/16 Swapped drawing-OP-Revision 3. 10/26/16 Rejected Contractor changed. New filing required.						
53541	16A0060	Delco Electrical Corp. 241 West 37th Street, Suite700 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Marcus Garvey Houses 353 Chester Street Brooklyn NY	Approved	\$650.00
Correct note #5 on drawing to match 1 Line. 2/18/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53422	16A0062	Positive Electrical Associates, Inc. 40-33 23rd Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	I.S. 229 Bronx 275 Harlem River Park Bridge Bronx NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

January 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53423	16A0063	Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	135 Madison Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/23/16 Swapped drawing 1-Revision 1.						
53432	16A0064	Reliant Electrical Contracting, Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	603 Mother Gaston Blvd. Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53424	16A0065	Qncc Electric 86-40 122nd Street Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	211 Central Park West New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0066	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	33 Bond Street Brooklyn NY	On Hold	\$650.00
<p>1) Add note under emergency switchboard if 3 or 4 pole ATS' are being installed. 2) Provide full reduced neutral calculations with voltage drop calculations. 3) Verify amount of conductors in conduit for fire pump with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
53419	16A0072	Patriot Electric Corp. 58-71 57th Road Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	Medeast 255 Greenwich Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/8/16 Swapped drawing #EAB-1589-A.1						

ADVISORY BOARD CALENDAR

January 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53433	16A0074	Rightway Electrical Inc. 18 Orchard Street, 1st Floor New York NY 10002	Requested approval for the electric service equipment proposed to be installed	156 Tillary Street Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/25/16 Swapped drawing 1, Revision 1. 5/23/16 Swapped drawing 1-Revision 2.						
	16A0076	New York Environmental Protection 96-05 Horace Harding Expressway Corona NY 11368	Requested approval for the electric service equipment proposed to be installed	Douglaston Pumping Station Queens NY	Denied	\$650.00
1) Drawing not in Advisory Board format. 2) Coordination study signed and stamped by a P.E. not submitted.						
53406	16A0077	Dooley Electric Co., Inc. 4014 3rd Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Citigroup Imaging Center Bldg. 516 East 72nd Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53408	16A0078	I.P. Electrical Inc. 143 30th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	219 East 44th Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53479	16A0086	Walsh Electrical Contracting Inc. 15 Newark Avenue Staten Island NY 10302	Requested approval for the electric service equipment proposed to be installed	121-10 Rockaway Blvd. Queens NY	Approved	\$650.00
OR 1) Equipment grounding conductor from transformer secondary to 400 amp switch undersized. 2) Transformer bonded and grounded on primary side of transformer. 3) Cover letter to request permission to install PV equipment above 600 volts. 4) This approval is limited to the final connection to 1000 KVA service only. 2/4/16 ok with the stipulations: 1) The equipment grounding from the transformer to the 400 amp disconnect switch is a 1/0 conductor. 2) 1000 VDC 23/28 and 36 KW string inverters for North America, Hyundai T1-Series Solar Modules, JAP6 72/300-320/3BB modules and locus LG Gate 360 commercial solar monitoring solution components are installed. 3) This approval is limited to the final connection to the 1000 KVA service and 1000 VDC equipment only. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/16/16 Rejected 1) Equipment grounding conductor between transformer secondary and 400 amp disconnect switch. 2) #4 AWG equipment grounding conductor between panelboard and transformer not identified. 3/25/16 Swapped drawing AB50-01-Revision 2 with the stipulation that the equipment grounding conductor from the transformer to the 400 amp switch is size 1/0 copper and EGC from 400 amp switch to main distribution board is 250 KCM copper.						

ADVISORY BOARD CALENDAR

January 13, 2016

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53480	16A0087	Walsh Electrical Contracting Inc. 15 Newark Avenue Staten Island NY 10302	Requested approval for the electric service equipment proposed to be installed	133-25 Guy R. Brewer Blvd. Queens NY	Approved	\$650.00
<p>OR 1) Transformer bonded and grounded on primary side not secondary side. 2) Cover letter to request to request permission to install PV equipment over 600 volts. 3) This approval is limited to the final connection to 1000 KVA service only. 2/4/16 Job finalized. 2/4/16 ok with the stipulations: 1) 1000 VDC 23/28 and 36 KW string inverters for North America, Hyundai T1-Series Solar Modules, JAP6 72/300-320/3BB modules and Locus LG Gate 360 commercial solar monitoring solution components are installed. 2) This approval is limited to the final connection to the 1000 KVA service and 1000 VDC equipment only. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/16/16 Rejected. Drawings FP 50-01, Revision 1 and AB 50-01, Revision 1 were approved on 1/13/16. Received on 1/20/16 are FP50-01 Revision 0, and AB50-01, Revision 1 which are correct? 3/25/16 Swapped drawing AB50-01-Revision 2.</p>						