

ADVISORY BOARD CALENDAR

January 14, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
44556CO	02A0780	Cabin Electric Inc. 77 Commerce Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	Acorn High School 1396 Broadway Brooklyn NY	Approved	\$250.00
Carried over from December 11, 2002 meeting.						
45260CO	03A0580CO	Livingston Electrical Associates, Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	New Fire Alarm System 9 West 57th Street New York NY	Approved	\$250.00
Carried over from October 15, 2003 meeting.						
45355CO	03A0651CO	Kleinknecht Electric Company, Inc. 940 Eighth Avenue New York NY 10019	Requested approval for the electric service equipment proposed to be installed	Citibank One Court Square Long Island City NY	Approved	\$250.00
Carried over from December 17, 2003 meeting						
45368CO	03A0663CO	Gessin Electrical Contractors, Inc. 791 East 139th Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	Bradhurst Court 300 West 145th Street New York NY	Ok, but	\$250.00
Carried over from December 17, 2003 meeting. Block off access to rear of switchboards.						
45405CO	----	Consentini Associates Consulting Engs. Two Pennsylvania Plaza New York NY 10121	Requesting permission to leave as installed a 480 volt 400 amp automatic transfer switch with external bypass with a front clearance of 2' 6 1/2". The original ATS did not include an external bypass.	1345 Avenue of the Americas New York NY	Denied	\$0.00
See Section 110-26.(a) for the correct equipment clearance distances. Carried over from December 17, 2003 meeting.						

ADVISORY BOARD CALENDAR

January 14, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45414	04A0018	Zwicker Electric Co., Inc. 200 Park Avenue South New York NY 10003	Requested approval for the electric service equipment proposed to be installed	9 Metro Tech South Brooklyn NY	Approved	\$650.00
45415	04A0016	Sage Electrical Contracting 651 Willowbrook Road, Suite 201 Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Fiber Net Telecom Group 60 Hudson Street New York NY	Approved	\$650.00
45416	04A0014	A & M Electrical Service Inc. 5309 2nd Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	260 Park Avenue South New York NY	Approved	\$650.00
45417	04A0013	A & M Electrical Service Inc. 5309 2nd Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	414 Flushing Avenue Brooklyn NY	Approved	\$650.00
45418	04A0020	Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	The Rockefeller University 1230 York Avenue New York NY	Ok, But	\$650.00
Provide GFP per 215-10.						

ADVISORY BOARD CALENDAR

January 14, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45419	04A0017	L.K. Comstock & Company, Inc. 1560 Broadway-Suite 1214 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Random House 235 West 55th Street New York NY	Hold	\$650.00
Clarify scope of submission.						
45420	04A0005	Tru-Val Electric Corp. 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	2601 Ocean Parkway Brooklyn NY	Ok, but	\$650.00
On the 1200 amp service switch that feeds ATS-EL, either decrease the fusing or increase the conductors.						
45421	04A0001	Mage Electrical Contractors 158 Perry Street New York NY 10014	Requested approval for the electric service equipment proposed to be installed	740 Broadway New York NY	Approved	\$650.00
45422	03A0703	Ideal Electric & HVAC Co., Inc. 235 India Street Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	Pagano Residence 1060 5th Avenue-Apt. 11C-11D New York NY	Hold	\$250.00
45423	04A0012	M.O.S. Electrical Contracting Corp. 4340B Katonah Avenue Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	450 North End Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

January 14, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45424	04A0015	Hugh O Kane Electric Company LLC 30-40 48th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Time and Life Bldg. 1271 Avenue of the Americas New York NY	Approved	\$650.00
45425	04A0011	Innovative Client Solutions 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	485 First Avenue New York NY	Approved	\$650.00
45426	04A0010	Izzo Electric Inc. 2522 E. Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	304 West 117th Street New York NY	Approved	\$650.00
45427	04A0009	Samson Electric Corp. 37-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Food Network 75 9th Avenue New York NY	Approved	\$650.00
45428	04A0008	Powertech Electrical Contractors 38-36 Crescent Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	325 West End Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

January 14, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45429	04A0007	L.K. Comstock & Company, Inc. 1560 Broadway-Suite 1214 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	New York Life 51 Madison Avenue New York NY	Hold	\$650.00
1-Service conductors undersized. 2-The feeder conductors so feeding existing ATS #6 are undersized. 3-Show the size and # of poles for ATS #6. 4-Show 2nd fusing of the panel pp-2B-AC. 5-The switch after the step up transformer must be GFCI protected. 6-Explain key interlocking on existing distribution switch board.						
45430	04A0006	D.J. Electrical Contractors Inc. 217 Fordham Street Bronx NY 10464	Requested approval for the electric service equipment proposed to be installed	295 Central Park West New York NY	Approved	\$650.00
45431	04A0002	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Frank Sinatra High School 20-30 Thomson Avenue Long Island City NY	Approved	\$650.00
45432	04A0019	Lippolis Electric Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Salanter Akiba Riverdale H.S. 5909 Riverdale Avenue Bronx NY	Approved	\$125.00
1-Increase service entrance and feeder conductor, with one more set. 2-Show neutral bond in 400 amp service switch. 3-Title block change remove Benfield correct title block properly.						
45433	03A0702	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	975 Essex Street Brooklyn NY	Approved	\$250.00

ADVISORY BOARD CALENDAR

January 14, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45434	04A0004	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	90-75 Sutphin Blvd. Jamaica NY	Approved	\$650.00
45435	04A0003	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	254 Canal Street New York NY	Approved	\$650.00
45436	-----	Tru-Val Electric Corp. 2550 Park Avenue Bronx NY 10451	Requesting permission on a previously approved drawing (44834 old code) to relocate a 1200 amp disc switch that will face a 5000 amp service switch with a front clearance of 48" cabinet to cabinet on a 480/277 volt service.	100 Gold Street New York NY	Denied	\$0.00
Section 230-64.b1 states at least 5 feet (1.52 meters) in front of the switchboard if it is in one line, and at least 7 feet (2.13 meters) in front of the board if the boards are installed facing each other.						
45437	-----	Proton Electric & Security Systems Inc. 7715 15th Avenue Brooklyn NY 11228	Requesting permission to leave as installed service equipment that is not grouped together with signage in each service room indicating where the other service is located.	292-296 4th Avenue Brooklyn NY	Approved	\$0.00
45438	04A0021	GE Consumer & Industrial Product 41 Woodford Avenue Plainville NY 06062	Requested approval for use in New York City of your Lighting Control System. Model Nos. #RINTERXX12, RINTERXX24 and RINTERXX48.		Approved	\$200.00

ADVISORY BOARD CALENDAR

January 14, 2004

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45439	04A0022	Thomas & Betts Corp. 8155 T & B Blvd. Memphis TN 38125	Requested approval for use in New York City of your Steel/Cast Iron Foor Box and covers-AL suffix for Alum. Assemblies 1, 2, & 3, 4 gang. Catalog Nos. 641,642,643,644,641-AL, 642-AL, 643-AL, 644-AL, P64-CP Series P64-CP-AL Series, P64 Series covers and P64-A6 Series covers.		Approved	\$200.00
45440	----- --	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requesting permission on a 480 volt 2500 amp bus duct riser to install 3 bus duct switches with front clearances less than 36".	731 Lexington Avenue New York NY	Denied	\$0.00
See Section 110-26(a) for the correct equipment clearnce distances.						