

ADVISORY BOARD CALENDAR

January 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46359CO2	05A0177CO2	Stat Electric Inc. 118-24 Queens Blvd., Suite311 Forest Hills NY 11375	Requested approval for the electric service equipment proposed to be installed	Dunkin Donuts Store 476 Second Avenue New York NY	Approved	\$0.00
Carry over from September 14, 2005 meeting. With the stipulation that the circuit breakers in the new panel have a 22K rating.						
46621CO	05A0425CO	Lehigh Electric Products Company 6265 Hamilton Blvd. Allentown PA 18106	Requested approval for use in New York City of your Dimmer Rack/Lighting Control Panel. Model/Series Nos. DX2-30, DX2-60 and DX2-120.		Approved	\$0.00
Carry over from August 17, 2005 meeting.						
46622CO	05A0426CO	Lehigh Electric Products Company 6265 Hamilton Blvd. Allentown PA 18106	Requested approval for use in New York City of your Dimmer Rack/Lighting Control Panel. Model/Series Nos. Sunburst: SB2400-6, SB2400-9 and SB2400-12.		Approved	\$0.00
Carry over from August 17, 2005 meeting.						
46813CO	05A0632CO	Coastal Electric Construction Corp. 232 Madison Avenue, Suite 200 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	PS/IS 263 222-14 Jamaica Avenue Queens NY	Approved	\$0.00
Carry over from December 14, 2005 meeting.						
46831CO	05A0592CO	B & G Electrical Contractors of NY Inc. 1481 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	25 West 51st Street New York NY	Approved	\$0.00
Carry over from December 14, 2005 meeting.						

ADVISORY BOARD CALENDAR

January 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46832CO	05A0627CO	Gannett Fleming, Inc. P.O. Box 560 Hammonton NJ 08037	Requested approval for the electric service equipment proposed to be installed	Visy Paper Staten Island Facility Staten Island NY	Approved	\$0.00
Carry over from December 14, 2005 meeting.						
46842CO1	05A0620CO1	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	45 East 89th Street New York NY	Approved	\$0.00
Carry over from December 14, 2005 meeting.						
46861CO	.	M. Chetrit 56 West 45th Street New York NY 10036	Requesting permission on an existing 265/460 volt 1000 KVA service, to replace one for one 3 defective service switches rated over 1000 amps without ground fault protection.	555 Madison Avenue New York NY	Denied	\$0.00
Carry over from December 14, 2005 meeting. Section 240.13 requires ground fault protection of equipment on 480 volt systems where the main disconnect are rated 1000 amps or greater.						
46863	06A0013	Corporate Electric Group, Inc. 112-09 14th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Stuyvesant Town/Peter Cooper 514 East 20th Street New York NY	Approved	\$650.00
46864	06A0026	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Lutheran Medical Center 150 55th Street Brooklyn NY	Approved	\$650.00
Provide short circuit and coordination study.						

ADVISORY BOARD CALENDAR

January 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46865	06A0047	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	FDNY/NYPD 850 Third Avenue New York NY	Approved	\$650.00
46866	06A0049	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	1107 Broadway New York NY	Hold	\$650.00
Need floor plan.						
46867	06A0054	Robert -Allen Associates, Inc. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	#10 Rockefeller Center New York NY	Approved	\$650.00
46868	06A0056	MSM Electric, Inc. 3089 Brighton 6th Street Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	880 3rd Avenue New York NY	Approved	\$650.00
46869	06A0057	MSM Electric, Inc. 3089 Brighton 6th Street Brooklyn NY 11235	Requested approval for the electric service equipment proposed to be installed	614 Sheepshead Bay Road Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

January 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46870	06A0058	Takos & K Electric, Inc. 38-58 11th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	88-11 165th Street Jamaica NY	Approved	\$650.00
46871	06A0042	SecureCom.Electric 22-26 College Point Blvd. College Point NY 11358	Requested approval for the electric service equipment proposed to be installed	1035 Fifth Avenue New York NY	Approved	\$650.00
46872	06A0043	Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	406-410 East 79th Street New York NY	Approved	\$650.00
46873	06A0046	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Clinton Green-Tower 2 515 West 52nd Street New York NY	Ok, but	\$650.00
1) 2000A and 600A fuse not coordinated(TDP-16). 2) Bus undersized in TDP-3.						
46874	06A0006	Hugh O Kane Electric Company, Inc. 30-40 48th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NBC Emerg. Pwr to Studio 1A 30 Rockefeller Plaza New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

January 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46875	06A0007	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Waldorf Astoria 301 Park Avenue New York NY	Approved	\$650.00
XFMRs should be 208A-480Y. Job finalized 2/28/06.						
46876	06A0010	Selpan Electric Co., Inc. 23 Herkimer Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	Silverstein Properties 120 Broadway New York NY	Approved	\$650.00
Block off rear access to new switchboard. Job finalized 12/26/07.						
46877	06A0018	Eastman Electric Corp. 1541 Dean Street Brooklyn NY 11213	Requested approval for the electric service equipment proposed to be installed	Dempsey Multi Service Center 127 West 127th Street New York NY	Approved	\$650.00
46878	06A0019	J.J. Rosenberg Electrical Contractors, Inc. 27 Herkimer Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	Fisk Building 250 West 57th Street New York NY	Approved	\$650.00
1) Increase bus size in tie switch component. 2) Reduce 3000A fuses to 2500A. 3) Switch and fuse drawn backward in 1600A distribute switchboard. 4) Verify feeders sizes. Job finalized 2/28/06.						
46879	06A0022	Meir Electrical Corp. 423 East 78th Street New York NY 10021	Requested approval for the electric service equipment proposed to be installed	230 Riverside Drive New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

January 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46880	06A0024	Approved Electrical Contractors, Inc. 6318 New Utrecht Avenue Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	Wartbug Lutheran Home for Aging 50 Sheffield Avenue Brooklyn NY	Approved	\$650.00
46881	06A0030	A.S.R. Electrical Contracting, Inc. 177-04 93rd Avenue Jamaica NY 11433	Requested approval for the electric service equipment proposed to be installed	Desmond Tutu Education Ctr. 175 9th Avenue New York NY	Hold	\$650.00
1) Supplementary ground. 2) Fire pump s/s needs neutral to be bonded. 3) Fuse cutout (normal) bond neutral. 4) Provide FLA of fire pump. 5) Fire pump feeder must be 2 hours fire rated. 6) Ground chasis of a generator to a building steel.						
46882	06A0033	Charan Electrical Enterprises, Inc. 27-14 39th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	The Studio Museum of Harlem 144 West 125th Street New York NY	Approved	\$650.00
46883	06A0035	D.J. Electrical Contractors, Inc. 217 Fordham Street Bronx NY 10464	Requested approval for the electric service equipment proposed to be installed	60 Sutton Place South New York NY	Hold	\$650.00
Provide physical of retrofit of panel by manufacturer.						
46884	06A0037	Polo Electric Corp. 497 Canal Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Jewish Community Center 1466 Manor Road Staten Island NY	Approved	\$650.00
1) Fire alarm switch must be service with a neutral which must be bonded. 2. 3000A service switch incorrect orientation . Job finalized 2/28/06.						

ADVISORY BOARD CALENDAR

January 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46885	06A0039	Sajiun Electric Inc. 105 West 27th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	PS-125, M 425 West 123rd Street New York NY	Approved	\$650.00
46886	06A0028	Up Town Electric, Inc. 128-20 14th Avenue College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	2900 Veterans Parkway West Staten Island NY	Hold	\$650.00
Conform to rule 12-01 with F.A. ATS.						
46887	06A0008	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	11 Metro Tech Center New York NY	Hold	\$650.00
1) Dimensioned floor plan. 2) GE switchgear drawings in Advisory Board format.						
46888	06A0012	Hugh O Kane Electric Company, Inc. 30-40 48th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NYCHA Ocean Bay Apts. Edgemere Houses Far Rockaway NY	Hold	\$650.00
46889	06A0014	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	PS/IS 189X 3440 Steenwick Avenue Bronx NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

January 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46890	06A0027	Jata Electrical Construction Corp. 16 West 36th Street, 10th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	511 West 25th Street New York NY	Ok, but	\$650.00
1) Provide supplemental ground. 2) Bus undersized after 4000 amp service switch.						
46891	06A0060	C.W. Greene, Inc. 111 John Street New York NY 10038	Requested approval for the electric service equipment proposed to be installed	230 West 41st Street New York NY	Approved	\$650.00
46892	06A0059	Selpan Electric Co. Inc. 23 Herkimer Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	Silverstein Properties 120 Broadway New York NY	Hold	\$650.00
1) Supplemental ground not provided. 2) Bus sizes not provided on drawing.						
46893	06A0050	Hampton Electrical Corporation 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	11 East 44th Street New York NY	Approved	\$650.00
46894	06A0051	OM Electric, Inc. 262 West 38th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	1381 6th Ave. aka 100 W. 57th St. New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

January 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46895	06A0052	Innovative Client Solutions 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	8-33 40th Avenue Long Island City NY	Approved	\$650.00
46896	06A0053	LLE Electric 236 West 26th Street, Suite 605 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	25 East 86th Street New York NY	Approved	\$650.00
46897	06A0055	Mackey Reed Electric, Inc. 197-25 Jamaica Avenue Hollies NY 11423	Requested approval for the electric service equipment proposed to be installed	30 Lafayette Avenue Brooklyn NY	Approved	\$650.00
46898	06A0001	W.M. Sanfardino Electric, Ltd. 3170 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Fathers Fish 1280 Ryawa Avenue Bronx NY	Approved	\$650.00
46899	06A0002	Forest Electric Corp. 2 Penn Plaza New York NY 10121	Requested approval for the electric service equipment proposed to be installed	111 8th Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

January 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46900	06A0003	Forest Electric Corp. 2 Penn Plaza New York NY 10121	Requested approval for the electric service equipment proposed to be installed	111 8th Avenue New York NY	Approved	\$650.00
46901	06A0004	Contractors Electrical Service Inc. 213 West 35th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Windemere 666 West End Avenue New York NY	Approved	\$650.00
46902	06A0009	Taft Electric Co., Inc. 31-31 123rd Street Flushing NY 11354	Requested approval for the electric service equipment proposed to be installed	21 Astor Place New York NY	Hold	\$650.00
Verify 2 means of egress from service room.						
46903	06A0011	Rothstein & Hoffman Electric Serv., Inc. 257 Centre Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Gyu-Kaku Restaurant 34 Cooper Square New York NY	Approved	\$650.00
Provide fuse types. Job finalized 5/15/06.						
46904	06A0015	Nelson & Tom Maintenance, Inc. 33 Henry Street, West Store New York NY 10002	Requested approval for the electric service equipment proposed to be installed	135-11 40th Road Flushing NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

January 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46905	06A0016	Spieler & Ricca Electrical Co., Inc. 52-09 Van Dam Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	55 West 25th Street New York NY	Hold	\$650.00
1) Service switchboard side must have 30" clearance to wall. 2) Are the rear doors of service switch #1, & 5 double doors?						
46906	06A0017	J.J. Rosenberg Electrical Contractors, Inc. 27 Herkimer Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	Union League Club 38 East 37th Street New York NY	Approved	\$650.00
46907	06A0020	Montgomery Electrical Contracting Corp. 4250 Van Cortland Park East Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	Martha Washington Hotel 30 East 30th Street New York NY	Approved	\$650.00
46908	06A0044	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	200 Fifth Avenue New York NY	Approved	\$650.00
46909	06A0041	Selectric Electrical Contracting Co., Inc. 78-14 46th Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	J.H.S. 13 1573 Madison Avenue New York NY	Denied	\$650.00
1) G.E. drawings not provided. 2) Request bus sizes inside switchgear.						

ADVISORY BOARD CALENDAR

January 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46910	06A0045	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Clinton Green-Tower 1 510 West 52nd Street New York NY	Approved	\$650.00
46911	06A0021	Tom Fitzpatrick Electrical Contg Corp. 1643 Utica Avenue Brooklyn NY 11234	Requested approval for the electric service equipment proposed to be installed	Peninsula Hospital 51-15 Beach Channel Drive Far Rockaway NY	Approved	\$650.00
46912	06A0023	Control Spec Electrical System, Inc. 30-60 Review Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	500 East 77th Street New York NY	Approved	\$650.00
46913	06A0025	C.Q. Electrical Contracting Corp. 10-16 34th Avenue Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Gabrielle's Restaurant 688 Columbus Avenue New York NY	Approved	\$650.00
46914	06A0029	Cabin Electric Inc. 77 Commerce Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	3220 Arlington Avenue Bronx NY	Approved	\$650.00
1) Provide 1 line diagram showing bus sizes. 2) Drawings not submitted in Advisory Board format						

ADVISORY BOARD CALENDAR

January 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46915	06A0031	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	375 Park Avenue New York NY	Hold	\$650.00
1) Feeders undersized. 2) Need curves. 3) ATS-3-4 pole.						
46916	06A0032	SMC Electrical Contracting Inc. 150-11 14th Avenue Whitestone NY 11357	Requested approval for the electric service equipment proposed to be installed	67 West 44th Street New York NY	Approved	\$650.00
Change feeder to 350 MCM. Job finalized 2/28/06.						
46917	06A0034	Double D Electric Corp. 33 2nd Avenue Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Alpha 3T and Open MRI 145 East 32nd Street New York NY	Approved	\$650.00
Lower 1200 amp fuse in service switch or increase bus in new distribution board. Job finalized 2/28/06.						
46918	06A0036	Mage Electrical Contractors 158 Perry Street New York NY 10014	Requested approval for the electric service equipment proposed to be installed	36 West 44th Street New York NY	Ok, but	\$650.00
1) Need cut sheet of new switchboard interior. 2) Verify if bus or sets of conductors are feeding new interior.						
46919	06A0038	Polo Electric Corp. 497 Canal Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Barbizon/63 140 East 63rd Street New York NY	Approved	\$650.00
1) Block off rear of switchboard. 2) Feeder off of service switch #1 undersized. 3) Show service switch in service room (not marked).						

ADVISORY BOARD CALENDAR

January 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46920	06A0040	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	240 Central Park South New York NY	Approved	\$650.00
Change 400 fuses ot A2D Type. Job finalized August 22, 2006						
46921	06A0005	Hugh O Kane Electric Company, Inc. 30-40 48th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Royal Bank of Canada 1 Liberty Plaza New York NY	Approved	\$650.00
Verify if existing ATS #3 and #1 are 3 or 4 pole. Job finalized 2/28/06.						
46922	--	altPower, Inc. 160 Fifth Avenue, Suite 807 New York NY 10010	Requesting permission to allow the installation of custom laminated photovoltaic (PV) modules that are not listed by a nationally recognized testing laboratory but are built to UL1703 standards.	Battery Park City Site 30 West Street New York NY	Approved	\$0.00
with the stipulation that all other components be listed and approved and shall be field evaluated as a complete system by a nationally recognized testing laboratory.						
46923	--	Atkinson Koven Feinberg Engineers LLP 1501 Broadway, Suite 700 New York NY 10036	Requesting permission to feed power to a fire alarm cutout with a dedicated automatic transfer switch by using one of two options, #1 with 120/208 volt UPS-ATS and option #2 with 480 volt UPS-ATS, see attached.	10 Teleport Staten Island NY	Approved	\$0.00
with the stipulation that both installation's are code compliant but subject to fire department approval.						
46924	--	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requesting permission to leave as installed a service switch mounted outside of a building that is not grouped together with the existing service equipment, for a cell site.	Crown Castle Mobile Media 138-01 Springfield Blvd. Queens NY	Approved	\$350.00
with the stipulation that signage is provided at each service indicating where the other service is located.						

ADVISORY BOARD CALENDAR

January 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46925	-- -	RSC Electrical Co., Inc. 64-11 Broadway Woodside NY 11377	Requesting permission not to install a receptacle outlet on a kitchen island counter space due to the electrician's client refusing to do so.	222 East 80th Street, Apt #5G New York NY	Denied	\$350.00
Section 210.52(c)(2) of the 2002 NEC requires the installation of a island counter receptacle.						
46926	---	Laser Lite Electrical, Inc. 40 Gaton Street Staten Island NY 10309	Requesting permission to run 2 sets of 500 MCM service entrance conductors in galvanized conduit approximately 15 feet inside of a building without encasing them in concrete.	3845 Richmond Avenue Staten Island NY	Approved	\$0.00
46927	----	V-Mar Electric Ltd. 408 Grand Street Brooklyn NY 11211	Requesting permission due to the building having no common areas to install two 200 amp service switches, meters and disconnect switches on the outside of four 3 family buildings that will feed 6 apartments and two PLPs.	217, 219, 221, 223 Beach 90th Street Queens NY	Approved	\$0.00
One time, and one time location.						
46928		V-Mar Electric Ltd. 408 Grand Street Brooklyn NY 11211	Requesting permission to leave as installed on the outside of a building that does not have any common areas, service equipment for 7 apartments and one PLP.	139 Beach 120 Street Queens NY	Approved	\$0.00
One time and one location.						
46929	-	Stromero & Marino s United Electric Co., In 58-15 Fresh Pond Rd. Maspeth NY 11378	Requesting permission to install Schedule 80 non metallic conduit standpipes on 2, two family buildings located in a highly corrosive area, Far Rockaway, Queens.	185 and 187 Beach 25th Street Far Rockaway NY	Approved	\$0.00
One time, one location.						

ADVISORY BOARD CALENDAR

January 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46930	---	Purcell Electrical Contractors, Ltd. 138-79 Francis Lewis Blvd. Rosedale NY 11422	Requesting permission to install Schedule 80 non metallic conduit standpipes on 10 two family buildings located in a highly corrosive area, Far Rockaway, Queens.	Burchell Rd. Far Rockaway NY	Approved	\$0.00
One time, one location.						
46931	---	Lewteck Electric Inc. 309 Clarkson Avenue Brooklyn NY 11226	Requesting permission to install Schedule 80 non metallic conduit on 28 two family dwellings with underground services located in a highly corrosive area, Far Rockaway, Queens.	,Bch Breeze Pl., Bch Breeze Ln. & E Far Rockaway NY	Approved	\$0.00
with the stipulation that metallic enclosures are installed.						
46932	06A0061	Juno Lighting Inc. 1300 S. Wolf Road Des Plaines IL 60017	Requested approval for use in New York City of your Line of Exit Signs and Emergency Lighting Units. Series: Line of Exit Signs and Emergency Lighting Units. Series: NNYXS, NNYXSB, NNYXSC, NNYXESB, NNY6, NNY12, NNYXD and NNYXDB.		Approved	\$200.00
46933	06A0062	MechoShade Systems, Inc. 42--03 35th Street Long Island City NY 11101	Requested approval in New York City of your Motorized Shading System. Model/Series Numbers: MechoShade's Electro1, Electro2, Electro3 Motorized Shading Solutions including MechoShade E-Switch Line Voltage Switch solutions and a variety of Line Voltage Motor <input type="checkbox"/> Controllers including but not limited to MechoShade's ICON-BI, IQ/MLC or MLC.		Hold	\$200.00

ADVISORY BOARD CALENDAR

January 25, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46934	06A0048	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	2628 Broadway New York NY	Approved	\$650.00