

ADVISORY BOARD CALENDAR

February 12, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52143	13A0507	Queue Electrical Contractors, Inc. 58-38 59th Street Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	116 West 23rd Street New York NY	Approved	\$650.00
5/27/15 Swapped FP20-01, Rev 4; AB20-01, Rev 2; SB10-1 of 2, Rev 3; SB10-2 of 2, Rev 3.						
52201	13A0519CO3	Ivatore Campisi and Sons Electl Contrs, Ir 1831 Decatur Street Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	88 Greenwich Street New York NY	Approved	\$0.00
Carry over from January 15, 2014 meeting. 1) The documented switching procedure shall implemented by a NEC qualified person familiar with all the equipment and this procedure to be published by a PE./RA. 2) Provide signage on the service switches "open service switch prior to starting generator". 3) Provide detail drawing of the triple manual switch on the drawing. 3/11/14 job finalized.						
52449	13A0572	Anthony G. Ferry Inc. 1916 Park Avenue New NY 10037	Requested approval for the electric service equipment proposed to be installed	81 Fleet Place Brooklyn NY	Approved	\$650.00
1) Show rating of 40 amp ATS. 2) MI cable undersized. 3) Service switch #3 fusing and 800 amp 2nd fusing don't coordinate. 5/14/14 Item #1 not addressed. 7/31/14 Job finalized. 2/25/16 Rejected Conductors feeding "ODB" panel undersized. 3/29/16 Swapped Drawing B-Revision 3 and Drawing C-Revision 3.						
52144	13A0696	M.R. Electrical Service LLC 115 Heyward Street Brooklyn NY 11206	Requested approval for the electric service equipment proposed to be installed	Richardson Street aka 395 Leonard St Brooklyn NY	Approved	\$650.00
	13A0697	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	99 Church Street New York NY	On Hold	\$650.00
1) Newly submitted drawings to be Revision 0 past revisions to newly submitted drawing shall not be shown. 2) What is the clearance between floor and ceiling mounted transformer? 3) Verify that emergency conductors are not run through the service room. 4) Show withstand rating of 30 amp TVSS. 5) Verify PVC will be installed underground. 6) Verify bus sizes in DP-43-AG, overfused. 7) Transformer feeder secondary conductors feeding DP APT 68 undersized, do not show length of the tap conductors and clarify sets. 8) Service board 556-6H bus to service switches 1,3,4 undersized. 9) Show 2nd fusing off of MP23MPH 1200 amp disconnect switch. 10) Show lengths of transformer taps. 11) 5 KV bus sizes not shown. 12) Tap to panel PP-68 undersized, show transformer tap lengths. 13) Transformer secondary tap lengths to be shown. 14) Panel MP AZ AH does not shown incoming feeder.						

ADVISORY BOARD CALENDAR

February 12, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52275	13A0716	First Quality Electric Corp. 5120 Ft. Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	177 Harrison Avenue Brooklyn NY	Approved	\$650.00
1) Equipment grounding conductors undersized. 2) Wire tie between split panelboards not shown MDP-2/3. 3) Fire alarm service entrance conductors size not shown. 4) fire pump emergency feeder to be fire rated. 5) Emergency panel EMDP over fused. 6) Neutral taps for fire pump and fire alarm switches (on normal feeds) to be on line side of neutral disconnect link. 7) Fire alarm ATS undersized, fire alarm ATS load conductors undersized. 8) SS# labeled 480V, system is 208V. 4/14/14 Job finalized.						
52401	14A0004	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	5 Madison Avenue New York NY	Approved	\$650.00
1) All ATS labeled as fire alarm. 2) Feeder sizes from generator to panels not shown. 3) Identify fuses in normal panels that will supply the ATS. 4) Feeder sizes for fire alarm system not shown. 5) Verify by note on drawing that ATS will be 3 pole for other ATS not shown on these drawings. 6) Fire alarm feeds require neutral conductor. Fire alarm ATS to be 4-pole. 7) In "EDP-Gen-Emerg" separate emerg breakers from standby breakers. 8) SS #1 and SS-T4 does not coordinate. 4/17/14 Rejected Item #3 not addressed. 6/18/14 Rejected. Feeders to emergency panels not protected. 6/27/14 Job finalized. 3/23/15 Swapped AB20 1 of 2, Revision 3 and SB50 1 of 5, Revision 3. 8/20/15 Rejected 1/0 fuse at 200 amps. 8/26/15 Swapped AB20-1, Revision 4.						
52234	14A0008CO	zardos Mechanical & Electrical Engineerin 240 West 35th Street, Suite 304 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	New York University 100 Washington Square East New York NY	Approved	\$0.00
Carry over from January 15, 2014 meeting. 1) Equipment bonding jumpers on drawing #6 to be 500 MCM no 1/0. 2) Why are bonding jumpers being installed if it is a metal to metal connection? 3) The bonding bushings and lugs must be listed to terminate 500 MCM bonding jumpers. 4) The 24" clearance between equipment is unacceptable unless there is another means of egress that is not shown on the drawing. 3/19/14 Job finalized.						
52206	14A0009	Innovative Electrical Services 3346 Provost Avenue Bronx NY 10475	Requested approval for the electric service equipment proposed to be installed	1501 Broadway New York NY	Approved	\$650.00
1) Equipment grounding conductor undersized on load side of fire pump service switch. 2) New fire pump switch to be 12" from ss#1. 3/14/14 Job finalized. 4/17/14 Swap Rev 2.						
53199	14A0029	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	10 Richmond Plaza Bronx NY	Approved	\$650.00
1) Service room doors to open outwards. 2) Equipment grounding conductor on load side of 15 KVA transformer undersized. 3) Confirm FA meter location w/utility company. 8/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

ADVISORY BOARD CALENDAR

February 12, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53200	14A0030	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	20 Richman Plaza Bronx NY	Approved	\$650.00
<p>1) Show clearance behind switchboard, why is rear of board blocked OCC if equipment has rear doors? 2) Confirm fire alarm meter locations w/utility company. 8/24/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
	14A0036	Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	220 West 41st Street New York NY	Rejected	\$650.00
<p>1) Show size of main bonding jumper. 2) Equipment grounding conductor for fire pump undersized. 3) Conduits undersized fire alarm system, verify conductor size. 4) No main switch with OCPD in panel HDP. 5) 200 amp w/400 pump fuse panel HDP. 6) Service switch should be 1600A min. 7) ATS #3 must be 4 pole switch. 5/22/14 Address correction. Job finalized. 9/29/16 Show all clearances in the service room. 2) 1 Line does not match room layout 1200 vs 1600A S.S. 3) Fire pump emergency feeder conduit too small for 5-3/0 conductors. 4) Fire alarm ATS to be 2 pole, explain feeders to FA ATS 4 conductor on emergency side 3 conductors on normal side? 5) Fire pump equipment grounding conductors undersized. 11/23/16 Rejected 1) Verify that gen is not separately driven system. 2) Verify distance in the back of 1600A bus duct riser disconnect switchboard. 3) Provide Gen Set cutsheet with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
52193	14A0037	Gilston Electrical Contracting Corporation 338 East 95th Street New York NY 10128	Requested approval for the electric service equipment proposed to be installed	522 First Avenue New York NY	Approved	\$650.00
<p>Show location of service switch SS-C in service room. 2/27/14 job finalized. 3/18/14 Swapped A and B drawings Revision 1.</p>						
52145	14A0038	Robert B. Samuels Inc. 253 West 35th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Health and Hospital Corp. 55 Water Street, 24, 25, 26 Floors New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 12, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0039	Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	605 West 42nd Street New York NY	On Hold	\$650.00
1) Show drawing of incoming service on cellar/mezzanine level. 2) Rear of service switchboards to comply with Section 408.60r or 230.64(B)4. 3) How will service entrance conductors be supported prior to terminating to CT terminals on drawings C,D, and E? 4) Section bus undersized in DP-A, DP1 HC. 5) Tap lengths to DP 58W, DP22W, DP-10W, DP-34W, DR46W, DP34E, NP46E, DP10E, DP22E, DP58E, DP46E not shown and feeders supplying them undersized. 6) Bus to ss 4c undersized. 7) Feeders from ss#5D in MSB-D, PP-RF-A board overfused. 8) Emergency feeder to panel EAP-2-146 does not comply with tap rule. 9) Provide reduced neutral calculations. 310.154C						
52146	14A0041	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	50 North 5th Street Brooklyn NY	Approved	\$650.00
52233	14A0043	Anthony G. Ferry Inc. 1916 Park Avenue New York NY 10037	Requested approval for the electric service equipment proposed to be installed	Corn Exchange 81 East 125th Street New York NY	Approved	\$650.00
1) New submitted drawings shall not be Revision 1. 2) Tap conductor to 400 amp disconnect switch undersized. 3/19/14 Job finalized. 8/26/15 Rejected 1) Meter pan in service room to comply with 110.26(A)(2). 2) Show how pull box will connect to 1200 amp trough. 12/18/15 Swapped Drawing A-Revision 4. 3/29/16 Swapped drawing A-Revision 5.						
52147	14A0044	Nunez Electric, Inc. 32-14 Greenpoint Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	PS 892Q 199-10 112th Avenue Queens NY	Approved	\$650.00
52200	14A0046	Delco Electrical Corp. 766 Fifth Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	551 West 21st Street New York NY	Approved	\$650.00
1) Show rating of 30 amp TVSS switch. 2) Room layout shows service entrance conductors entering main switchboard, 1 Line doesn't match it. 3) 1200 amp s.s.#4 to 600 amp 2nd fuse do not coordinate. 3/10/14 job finalized.						

ADVISORY BOARD CALENDAR

February 12, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52289	14A0047	New York Mechanical Electrical Co. 269 37th Street, Suite #200 Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Bush Terminal, Bldg #10 882 Third Avenue Brooklyn NY	Approved	\$0.00
SANDY Verify that this installation is not connected to any conductors that were not replaced due to water damage. 4/21/14 Job finalized.						
	14A0048	NJS Electrical Services Corp. 36-16 13th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	325 Hudson Street New York	Rejected	\$650.00
1) Not 1000 KVA 480V at 1200 amps existing equipment. 2) Coordination study not provided. 3) Sizes of existing wiring not provided. 4) Show calculation for required neutral curve numbers 005TCC, 001ETCC and 005ETCC. 5) Circuit breakers lack coordination. 3/27/14 Rejected. Items 4 and 5 not addressed.						
52222	14A0049	Konsker Electric Corp. 35-40 26th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	30 Main Street Brooklyn NY	Approved	\$0.00
SANDY 1) Verify that service room is mechanically ventilated. 2) Limited service fire pump over-fused. 3/14/14 job finalized. 3/30/15 Swapped Drawings A-Rev 3, B-Rev 1 and C-Rev 2.						
	14A0050	K & R Electric Co., Inc. 638 Sharrotts Road Staten Island Ny 10309	Requested approval for the electric service equipment proposed to be installed	40 Oceana Drive West Brooklyn NY	Pending	\$0.00
SANDY 1) Verify that underground feeder to meter banks are new. 2) Circuit breakers are underrated. 3) Verify that existing circuit breakers were installed horizontally.						
52148	14A0051	Jones Group 75 Broad Street, Suite 1902 New York NY 10004	Requested approval for the electric service equipment proposed to be installed	199 Water Street New York NY	Approved	\$0.00
SANDY						

ADVISORY BOARD CALENDAR

February 12, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52192	14A0052	Rainbow Electric Co. Inc. 76-18 Rockaway Blvd. Woodhaven NY 11421	Requested approval for the electric service equipment proposed to be installed	301 East 64th Street New York NY	Approved	\$650.00
Service room door to open outwards. 2/27/14 job finalized. 8/27/15 Swapped Drawing A, Revision 2.						
	14A0054	aros, Baum & Bolles Consulting Engineer 80 Pine Street New York NY 10005	Requesting permission to leave as installed 2 sets of 4/0 copper conductors tapped from the loadside of 4000 amp fuses that supply 2 separate 200 amp disconnect switches due to the correct size tap conductors not being able to terminate to a 200 amp switch.	150 East 42nd Street New York NY	Denied	\$350.00
Code: 110.2 Exception No.2, 240.21(B)(2).						
	14A0055	Bigman Brothers Inc. 43-40 34th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	575 Lexington Avenue New York NY	Rejected	\$650.00
1) Show length of taps to chiller switches. 2) Fire rate fire pump feeder. 3) Equipment grounding conductor undersized fire pump. 4) Generator OCPD to have ground fault indication. 7/22/14 Rejected. 1) Item #2 not addressed on emergency side. 2) Normal fire pump feeder underfused.						
	14A0056	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	85 Broad Street New York NY	On Hold	\$0.00
SANDY 1) Russo Electric drawing missing. 2) Fire pump emergency switch and wiring undersized. 3) Second fusing for chiller not shown and are feeders and chillers existing. 4) Show routing of concrete encased conduits from service room in basement to new service room location, conduit support boxer if required, Will metal conduit be installed? 5) Fire alarm emergency feed mismarked at fire pump. 6) Fire pump emergency feed not shown or identified on 5 of 5.. 7) Switchboard ELDRH not shown on drawing 5 of 5. 8) 3000 amp breaker not identified for switchboard 31-B1. 9) Omit neutrally-to-ground bonds in paralleling switchgear. 10) Confirm ground fault sensing scheme where tie breakers connect distribution switchboards. Solid neutrals connecting switchboards. W/3-pole switching.						

ADVISORY BOARD CALENDAR

February 12, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52162	14A0057	Zwicker Electric Co. Inc. 360 Park Avenue South New York NY 10010	Requesting permission to leave existing emergency feeders as originally designed inside of the service room where the existing service is being replaced and a new ATS room was built in a building where the existing service was water damaged by Hurricane Sandy.	60 Broad Street New York NY	Approved	\$0.00
52149	14A0059	Fresh Meadow Electl Contrs, LLC 65-01 Fresh Meadow Lane Fresh Meadow NY 11365	Requested approval for the electric service equipment proposed to be installed	Mount Sinai Hospital 1414 Madison Avenue New York NY	Approved	\$650.00
52150	14A0061	P.E. Stone, Inc. 50 Watts Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	1140 Sixth Avenue New York NY	Approved	\$650.00
52163	14A0062	Lilker Associates Consulting Engs, PC 1001 Avenue of the Americas New York NY 10018	Requesting permission to install PVC wiring method indoors and outdoors of a building with highly corrosive areas where the building is located close to the ocean and the existing wiring methods and conductors are being replaced due to Hurricane Sandy.	New York Aquarium 602 Surf Avenue Brooklyn NY	Approved	\$0.00
Code: 352.10(B)						
52290	14A0063	Kleinknect Electric Company, Inc. 252 West 37th Street, Suite 1402 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	230 Park Avenue New York NY	Approved	\$650.00
<p>1) Disconnect switch identified as service switch in on 1-line, it is 2nd fuse. 2) Neutral ground to be located on line side of disconnect link. 3) New 400A switch is 2nd fuse, not service switch. Remove neutral ground confirm 10FT tap. 4) Feeder to existing panel "HTN-25W" undersized, conduit undersized, panel not protected by fuse. 3/11/14 Rejected Bonding and grounding of existing 1600 amp service switch to be installed on line side of neutral link. 4/21/14 Job finalized. 12/28/15 Swapped drawing 1 and 2-Revision 3.</p>						

ADVISORY BOARD CALENDAR

February 12, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	14A0064	Demand Electric Co. 1219 Rockway Avenue Brooklyn NY 11236	Requested approval for the electric service equipment proposed to be installed	455 Rear Front Street Staten Island NY	On Hold	\$0.00
SANDY 1) Verify aggreko generators is listed by a NRTL. 2) Verify that Philips Brothers equipment is listed by a NRTL. 3) Show all clearances and front of equipment. 4) Do generators, feeders and 2500 amp switches manufactured as a complete assembly if so, provide cut sheet and listing information. 5) Provide ground grid drawing showing all points of grounding of equipment. 6) Show conductor sizes in cable tray and how conductors will be installed in the cable trays. 7) Show sizes of bus bars. 8) Provide 13.8KV sync board equipment. cuts and details. Who is the manufacturer, are they recognized?						
52355	14A0065	Evergreen Electrical Corp. 133 50th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	301 East 61st Street New York NY	Approved	\$650.00
1) Provide protection for fire pump, service switch and controller. 2) Feeder size to PNL HBL not shown. 3) Fire alarm emergency feeder overfused. 4) Emergency feeder for fire pump connected to 2nd fusing. 5) Fire pump to have dedicated ATS. 6) Revisit design for emergency feed to HDP panel along with fire pump emergency connection. 7) Provide short circuit curves s.s #4 and RDP panel. 5/22/14 Job finalized.						
52207	14A0066	CSA Engineering Services, LLC 15 Trowbridge Drive Bethel CT 06801	Requested approval for the electric service equipment proposed to be installed	Double Tree Times Square 1568 Broadway New York NY	Approved	\$650.00
1) If the 2-600 am switches are being added to the Board the sizes of the vertical bus must be shown on the drawing. 2) Verify that service room is mechanically ventilated. 3/14/14 Job finalized.						
52151	14A0067	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	104 Broad Street New York NY	Approved	\$0.00
SANDY 2/19/16 See new submittal 15A0842. 3/21/16 Swapped drawings 301 and 601, Revision 3s.						
52165	14A0068	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requesting permission to replace like and kind 5KV existing underground non utility loop on Governors Island where the existing government specs underground ducts and manholes will be inspected cleaned and possible repaired if required	Governors Island 10 South Street New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

February 12, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52152	14A0069	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Stuyvesant Town 272 First Avenue, Bldg #7A New York NY	Approved	\$650.00
10/30/15 Drawing swapped 1, Revision 2. 4/21/16 Swapped drawing 1-Revision 3.						
52153	14A0070	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Stuyvesant Town 278 First Avenue, Bldg. #7B New York NY	Approved	\$650.00
10/30/15 Swapped Drawing 1, Revision 1. 4/21/16 Swapped drawing 1-Revision 2.						
52154	14A0071	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Stuyvesant Town 2 Stuyvesant Oval, Bldg #20 New York NY	Approved	\$650.00
52155	14A0072	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Stuyvesant Town 17 Stuyvesant Oval, Bldg #8 New York NY	Approved	\$650.00
52392	14A0073	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Stuyvesant Town 317 Avenue C, Bldg #25 New York NY	Approved	\$650.00
1) Relocate existing T mobile from in front of 4000 amp service switch. 2) Check fuses different manufacturers. 6/20/14 Job finalized.						

ADVISORY BOARD CALENDAR

February 12, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52203	14A0074	Shorr Electrical Contracting, Inc. 34-13 10th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Macy's 422 Fulton Street Brooklyn NY	Approved	\$650.00
1) Is this temporary, is this a replacement board? 2) Explain (4) 900 MCM in free air rack. 3) Indicate system voltage 208V or 170/208V. 4) Feeder cable to be rated per Article 392. 3/13/14 Job finalized.						
52240	14A0075	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	Hunters Point South Parcel "A" 1-50 50th Avenue Long Island City NY	Approved	\$650.00
Provide reduced neutral calculations. 3/21/14 Job finalized. 12/28/15 Swapped 1,2,3- Revision 2.						
52156	14A0076	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	City Point 2, Tower 2 336 Flatbush Avenue Extension Brooklyn NY	Approved	\$650.00
52341	14A0077	Horsepower Electric 188 21st Street, 2nd Floor Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	460 Washington Street New York NY	Approved	\$650.00
1) Verify that there are no emergency feeders installed in the service room. 2) Show rating of 30 amp ATS. 3) Fire pump and fire alarm have an upstream OCPD, they must be relocated. 5/15/14 Job finalized.						
52157	14A0078	M.O.S. Electrical Contracting Corp. 4340B Katonah Avenue Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	207 East 94th Street New York NY	Approved	\$650.00
4/17/14 Swapped Rev 1.						

ADVISORY BOARD CALENDAR

February 12, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52158	14A0079	Control Electrical Contracting Corp. 85 Tompkins Street Staten Island NY 10304	Requested approval for the electric service equipment proposed to be installed	5 East 22nd Street New York NY	Approved	\$650.00
52159	14A0080	Laredo Electric, Inc. 2477 Arthur Kill Road Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	2 Water Street New York NY	Approved	\$650.00
Rejected. 7/21/15 1) 3 sets of 750 AL fused at 1200 amp (overfused). 2) Changes on drawing-2 not shown. 4/21/16 Swapped drawing 1, 2 and 3, Revision 2.						
52227	14A0081	Milad Contracting Corporation 59-01 39th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	P.S. 106X 1514 Oldstead Avenue Bronx NY	Approved	\$650.00
Indicate 1600A switch as unfused. 3/17/14 Job finalized						
52160	14A0082	Marcel Electrical Contracting Corp. 1406 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Fairway 400 Walnut Avenue Bronx NY	Approved	\$650.00
52161	14A0083	Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	39 West 19th Street New York NY	Approved	\$650.00
3/24/15 Swapped Drawing 1, Revision 1. 9/12/16 Swapped drawing 1-Revision 2						

ADVISORY BOARD CALENDAR

February 12, 2014

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
52448	14A0085	Valmar Electric Corp. 5-44 47h Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	SoHo Square Project 233 Spring Street New York NY	Approved	\$650.00
1) Main bonding jumper undersized. 2) Supplemental ground not shown. SS, #4. 3) Tap lengths not shown into 1600A switches (2). 4) Bonding and grounding of fire alarm switch not shown. 5) Service room doors to swing out. 5/22/14 Rejected Equipment grounding conductors undersized for taps to 1600 amp switches. 6/20/14 Rejected Equipment grounding conductors undersized for taps to 1600 amp disconnect switches. 7/30/14 Job finalized.						
	14A0086	Valmar Electric Corp. 5-44 47th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	161 Avenue of the Americas New York NY	On Hold	\$650.00
1) Cut sheet for service end box not provided. 2) 1 Line drawing does not match room layout for service entrance box, are service entrance conductors running through the switchboard? 3) Confirm POE location(s). 4) Indicate location of service board(D). 5) Indicate locations of service board C + C1 on single line.						
52292	14A0087	NJD Wiring & Electric, Inc. 213-08 99th Avenue Queens Village NY 11429	Requested approval for the electric service equipment proposed to be installed	62R 644 Bloomingdale Rd. Staten Island NY	Approved	\$650.00
1) Correct contractor's name in title blocks. 2) Show size of main bonding jumper. 3) Check wire fill for 1" conduits. 4) Neutrals to be bonded to enclosures in remote service switches. 5) Fire pump emergency fusing undersized. 6) Fuse types not shown on drawing. 7) Neutral bonded in EDP-GEN panel. 3/19/14 panels pp-pv2.2 overfused, 2 sets of 350 MCM fused at 800 amps. 4/21/14 Job finalized.						
52164	14A0089	AKF 330 West 42nd Street, 14th Floor New York NY 10036	Requesting permission to tap emergency power to supply a new fire alarm system ATS connected to the line side of a double ended emergency switchboard fed from another building. The normal utility supply for the fire alarm system will be fed from both ends of a double ended switchboard with a ATS between them to increase reliability of the normal supply for the fire alarm system where it would be a hardship to run conduits back to the supply in the other building.	630 West 168th Street New York NY	Approved	\$0.00

Code: 90.2(c), 760.41(A)(1)