

ADVISORY BOARD CALENDAR

February 13, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47688CO2	06A0508CO2	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	City University of New York Convent Avenue @ 138th Street New York NY	Approved	\$0.00
Carry over from August 15, 2007 meeting.						
48117CO	07A0394CO	Tower Electric Inc. 21-19 40th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Greater Allen Cathedral 110-42 Merrick Boulevard Queens NY	Approved	\$0.00
Carry over from August 15, 2007 meeting. Provide full detail of tap box. A) Size of tap box. B) Wire bending radius of conductors. C)Polaris connector can not share emergency and non life safety. Job finalized 3/3/08.						
48331CO	07A0635CO	Interphase Electric Corp. 5304 Seventh Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	R & T Building 48-34 35th Street Long Island City NY	Approved	\$0.00
Carry over from December 12, 2007 meeting.						
48424CO	08A0022CO	Hugh O Kane Electric Co., Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Rockefeller Group 1271 6th Avenue New York NY	Approved	\$0.00
Carry over from January 16, 2008 meeting.						
48438CO	08A0036CO	Petrocelli Electric Co., Inc. 22-09 Queens Plaza North Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Weil Cornell 407 East 61st Street New York NY	Hold	\$0.00
Carry over from January 16, 2008 meeting. Redsign portable generator switch to emergency switchboard with protection so that portable and emergency generator can work simultaneously and then feed FA emergency side.						

ADVISORY BOARD CALENDAR

February 13, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48460	08A0049	Infinity Electrical Contractors, Inc. 22-10A 35th Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	126 Water Street New York NY	Hold	\$650.00
No Drawings.						
48461	08A0048	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	U.S. Tennis Association 123-50 Roosevelt Avenue Flushing Meadow NY	Approved	\$650.00
1) Indicate wiring method for 5KV feeder cable type, conduit. 2) Life safety ATS cannot be in service room per rule 12-01. Job finalized 3/21/08.						
48462	08A0101	Nivek Electrical Contracting, Inc. 301 East 119th Street New York NY 10035	Requested approval for the electric service equipment proposed to be installed	3820 Review Avenue Long Island City NY	Approved	\$650.00
48463	08A0096	Crana Electric Inc. 695 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	333 Rector Place New York NY	Approved	\$650.00
Clarify routing of trough from SS#2 and #3 as it enters distribution switchboard. Job finalized 2/25/08.						
48464	08A0097	Genmar Electrical Contracting Corp. 98-19 103rd Avenue Ozone Park NY 11417	Requested approval for the electric service equipment proposed to be installed	101 Ludlow Street New York NY	Approved	\$650.00
Emergency feed to fire pump must be rated. Job finalized 3/3/08.						

ADVISORY BOARD CALENDAR

February 13, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48465	08A0092	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	111 Eighth Avenue New York NY	Approved	\$650.00
48466	08A0088	BLZ Electric, Inc. 150 52nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	206-226 North 11th Street Brooklyn NY	Approved	\$650.00
1) 600 amp switches not shown, length of conductor taps not provided. 2) No coordination between 1200A service fuse and 400A TR in Dist. B. Job finalized 3/21/08.						
48467	08A0074	J.J. Rosenberg Electrical Contractors, Inc. 27 Herkimer Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	ANA Tzarev Gallery 24 West 57th Street New York NY	Approved	\$650.00
Provide number of sets of conductors in panel. Job finalized 2/25/08.						
48468	08A0073	Bigman Brothers Inc. 43-40 34th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	444 Madison Avenue New York NY	Approved	\$650.00
48469	08A0070	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	775 Columbus Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 13, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48470	08A0068	Charan Electrical Enterprises, Inc. 27-14 39th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	V.H.S. of Graphic Communication 439 West 49th Street New York NY	Approved	\$650.00
1) Length of tapped conductor not provided. 2) Conduit installation per plan not 1-Line tap conductors to enter MCB enclosure. Job finalized 5/6/08.						
48471	08A0067	Arc Electl & Mechanical Contrs, Corp. 28 Delavan Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	574 4th Avenue Brooklyn NY	Approved	\$650.00
1) Fire pump branch circuit not fire rated. 2) feeders to panel not shown. 3) Short circuit calculations and coordination curves not provided. Job finalized 4/2/08.						
48472	08A0065	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	Columbia Univ.-McVickar Hall 622 West 113th Street New York NY	Approved	\$650.00
1) Verify who is installing conductors from manhole into service. 2) Neutral bonded in emergency faco. 3) Normal and emergency branch circuits for fire pump not fire rated. 4) Service room door to open out. 5) Verify bus bar connections are 30" max from front of switchboard. Job finalized 4/2/08.						
48473	08A0061	Danco Electrical Contractor, Inc. 40-17 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Brooklyn College-West Quad 2900 Bedford Avenue Brooklyn NY	Approved	\$650.00
Only for additional service conductors.						
48474	08A0060	B & G Electl Contractors of New York 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Triangle Core & Shell/Triangle 2201 Nostrand Avenue Brooklyn	Hold	\$650.00
1) Supplemental ground not provided. 2) Interior bus size not provided in right panel in Switchboard MS-1 and middle of MS-2. 3) 400 amp neutral not bonded to enclosure in (all) 400 amp service switch. 4) Secondary of step down transformer not grounded to building steel. 5) Fire pump service switch neutral not bonded to enclosure. 6) Neutral in emergency switchboard bonded to enclosure. 7)Emergency feed to fire pump must be ahead of main. 8) F.P. feeds must be rated. 9) 800A and 601A fuses not coordinated in MS-1. 10) Provide coordination curves for 'MDS'.						

ADVISORY BOARD CALENDAR

February 13, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48475	08A0057	Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028	Requested approval for the electric service equipment proposed to be installed	Russo's on the Bay 162-45 Cross Bay Boulevard Howard Beach NY	Ok, but	\$650.00
Special permission needed to not group together service equipment.						
48476	08A0056	Denmar Electric Corp. 47-40 48th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	185 Varick Street New York NY	Approved	\$650.00
1) Supplemental ground not provided. 2) Jockey pump tap must be outside ATS enclosure. 3) indicate legal egress out of new service room. 4) Provide signage indicating 2nd service room. Job finalized 12/12/08.						
48477	08A0058	Flemington Electrical Maintenance Inc. 121 Varick Street, 4th Floor New York NY 10013	Requested approval for the electric service equipment proposed to be installed	515 7th Avenue New York NY	Approved	\$650.00
1) Bus in panelboards BDP and RDP undersized. 2) No coordination with 300A & 800A fuses in 'RDP'. 3) 3ft width required for egress in service room. Job finalized 3/21/08.						
48478	08A0052	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	20 Exchange Place New York NY	Approved	\$650.00
1) Show through bus size in last cubicle in Board "DP56". 2) Service room doors to open out. 3) Verify that your are installing the fire pump service switches and branch circuits, pump wiring and fuses by others. 4) Feeders to bus duct undersized from service switch 1B. 5) Ground strap undersized in service switchboard B. Coordinate problems: Service Switchboard A- 1200A-800A, 1600A-800A DP22, 1600A-800A DPN 20. Job finalized 3/21/08.						
48479	08A0078	Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	East 1st Street a.k.a 11 East 1st Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 13, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48480	08A0085	Red Wing Electric of New York 261-10 East Williston Avenue Floral Park NY 11001	Requested approval for the electric service equipment proposed to be installed	Hunter College 695 Park Avenue New York NY	Approved	\$650.00
1) 2nd fusing not shown. 2) If 2nd fusing is a circuit breaker panel show short circuit calculations. Job finalized 2/25/08.						
48481	08A0082	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Kingsborough Community College 2000 Oriental Blvd. Brooklyn NY	Approved	\$650.00
48482	08A0083	CRM Electric Corporation 601 West 26th Street, Suite 1695 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	1926 Crotona Parkway Bronx NY	Approved	\$650.00
Fuses per 400A switch on ODB do not coordinate with service switch. Job finalized 2/25/08.						
48483	08A0086	Christopher Jon Electrical Contractors, Inc 108 Frost Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	300 West 22nd Street New York NY	Approved	\$650.00
1) Bond neutral to enclosure in FCO on normal side. 2) Provide tap box prior to fire pump controller for jockey pump connection. 3) Ground generator frame to building steel. 4) Generator neutral to be bonded to main water ground electrode. 5) FP emergency feeder to be rated. Job finalized July 21, 2008.						
48484	08A0087	A & S Electric Inc. 45 East 7th Street New York NY 10003	Requested approval for the electric service equipment proposed to be installed	George Washington H.S. 549 Audobon Avenue New York NY	Approved	\$650.00
1) Existing 5000, 1200's and 600 amp service switches neutrals not bonded and grounded. 2) No neutral links provided. 3) Feeders to new 1200 amp switch are undersized, 25' tap. 4) Conductors on load side of 1200 amp switch not provided. Job finalized 3/21/08.						

ADVISORY BOARD CALENDAR

February 13, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48485	08A0076	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	510 Madison Avenue New York NY	Ok, but	\$650.00
1) Provide neutral disconnect link on 2000A unmetrated switch, MS-B. 2) No coordination 1800A- 1200A MS-A.. 3) Confirm generator bus detail meets NYCEC or provide UL listing details.						
48486	08A0102	CSA Engineering Services 37 Miry Brook Road Danbury CT 06810	Requested approval for the electric service equipment proposed to be installed	NYC Dept. of Environ. Protection Wards Island Water Pollution Plant Wards Island NY	Approved	\$650.00
1) Provide bus sizes on Advisory Board format 1-Line for all switchgear and switchboards. 2) Submit Section views of gear. Job finalized 5/6/08.						
48487	08A0047	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Morgan Stanley 1 Pierreponte Plaza New York NY	Approved	\$650.00
48488	08A0050	Commercial Electrical Contractors, inc. 10-28 47th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Marriot Financial Center Hotel 85 West Street-4th Floor New York NY	Approved	\$650.00
1) Verify bus size to existing 4000 amp service switch. 2) Confirm that the BPS is being used within its rating. Job finalized 2/25/08.						
48489	08A0051	J.J. Rosenberg Electrical Contractors, Inc. 27 Herkimer Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	ABC TV Generator UPS Upgrade 47 West 66th Street New York NY	Approved	\$650.00
Reprint typo on 1 line. Job finalized 2/25/08.						

ADVISORY BOARD CALENDAR

February 13, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48490	08A0100	Essential Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Atria Assisted Living 333 West 86th Street New York NY	Approved	\$650.00
48491	08A0098	Evergreen Electrical Corp. 133 50th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	194 Atlantic Avenue Brooklyn NY	Approved	\$650.00
Tap to 60 amp switch undersized. Job finalized 5/6/08.						
48492	08A0090	Megan Electrical Enterprise, Inc. 23-30 College Point Blvd. College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	221 McKibben Street Brooklyn NY	Approved	\$650.00
1) Fire pump branch circuit to be fire rated. 2) Fire pump service switch must be identified. Job finalized 4/3/08.						
48493	08A0095	Jun Safety Electrical Inc. 1184 60th Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	142-28 38th Avenue Queens NY	Approved	\$650.00
48494	08A0091	Belway Electric NYC, LLC 38 East 29th Street New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Elie Tahari 510 Fifth Avenue New York NY	Hold	\$65.00
Redesign job to provide coordination between 3000 amp distribution and 400 amp service switch.						

ADVISORY BOARD CALENDAR

February 13, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48495	08A0094	Belway Electric NYC, LLC 38 East 29th Street New York NY 10016	Requested approval for the electric service equipment proposed to be installed	CRG West Phase 1 32 Avenue of the Americas New York NY	Approved	\$650.00
1) Provide GF protection at 3200 amp circuit breakers. 2) Bond generator neutrals to enclosures. 3) Service switches to be GF protected. 4) Interlock protection for load bank recommended. Job finalized 3/21/08.						
48496	08A0093	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	CRG-West Phase 2 12 Avenue of the Americas, 7th Floor New York NY	Approved	\$650.00
Increase bus sizes in switchboards. Job finalized 3/21/08.						
48497	08A0089	Campisano Electric Inc. 355 Food Center Drive, Suite F101 Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	Baldor Specialty Foods Food Center Dr. aka 1400 E. Bay Ave Bronx NY	Approved	\$650.00
1) Existing grounding not shown. 2) Tap to 400 amp switch undersized. Job finalized 3/21/08.						
48498	08A0075	Robert B. Samuels Inc. 48 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Google 75 9th Avenue New York NY	Approved	\$650.00
48499	08A0069	Caruso & Sons Electrical Contracting, Inc. 1489 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Times Warner Cable 25-20 BQE West Woodside NY	Approved	\$650.00
Provide length of both taps. Job finalized 2/25/08.						

ADVISORY BOARD CALENDAR

February 13, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48500	08A0071	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	795 Columbus Avenue New York NY	Approved	\$650.00
1) Provide bus sizes to 1200 amp switches in switchboard "13". 2) Provide fuse types in meter banks. Job finalized 2/25/08.						
48501	08A0066	Levinson & Santoro Electric Corp. 20-16 130th Street College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	Staten Island Technical H.S. 485 Clawson Street Staten Island NY	Ok, but	\$650.00
1) Neutral in FCO not bonded to enclosure. 2) Bus in panelboards undersized.						
48502	08A0064	Coastal Electric Construction Corp. 232 Madison Avenue, Suite 200 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Pepsi Cola Bottling Co. or NY 650 Bruhx Avenue Bronx NY	Approved	\$650.00
1) Ground and supplemental ground not provided. 2) Bus sizes in panelboard undersized. 3) 30 amp service undersized. Job finalized 4/2/08.						
48503	08A0063	Accountable Electrical Corporation 10 Cebra Avenue Staten Island NY 10301	Requested approval for the electric service equipment proposed to be installed	33 West 37th Street New York NY	Approved	\$650.00
Service entrance conductors are undersized. Job finalized 1/4/10						
48504	08A0062	B & G Electrical Contractors of New York 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	IKEA 1 Beard Street Brooklyn	Hold	\$650.00
Not reviewed, indicate on the drawings what work is new and what is existing.						

ADVISORY BOARD CALENDAR

February 13, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48505	08a0059	Arnold Finkelstein, Licensed Electrician 430 East 89th Street New York NY 10028	Requested approval for the electric service equipment proposed to be installed	615-633 East 104th Street Bronx NY	Approved	\$650.00
Supplemental ground not provided. Job finalized 2/2708.						
48506	08A0054	Lite Tron Electrical Corp. 236 West 26th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Chelsea Piers North River Piers 59-62 New York NY	Approved	\$650.00
Supplemental ground not provided. Job finalized 2/2708.						
48507	08A0055	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	The Edge Building 2 34 N 6th Street Brooklyn NY	Ok, but	\$650.00
1) Bus in 3000 amp service switch undersized. 2) Provide bus sizing service switches 1,2,3,4 and 5. 3) Clarify feeder from service switches #1 and 2. 4) Are non metallic conduits encased in concrete or underground? 5) Provide reduced neutral calculations. 6) Coordinate problems: throughout job A4BY-TR 4:1. 7) Provide supplemental ground lug in main service switchboard.						
48508	08A0053	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	515 West 52nd Street-Tower 2 New York NY	Ok, but	\$650.00
1) Request special permission to install non metallic conduits for service entrance to locate service switch outside of the electrical room. 2) Request special permission to install new service switch in separate room not grouped with other service switchgear. 3) Show detail of how service conductors are routed to new CT compt.						
48509	08A0080	M & J Electrical Contractors Corp. 23-24 Steinway Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	168-23 Jamaica Avenue Queens NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 13, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48510	08A0077	Frank Mann, P.E., P.C. 10 Ambler Drive Bedford NY 10506	Requested approval for the electric service equipment proposed to be installed	151 East 31st Street New York NY	Approved	\$650.00
48511	08A0079	June Electric Corp. 2025 Continental Avenue, Suite 5E Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	105 Chambers Street New York NY	Approved	\$650.00
48512	08A0081	Vere Electric Corporation 726 Sterling Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	140 Charles Street New York NY	Approved	\$650.00
48513	08A0084	Fred Geller Electrical, Inc. 54-15 38th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Anheiser Busch 550 Food Center Drive Hunts Point NY	Approved	\$650.00
48514	08A0103	erified Electrical & Technical Services, In 27 William Street, Suite 409 New York NY 10005	Requested approval for the electric service equipment proposed to be installed	Cingular Wireless 40 East 9th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 13, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48515	08A0072	Egg Electric Inc. 24 West 25th Street New York NY 10011	Requested approval for the electric service equipment proposed to be installed	L & L Holding 200 5th Avenue New York NY	Approved	\$650.00
1) Generator room doors to open out and show clearances. 2) Switchboard #4 explain wire type and size. 3) Switchboard #5 bus sizes not provided to transformer. 4) Switchboard #5 ground fault protection. Job finalized 3/19/08.						
48516		Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requesting permission to install underground concrete encased service lateral conductors in fiberglass reinforced epoxy non metallic conduits.	775 Columbus Avenue New York NY	Approved	\$0.00
48517		Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requesting permission to install underground concrete encased service entrance conductors in fiberglass reinforced epoxy non metallic conduits.	795 Columbus Avenue New York NY	Approved	\$0.00
48518		Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requesting permission to leave as installed 5 sets of 500 MCM THHN conductors that run from the load side of a 2000 amp generator disconnect circuit breaker to an existing emergency distribution board on a job where just the generator is being replaced	195 Broadway New York NY	Approved	\$0.00
48519		MSM Electric, Inc. 417 Brighton Beach Avenue Brooklyn NY 11235	Requesting permission to leave as installed protected with ground fault circuit breakers in a place of assembly AC cables that do not contain an insulated equipment grounding conductor.	614 Sheepshead Bay Road Brooklyn NY	Hold	\$350.00
1) Prove hardship-pictures of why wiring can't be replaced. 2) Addition letter or diagram showing the quantity of cabling installed and where.						

ADVISORY BOARD CALENDAR

February 13, 2008

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
48520		Delaware Electrical Contracting Inc. 88 Guyon Avenue Staten Island NY 10306	Requesting permission to leave as installed 2 service switches on the outside of a commercial building and not group them together with 4 service switches that are installed inside of the same building.	3475 Victory Blvd. Staten Island NY	Approved	\$0.00
With the stipulation that signage is provided at each service indicating where the other service is located.						
48521	08A0104	Western Tub & Conduit 2001 E. Dominguez Street Long Beach CA 90801	Requested approval for use in New York City of your Electrical Steel Conduit- EMT (1/2"-4"), IMC (1/2"-4) and RMC (Rigid 1/2-6")		Approved	\$200.00