

ADVISORY BOARD CALENDAR

February 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46407CO	05A0244CO	Olympic Electrical Wiring Corp. 133 50th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	NYC Housing Authority 40-20 Channel Drive-Bldg. #1 Queens NY	Approved	\$0.00
Carry over from June 15, 2006 meeting.						
46408CO	05A0245CO	Olympic Electrical Wiring Corp. 133 50th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	NYC Housing Authority 453 Beach 40th St.-Bldg. #3 Queens NY	Approved	\$0.00
Carry over from June 15, 2005 meeting.						
46605CO1	05A0410CO1	Danco Electrical Contractor, Inc. 40-17 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	145 Brooklyn Avenue Brooklyn NY	Approved	\$0.00
Carry over from November 16, 2005 meeting. Remove note on generator, just ground frame. Job finalized 5/1/06.						
46687CO	05A0483CO	Danfoss Inc. 7880 Tranmere Drive Toronto ON L5S1L	Requested approval for use in New York City of your Danfoss LX Electrical Radiant Floor Heating Mats complete with Controller (thermostat). Model/Series Number: LX Series 088L.		Hold	\$0.00
Carry over from September 14, 2005 meeting.						
46798CO1	46798CO1	Hugh O Kane Electric Company, Inc. 30-40 48th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Queens Bay Apartments Rockaway NY	Approved	\$0.00
Carry over from November 16, 2005 meeting. Provide minimum 24" clearance(clearances issues in switgear room. Egress add additional doors) around all equipment and code clearance where service access is required on equipment. - Job finalized 5/15/06						

ADVISORY BOARD CALENDAR

February 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46809CO	05A0534CO	Daybrite Capri Omega 776 South Green Street Tupelo MS 38802	Requested approval for use in New York of your Recessed HID Downlight. Model/Series: OM13980			\$0.00
46810CO	05A0590CO	Tyco Thermal Controls Raychem 11 Exeter Pass Colts Neck NJ 07722	Requested approval for use in New York City of your New York City of your Multiple-entry power/splice/tee connection with junction box for Raychem heating cable. Model/Series Numbers: JBM Series.		Approved	\$0.00
46829CO	05A0597CO	Al-Lectric Electrical Corp. 137 Chrystie Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	106 Mott Street New York NY	Approved	\$0.00
Carry over from December 14, 2005 meeting.						
46834CO	05A0610CO	Hugh O Kane Electric Co., Inc. 30-40 48th Avenue-2nd Floor Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	90 John Street New York NY	Approved	\$0.00
Carry over from December 14, 2005 meeting.						
46866CO	06A0049CO	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	1107 Broadway New York NY	Approved	\$0.00
Carry over from January 25, 2006 meeting.						

ADVISORY BOARD CALENDAR

February 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46886CO	06A0028CO	Up Town Electric, Inc. 5-26 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	2900 Veterans Parkway West Staten Island NY	Approved	\$0.00
Carry over from January 25, 2006 meeting.						
46887CO	06A0008CO	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	11 Metro Tech Center New York NY	Approved	\$0.00
Carry over from January 25, 2006 meeting						
46888CO	06A0012CO	Hugh O Kane Electric Company, Inc. 30-40 48th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NYCHA Ocean Bay Apts. Edgemere Houses Far Rockaway NY	Approved	\$0.00
Carry over from January 25, 2006 meeting.						
46902CO	06A0009CO	Taft Electric Co., Inc. 31-31 123rd Street Flushing NY 11354	Requested approval for the electric service equipment proposed to be installed	21 Astor Place New York NY	Approved	\$0.00
Carry over from January 25, 2006.						
46905CO	06A0016CO	Spieler & Ricca Electrical Co., Inc. 52-09 Van Dam Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	55 West 25th Street New York NY	Approved	\$0.00
Carry over from January 25, 2006 meeting.						

ADVISORY BOARD CALENDAR

February 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46915CO	06A0031CO	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	375 Park Avenue New York NY	Hold	\$0.00
Carry over from January 25, 2006 meeting. Feeders undersized.						
46932CO	06A0061CO	Juno Lighting Inc. 1300 S. Wolf Road Des Plaines IL 60017	Requested approval for use in New York City of your Line of Exit Signs and Emergency Lighting Units. Series: Line of Exit Signs and Emergency Lighting Units. Series: NNYXS, NNYXSB, NNYXSC, NNYXESB, NNY6, NNY12, NNYXD and NNYXDB.		Approved	\$0.00
Carry over from January 25, 2006 meeting.						
46935	06A0070	A. Ceriello Electric, Inc. 15 Carroll Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	25 West Houston Street New York NY	Approved	\$650.00
46936	06A0071	Artic Electric Corp. 25 West 45th Street New York NY 10036	Requested approval for the electric service equipment proposed to be installed	3 Hanover Square New York NY	Approved	\$650.00
F.A. switch lockable in closed position per code. Job finalized 7/14/06.						
46937	06A0073	Hugh O Kane Electric Company, Inc. 30-40 48th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Bronx Lebanon Hospital 1276 Fulton Avenue Bronx NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46938	06A0074	Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	245 West 99th Street New York NY	Approved	\$650.00
46939	06A0077	Albin Gustafson Company 5 Tudor City Place New York NY 10017	Requested approval for the electric service equipment proposed to be installed	St. Luke's/Roosevelt Hospital 1091 Amsterdam Avenue New York NY	Approved	\$650.00
1) Indicate feeder size for sub-distribution Switchboard 'C'. 2) Block rear access to service Switchboard 'C'.						
46940	06A0078	Kleinknecht Electric Company, Inc. 940 Eighth Avenue New York NY 10019	Requested approval for the electric service equipment proposed to be installed	Citigroup 485 Lexington Avenue New York NY	Approved	\$650.00
1) Confirm generator neutral not grounded. (3-P ATS's provided). 2) Fuel storage shall not exceed code requirement.						
46941	06A0079	Power Masters Electrical Contracting, Inc. 37-23 27th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	400 East 57th Street New York NY	Approved	\$650.00
46942	06A0080	Robert Garcia Electrical Contracting Corp. 500 Trinity Avenue, Suite 1-B Bronx NY 10466	Requested approval for the electric service equipment proposed to be installed	521 West 42nd Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46943	06A0081	M.O.S Electrical Contracting Corp. 4304 Katonah Avenue Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	333 East 102nd Street New York NY	Approved	\$650.00
Provide physical drawing of new bus trough.						
46944	06A0082	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	10 West End Avenue New York NY	Approved	\$659.00
Provide reduced neutral calculations						
46945	06A0093	Zwicker Electric Co., Inc. 360 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	15 Central Park West New York NY	Approved	\$650.00
1) Indicate RHA wire for roof fire pump. 2) Indicate SEB on service 'C' 1-line diagram. 3) MS-C, retail service switch need neutral disconnect. 4) Show 800A secondary switch for 500KVA feeding DP-SC-ELEV. 5) Group service conductors wireway ABCN. 6) Main switchboard room-double doors to swing out. 7) CPW switchboard room-doors.						
46946	06A0098	The Electric Connection Inc. 410 West 127th Street New York NY 10027	Requested approval for the electric service equipment proposed to be installed	327 Central Park West New York NY	Approved	\$650.00
1) Provide fuse coordination per Code. 2) Provide detail of service end box location and routing of service conductors. Job finalized 9/23/09.						
46947	06A0099	Blake Electric Contracting Co., Inc. 311 E. 150th Street Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	88 Washington Place New York NY	Approved	\$650.00
Provide fuse coordination per code. Job finalized March 17, 2006.						

ADVISORY BOARD CALENDAR

February 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46948	06A0101	James F. Volpe Electl Contrg Corp. 81 Sackett Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	IS HS 43R Marsh Ave. and Essex Drive Staten Island NY	Approved	\$650.00
Bonding required in F.A. distribution switch.						
46949	06A0069	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	20 6th Ave, 6th Fl. Aka 45 W. 18th S New York NY	Approved	\$650.00
46950	06A0063	Stasi/Dallas Electrical Contracting, Inc. 6908 Eighth Avenue Brooklyn NY 11228	Requested approval for the electric service equipment proposed to be installed	Elmhurst Cancer Care Center 77-11 Broadway Elmhurst NY	Hold	\$650.00
Job changed Square D will send in updated drawings.						
46951	06A0064	Linco Electrical Contracting, Inc. 5442 Arthur Kill Road Staten Island NY 10307	Requested approval for the electric service equipment proposed to be installed	East Healthcare 140 Meisner Avenue Staten Island NY	Hold	\$650.00
1) Size of service switch not provided. 2) Fuse type in service switch not provided. 3) Bonding and grounding not shown on drawing. 4) Cut sheets of service switch not provided. 5) 2nd fusing not shown.						
46952	06A0065	Another Nycer Electric Corp. 652 Sackett Street Brooklyn NY	Requested approval for the electric service equipment proposed to be installed	415 East 37th Street New York NY	Denied	\$650.00
1) The drawings were not submitted in proper Advisory Board format. 2) Two sets of drawings were provided. 3) The new work was not identified on the drawings. 4) The types of fusing were not provided. 5) The manufacturer's cut sheet of the generator was not provided. 6) Generator room layout not provided. 7) Bonding and grounding of service equipment was not provided. 9) The service entrance conductors are undersized. 10) The submission shall be made by a New York City Licensed Master or Special Electrical Engineer, or an individual with comparable qualifications from an outside jurisdiction. The cover letter is from Another Nycer Electric Corp. Another Nycer Electrical Corp. should have been written in the title block. 11) The manufacturer's cut sheets of the switchboard was not provided.						

ADVISORY BOARD CALENDAR

February 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46953	06A0066	Infinity Electric Co. Inc. 88-14 Albert Rd. Ozone Park NY 11417	Requested approval for the electric service equipment proposed to be installed	Walgreens 103-16 Roosevelt Avenue Corona NY	Denied	\$650.00
The drawings were not submitted in the proper Advisory Board format.						
46954	06A0067	P.E. Stone, Inc. 50 Watts Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Quadriga 489 Fifth Avenue New York NY	Approved	\$650.00
46955	06A0072	Judd Electric Inc. 41-41 38th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	575 Eighth Avenue New York NY	Approved	\$650.00
46956	06A0075	A.S.R. Electrical Contracting, Inc. 177-04 93rd Avenue Jamaica NY 11433	Requested approval for the electric service equipment proposed to be installed	1072 Havemeyer Avenue Bronx NY	Hold	\$650.00
1) Increase bus size in last cabinet on the right side 3-2 x 1/4". 2) See if there are other options of running the service entrance conductors to the crown box.						
46957	06A0076	mpbell and Dawes Ltd. Electrical Contract 84-48 129th Street Kew Gardens NY 11415	Requested approval for the electric service equipment proposed to be installed	HSBC Cooling Tower 1 West 39th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46958	06A0083	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	11 East 29th Street New York NY	Approved	\$650.00
46959	06A0084	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Providence Rest Nursing Home 3304 Waterbury Avenue Bronx NY	Approved	\$650.00
46960	06A0085	Barbaro Electric Co. Inc. 331 38th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	200 Park Avenue South New York NY	Approved	\$650.00
46961	06A0086	Stonehill Electric Corp. 33-00 Northern Blvd.-Lobby Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	33-00 Northern Boulevard Long Island City NY	Approved	\$650.00
46962	06A0087	June Electric Corp. 2025 Continental Avenue, Suite 5E Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	15 Clarke Place Bronx NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46963	06A0089	Gallagher Electrical Contractings, Inc. 116 John Street, Suite 503 New York NY 10038	Requested approval for the electric service equipment proposed to be installed	111 Broadway New York NY	Approved	\$650.00
46964	06A0090	Arc Electrical & Mechanical Contrs, Corp. 26 Delavan Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	110 Livingston Street Brooklyn NY	Hold	\$650.00
Job changed Square D will send in updated drawings.						
46965	06A0091	SMC Electrical Contracting Inc. 150-11 14th Avenue Whitestone NY 11357	Requested approval for the electric service equipment proposed to be installed	Goldwater Memorial Hospital One Main Street Roosevelt NY	Approved	\$650.00
46966	06A0092	SMC Electrical Contracting Inc. 150-11 14th Avenue Whitestone NY 11357	Requested approval for the electric service equipment proposed to be installed	I.S. 113X 3710 Barnes Avenue Bronx NY	Approved	\$650.00
46967	06A0094	Zwicker Electric Co., Inc. 360 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Whitehall Street Ferry Terminal 4 South Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46968	06A0095	Robert B. Samuels Inc. 48 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Paramount Group 745 5th Avenue, Main Floor New York NY	Ok, but	\$650.00
Are the ATS's in the generator room.						
46969	06A0088	Elmac Electric, Inc. 61-20 Cooper Avenue Glendale NY 11385	Requested approval for the electric service equipment proposed to be installed	Monsignor McClancy H.S. 71-06 31st Avenue East Elmhurst NY	Approved	\$650.00
46970	06A0096	The Electric Connection Inc. 410 West 127th Street New York NY 10027	Requested approval for the electric service equipment proposed to be installed	New Yorker Hotel New York NY	Hold	\$650.00
1) Submission not in proper Advisory Board format. 2) Bus sizes not provided.						
46971	06A0097	BRG Electric, Inc. 88-26 Winchester Blvd. Queens Village NY 11427	Requested approval for the electric service equipment proposed to be installed	114-02 15th Avenue College Point NY	Approved	\$650.00
46972	406A0100	Olympic Electrical Wiring Corp. 133 50th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	103-105 Norfolk Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46973	06A0102	Mazza Electric Corp. 494 Eighth Avenue New York NY 10001	Requested approval for the electric service equipment proposed to be installed	330 5th Avenue New York NY	Hold	\$650.00
46974	06A0103	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	280 Madison Avenue New York NY	Approved	\$650.00
46975	=	Goldman Copeland Associates, P.C. 520 Eighth Avenue New York NY 10018	Requesting permission to mix together emergency and normal power in splice boxes for various life safety systems in a building where a 600 KW emergency generator will be installed.	Reckson Associates 1350 Ave of the Americas New York NY	Approved	\$0.00
with the stipulation that either the normal or emergency sets of feeders inside of the crown boxes are wrapped in a listed arc proof tape material as a barrier and are properly tagged indicating which sets are emergency or normal feeders and comply with 2002 NEC Article 225.37.						
46976	==	Tetra Tech 5 Penn Plaza, 15th Floor New York NY 10001	Requesting permission due to hardship, to install 61 new feeders in elevator shaftways that will power elevators and controllers in several low rise buildings.	NYCHA Whitman/Ingersoll Houses Brooklyn NY	Hold	\$0.00
46977	===	Savery Manfredonia, P.E., P.C. 56 West 45th Street, Suite 1104 New York NY 10036	Requesting permission in a building that has 7 existing elevators and will add 2 new elevators, to allow the installation of MI cable inside of the elevator shaftways to provide power to the elevators in a building that was not provided with space to install future risers.	1 Broadway New York NY	Denied	\$0.00

ADVISORY BOARD CALENDAR

February 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46978	=====	Herbert L. Mandel, P.C. Architect 443 Park Avenue South New York NY 10018	Requesting permission on Calendar numbers 46798 and 46888 to leave the replacement switchgear and equipment rooms as submitted due to the new equipment installed faces the exits and there not being enough wall space to add additional doors in these rooms	Ocean Bay Apartments Rockaway NY	Denied	\$0.00
Operational details of the automatic transfer switch, line and emergency feeds were not provided.						
46979	=====	Savery Manfredonia, P.E., P.C. 56 West 45th Street, Suite 1104 New York NY 10036	Requesting permission to tap the line side of a new ATS to power a new 10 HP sprinkler booster and jockey pumps located on the 55th floor due to the electric service room being located in the sub basement.	Chanin Building 122 East 42nd Street New York NY	Denied	\$0.00
Operational details of the automatic transfer switch, line and emergency feeds were not provided.						
46980	=====	P.E. Stone, Inc. 50 Watts Street New York NY 10013	Requesting permission to install a 800 amp 3 phase 120/208 volt panelboard in a mechanical room where several inches of one side of the panel will have a front clearance of 21 inches.	New York University 295 Lafayette Street New York NY	Approved	\$0.00
with the stipulation that the air conditioning unit is covered with a insulating material to provide protection for the electrician that will work on the panel.						
46981	=====	Spieler & Ricca Electrical Co., Inc. 52-09 Van Dam Street Long Island City NY 11101	Requesting permission to leave the room layout as submitted by leaving the switchboard with a side clearance of 12 inches from the wall, due to concrete columns.	55 West 25th Street New York NY	Approved	\$0.00
with the stipulation that a additional exit door must be installed behind service B.						
46982	=====	A.J. Caruso Electrical, Inc. 684 Richmond Road Staten Island NY 10304	Requesting permission to leave as installed service equipment that is not grouped together on a 2 family building where the outside service is for site lighting and the indoor services are for the dwelling units.	21 Mersereau Avenue Staten Island NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

February 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46983	=====	Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requesting permission to leave as installed 7 sets of underground service entrance conductors in F.R.E. conduit that enters the bottom of switchgear and is completely encased in concrete.	Mersereau Pumping Station 21 Mersereau Avenue Staten Island NY	Approved	\$350.00
with the stipulation that the conduits are sealed as per Section 230.8 of the 2002 NEC.						
46984	=====	D & S Electrical Corporation 450 Beach 48th Street Far Rockaway NY 11691	Requesting permission to not group together service equipment on a commercial building that had a new 2 family house built attached to it.	69-23 62nd Drive Middle Village NY	Approved	\$0.00
with the stipulation that the installation of the service entrance conductors comply with NEC Sections 230.2(E) and 230.6.						
46985	=====	D & S Electrical Corporation 450 Beach 48th Street Far Rockaway NY 11691	Requesting permission to install Schedule 80 non metallic conduit standpipes on 4 two family buildings located in a corrosive area, Far Rockaway, Queens	10 Bch 45th St., 30 Marvin St., & 291 Far Rockaway NY	Approved	\$0.00
46986	=====	D Alco Electrical, Inc. 119-19 14th Road College Point NY 11356	Requesting permission to leave as installed service equipment mounted on the outside of a commercial building enclosed in a metal screened in structure.	193-14 Northern Blvd. Queens NY	Approved	\$0.00
with the stipulation that the metal enclosure containing the service equipment is picked up in the grounding loop and the metal enclosure complies with the 2002 NEC Section 110.26 when the doors are in the open position.						
46987	=====	Artic Electric Corp. 25 West 45th Street New York NY 10036	Requesting permission due to lack of space inside of the existing service room, to install a new service for a fire pump outside of the service room.	3 Hanover Square New York NY	Approved	\$0.00
with the stipulation that the installation compiles with the 2002 NEC Section 230.2(E).						

ADVISORY BOARD CALENDAR

February 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46988	=====	Atkinson Koven Feinberg Engineers, LLP 1501 Broadway, Suite 700 New York NY 10036	Requesting permission to not comply with Section 110.26 (c) (2) in a service room where the egress would interfere with mechanical and laboratory equipment in adjacent spaces, and also interfere with the egress corridor.	89 Convent Avenue New York NY	Hold	\$0.00
Need mor information, sketch of room with dimensions needed.						
46989	#	Staten Island Electrical Contracting, Inc. 2653 Goethals Road North Staten Island NY 10303	Requesting permission to install a 400 amp service on the outside of a temporary construction office that is made up of 5 separate trailers that make up one building.	2851 Richmond Terrace Staten Island NY	Approved	\$0.00
46990	##	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requesting permission on a job where 5" existing conduits enter a undersized pullbox, to allow to pull additional new conductors into the undersized pullbox,	Newtown Creek Water 323 Greenpoint Avenue Brooklyn NY	Denied	\$0.00
46991	###	Absolute Advanced Electric, Inc. 135-15 37th Avenue, 4th Fl Flushing NY 11354	Requesting permission to run service entrance conductors approximately 12 feet into a 3 family building in EMT and to also not derate the service entrance conductors by 50%.	Amber Street Brooklyn NY	Hold	\$0.00
Provide calculation.						
46992	####	altPower, Inc. 160 Fifth Avenue, Suite 807 New York NY 10010	Requesting permission to install 84 photovoltaic modules that will be used as part of the balcony railings where the wiring that connects the PV's together will be contained inside of the balcony handrail.	88 Laight Street New York NY	Denied	\$0.00

ADVISORY BOARD CALENDAR

February 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46993	#####	J.P.E. Electrical Contractors, Inc. 7426 Amboy Road Staten Island NY 10307	Requesting permission to install non metallic cable in four 2 family buildings that has 3 stories and a one room mezzanine that does not exceed 33 1/3 percent of the gross floor.	New York NY	Approved	\$0.00
46994	06A0068	Cooper Lighting 1121 Hwy #74 South Peachtree City GA 30215	Requested approval for use in New York City of your Recessed Troffer. Model/Series numbers: AC-132-UNV-E881, AC-1287S-UNV-EB71, 2AC-232-UNV-EB81, 2AC-214T5-UNV-EB71, 2AC-22875-UNV-EBTIN, 2AC-224T5-UNV-EB71 and 2AC-217-UNV-EB81.		Approved	\$200.00