

# ADVISORY BOARD CALENDAR

**February 15, 2012**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
49270CO		Falcon Electrical Contracting Corp. 159 20th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Home Depot Jamaica 92-30 168th Street Jamaica NY	Approved	\$0.00
Carry over from February 11, 2009 meeting. 1) Size of main bonding jumper not shown. 2) Remove neutral bonds on emergency side disconnect switches, not a separately derived system, ground chassis only. 3) Do not bubble corrections. 4) Does fire pump service switch have rear doors? 230.64(B)(4). Job finalized 8/3/12.						
50869CO2		All American Electric Corp. 508 Lefferts Avenue Brooklyn NY 11225	Requested approval for the electric service equipment proposed to be installed	George Washington H.S. 549 Audobon Avenue New York NY	Approved	\$0.00
Carry over from October 19, 2011 meeting.						
50874CO3		Expert Electric, Inc. 18-71 41st Street Astoria NY 11105	Requested approval for the electric service equipment proposed to be installed	26Th Ward Water Pollution Con Brooklyn NY	Hold	\$0.00
Carry over November 9, 2011 meeting. 1) Special permission requested for clearances. 2) Fused disconnect switch required for portable generator. 3) Circuit breaker settings to be locked and tamperproof..						
50899CO		Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	bia University, Broadway and 218th New York NY	Approved	\$0.00
Carry over from October 19, 2011 meeting. Coordinate single line at drawing 411 with room and equipment elevation. Job finalized 3/26/12.						
50911CO		Meco Electric Co., Inc. 56 West Street Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	rth River WWTP, 135th and 12th Str New York NY	Hold	\$0.00
Carry over from October 19, 2011 meeting. 1) Show all clearances in 5KV service room and verify that room is ventilated. 2) Fused disconnect switch required for portable generator. 3) Drawings not in Advisory Board format. 4) Generator disconnect switches shown on 1-lines, not room layout. 5) Describe what work is new and what was existing and refurbished. 6) Are feeders new or existing? 7) Drawings numbers must be in sequence.						

# ADVISORY BOARD CALENDAR

**February 15, 2012**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50935CO		Horsepower Electric 821 McDonald Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	487 Keap Street Brooklyn NY	Approved	\$0.00
Carry over from October 19, 2011 meeting. Provide size of equipment grounding conductor on load side of fire pump. Job finalized 3/27/12.						
50936CO		E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1470 Madison Avenue New York NY	Hold	\$0.00
Carry over from October 19, 2011 meeting. 1) ATS#9 not identified on drawing 50565. 2) Normal feeds supplying fire pumps not shown. 3) Neutrals in emergency switchboard bonded 3 & 4 pole ATS' are being used. 4) Vertical bus sizes in ASCO gear not shown. 5) Someone who knows this job to appear at next meeting to explain job to the Board. 6) Review not complete.						
51001CO		J & R Rey Electrical Contrs Inc. 3471 Steenwick Avenue Bronx NY 10475	Requested approval for the electric service equipment proposed to be installed	250 East 57th Street New York NY	Hold	\$0.00
Carry over from December 14, 2011 meeting. 1) 5' clearance required in front of MDV switchboard. 2) Verify if transformer is being fed from the top or bottom. 3) New electrical distribution room is not code compliant.						
51012CO		Kanta Electric Corp. 34-21 56th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	215 East 161st Street Bronx NY	Approved	\$0.00
Carry over from December 14, 2011 meeting. 1) Show conductors after transition boxes ATS'. 2) Show board ESDB-10 bus bar sizes. Job finalized 7/25/12.						
51035CO		Commerce Electrical Contracting Corp. 40-12 28th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	PS-1 MOMA 46-01 21st Street Long Island City NY	Approved	\$0.00
Carry over from January 11, 2012 meeting.						

# ADVISORY BOARD CALENDAR

**February 15, 2012**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51037CO		RCM Technologies 3020 Westchester Avenue, Suite 401 Purchase NY 10577	Requested approval for the electric service equipment proposed to be installed	150-14 Jamaica Avenue Queens NY	Hold	\$0.00
Carry over from January 11, 2012 meeting. 1) Service room doors to open outwards. 2) Indicate bonding and grounding including bus/conductor sizes. 3) Permission is granted for 6'-4" clearance.						
51048CO		J.M. Electrical Corporation 122 East 42nd Street New York NY 10168	Requested approval for the electric service equipment proposed to be installed	550 Madison Avenue New York NY	Approved	\$0.00
Carry over from January 11, 2012 meeting.						
51066		Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	60 Hudson Street New York NY	Approved	\$650.00
51067		Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	NYU Tisch Elevator Addition 550 First Avenue New York NY	Denied	\$650.00
Received 2 room layouts only. No one line.						
51068		Rainbow Electric Co. Inc. 76-18 Rockaway Blvd. Woodhaven NY 11421	Requested approval for the electric service equipment proposed to be installed	117 Hudson Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**February 15, 2012**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51069		Verified Electl & Technical Services, Inc. 27 William Street, Suite 409 New York NY 10005	Requested approval for the electric service equipment proposed to be installed	1441 Broadway New York NY	Ok, but	\$650.00
1) Verify job address in title block. 2) 5' clearance required in front of new service switch. 3) is wireway in front of new service switch or above it? 4) Service entrance equipment grounding conductor undersized. 5) Conductors and wiring methods on line and load side of the transformers not shown. 6) Transformer not grounded. 7) Confirm AT & T panel is within 25' from transformer.						
51070		Zwicker Electric Co., Inc. 360 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	30-29 College Point Blvd. Queens NY	Approved	\$650.00
1) Verify equipment grounding conductor sizes for service entrance conductors supplying switchgear. 2) Equipment grounding conductor supplying 60 amp service switches and fire pump undersized. 3) Identify which breakers feed emergency load vs non emergency loads. 4) ASCO board, bus must be 12" off of finished floor. 5) Confirm that top breakers are 6'7" to the handles, ASCO gear. 6) Confirm current on main bus will not exceed 10,000 amps, ASCO gear, with possible future generators. Job finalized 3/26/12.						
51071		Robert B. Samuels Inc. 253 West 35th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	747 Third Avenue New York NY	Approved	\$650.00
Verify conductor and conduit sizes. Job finalized 8/17/12.						
51072		Spieler & Ricca Electrical Co., Inc. 52-09 Van Dam Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	533 West 52nd Street New York NY	Approved	\$650.00
1) Short circuit calculations not provided at meter banks. 2) Jockey pump cannot be tapped from the fire pump controller. Job finalized 5/7/12.						
51073		Edison Electrical Corporation 36-11 22nd Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	9 Bond Street New York NY	Hold	\$650.00
Verify that this is a 1000KVA service or show existing service equipment on 1-Line.						

# ADVISORY BOARD CALENDAR

**February 15, 2012**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51074		I.K.E. Electrical Corp. 601 West 26th Street, Suite 2M New York NY 10001	Requested approval for the electric service equipment proposed to be installed	642 Eldert Lane Brooklyn NY	Approved	\$650.00
51075		I.K.E. Electrical Corp. 601 West 26th Street, Suite 2M New York NY 10001	Requested approval for the electric service equipment proposed to be installed	628 Eldert Lane Brooklyn NY	Ok, but	\$650.00
1) Provide manufacturer cut sheet of panelboard MDP-1 showing its rating. 2) There are more than 6 service switches						
51076		Arc Electrical Construction Co., Inc. 739 Second Avenue New York NY 10016	Requested approval for the electric service equipment proposed to be installed	32 Avenue of the America New York NY	Approved	\$650.00
1) Submittal is not in Advisory Board format. 2) Provide individual room (area) layouts showing clearances.(Clearance dimensions in the room). Job finalized 10/17/12.						
51077		Brandl Electric 1926 Mott Avenue Far Rockaway NY 11691	Requested approval for the electric service equipment proposed to be installed	Jetro-Restaurant Depot 100 Oak Point Avenue Bronx NY	Denied	\$650.00
1) Short circuit curves not provided. 2) Voltage notes on drawing incorrect. 3) Manufacturer of equipment not shown. 4)Section bus sizes not shown. 5) Fuse types not shown on drawing. 6) Fire alarm system to be fused on normal and emergency sides. 7) Emergency generator to pick up fire pump fire and elevator if there is one.						
51078		John Michael Electrical Contracting, Inc. 85 Industrial Loop Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	60-10 Bay Parkway Brooklyn NY	Approved	\$650.00
Verify that occupancy does not require fire pump and fire alarm connection to emergency generator. Job finalized 1/14/13.						

# ADVISORY BOARD CALENDAR

**February 15, 2012**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51079		Axcel Electric Company 535 West 46th Street, 1st Fl. New York NY 10036	Requested approval for the electric service equipment proposed to be installed	310 East 67th Street New York NY	Approved	\$650.00
1) Show fusing on emergency side. 2) Verify that emergency fire pump branch circuit is fire rated. 3) Correct fire pump connection. Job finalized 1/14/13.						
51080		Joseph Garofolo Licensed Electl Contrs 125 1st Avenue New York NY 10003	Requested approval for the electric service equipment proposed to be installed	238 East 161st Street Bronx NY	Approved	\$650.00
51081		Tru-Val Electric Corporation 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	Hamilton Marine Transfer Station 500 Hamilton Avenue Brooklyn NY	Hold	\$650.00
1) Verify that the bubbled items are the only new work(all job is new) remove bubbles. 2) Fire pump and fire alarm must be bonded even this is a 3W system(Neutral ended in board). 3) Remove F.A, trans bonding. 4) verify that ATS "C-ATS-02" has integral service disconnects. 5) Issues in short circuit study must be addressed.						
51082		Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Nomura 825 8th Avenue New York NY	Approved	\$650.00
1) Show clearances inside of the generator room. 2) Equipment grounding conductors undersized for generators feeders. Verify if 250.122(F) is appliance? 3) Show electrical ground electric. 4) Provide egress/steps behind generators enclosures. Job finalized 8/9/12.						
51083		Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	270 Park Avenue New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**February 15, 2012**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51084		Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	113 Nassau Street New York NY	Approved	\$650.00
1) Tapped conductor to 100 amp disconnect switch undersized. 2) Fire alarm service switch neutral to be bonded to enclosure. Job finalized 4/23/12						
51085		Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	111 8th Avenue New York NY	Ok, but	\$650.00
1) Show second fusing. 2) Provide supplemental ground.						
51086		Strand Electric Co., Inc. 160 Eleventh Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	152-35 10th Avenue Queens NY	Ok, but	\$650.00
1) Show clearances in generator room, indicate front and rear of switches. 2) Generator neutrals not to be bonded to enclosures. 3) Trans for switches require rear access.						
51087		Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	30 Rockefeller Plaza New York NY	Approved	\$650.00
1) Service room to be mechanically ventilated. 2) Equipment grounding conductors undersized. Job finalized 8/2/12.						
51088		Spice Electrical Contracting Corp. 112-08 101 Avenue Richmond Hill NY 11419	Requested approval for the electric service equipment proposed to be installed	Shephardic Home 2266 Crospey Avenue Brooklyn NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**February 15, 2012**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51089		A.S.K. Electrical Contracting Corp. 26-50 BQE West Unit 2 Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Pierrpont House 55 Pierrpont St. Brooklyn Heights NY	Approved	\$650.00
1) Neutral not bonded in 100 amp service switch. 2) Show AIC at womens exchange panel. 3) Service room doors to open outwards. 4) Section 4 describe boxes 1-Line. 5) Neutral link to be on line side. 6) Show correct voltage on drawing. Job finalized 5/7/12.						
51090		Prince Electrical Contracting Corp. 1406 Blondell Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Holiday Inn Express 60 West 36th Street New York NY	Approved	\$650.00
1) Neutrals in service switches not bonded to enclosure's. 2) Show front clearances in room layout. 3) Provide short circuit calculations. Job finalized 7/31/12.						
51091		Hatzel & Buehler, Inc. 45 Broadway, Suite 1240 New York NY 10006	Requested approval for the electric service equipment proposed to be installed	Church Pension Group 19 East 34th Street New York NY	Hold	\$650.00
1) Primary switch at 208V is undersized for the in-rush current. 2) Provide GFI at secondary of transformer.						
51092		Kraft Electric Corporation 5310 Church Avenue Brooklyn NY 11203	Requested approval for the electric service equipment proposed to be installed	99 Hillside Avenue New York NY	Approved	\$650.00
Undersized tap conductor. Job finalized 3/27/12.						
51093		Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	Marriot 25 West 37th Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

February 15, 2012

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51094		Ral-Bar Electric, Inc. 34-09 45th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Shopping Center 134-40 Springfield Blvd. Queens NY	Approved	\$650.00
51095		Ramdeen s Electrical Contracting Corp. 132-10A Liberty Avenue Richmond Hill NY 11419	Requested approval for the electric service equipment proposed to be installed	373 Wythe Avenue Brooklyn NY	Approved	\$650.00
51096		Atlas-Acon Electric Service Corp 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Credit Agricole 1301 Avenue of the Americas New York NY	Approved	\$650.00
51097		Cogen Electrical Services Inc. 528 Craven Street Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	2960 & 2980 West 29th Street Brooklyn NY	Approved	\$650.00
11/25/13 Swapped Rev 2						
51098		Horsepower Electric 4109 Fort Hamilton Parkway Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	250 West Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**February 15, 2012**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51099		Gallagher Electric 111 John Street, Suite 2605 New York NY	Requested approval for the electric service equipment proposed to be installed	Bloomberg L.P. 120 Park Avenue New York NY	Hold	\$650.00
1) Verify lengths of 600 MCM transitions from MI cables. 2) Bus sizes not shown in new UPS switchgears. 3) Correct title block contractor's name. 4) Conductors undersized from gen to MI cable. 5) Indicate GFI protection. 6) Provide code required clearance for 4000A gen main CB.						
51100		Babaro Electric Co., Inc. 331 38th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	201 Douglass Street Brooklyn NY	Approved	\$650.00
1) Indicate where front of generators switch is located. 2) Verify sizes of bus bars 25" x 7". 3) Emergency disconnect and service switches to be ground fault protected. 4) Tapped conductors undersized and lengths of taps not shown. 5) Generator cut sheet not provided. Job finalized 6/13/13.						
51101		Essential Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	590 6th Avenue New York NY	Approved	\$650.00
51102		Genmar Electrical Contracting Corp. 98-19 103rd Avenue Ozone Park NY 11417	Requested approval for the electric service equipment proposed to be installed	3-5 West 36th Street New York NY	Approved	\$650.00
1) Provide sizes of equipment grounding conductors on fire pump and fire alarm. 2) Show bonding of fire alarm switch and fire pump. 3) Verify that Jockey pump controller is listed as service equipment. 3/19/14 1) 2000 amp service switch overfused. 2) EGC required in FMC for 10' tap. 7/18/14 Job finalized. 3/24/15 Swapped drawing 1, Revision 4.						
51103		New Phase Electrical Contractors, Inc. 725 East 136th Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	211 Central Park West New York NY	Approved	\$650.00
Tapped conductor to 800 amp disconnect switch is undersized. Job finalized 8/7/12.						

# ADVISORY BOARD CALENDAR

**February 15, 2012**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51104		Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	15 Washington Avenue Brooklyn NY	Approved	\$650.00
1) 4 sets 9f 500 MCM fused at 1600 amps. 2) Redesign service and distribution areas so access is readily available. 3) Provide details of grounding systems grid. 4) Remove neutral bond in fire alarm switch. Job finalized 3/21/12.						
51105		Allran Electric of NY 120 Broadway, 36th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	825 8th Avenue New York NY	Approved	\$650.00
51106		Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Numora Holding America, Inc. 825 Eighth Avenue New York NY	Approved	\$650.00
1) Bus sizing not shown in panels DS-UPS-B and DS-UPS-A. 2) Verify section bus sizes in panel DS Mech-B. Job finalized 8/8/12.						
51107		Spieler & Ricca Electrical Co., Inc. 52-09 Van Dam Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	46-15 Center Boulevard Long Island City NY	Approved	\$650.00
51108		OHM Electrical Corp. 39-40 21st Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	ASPCA 424 East 92nd Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**February 15, 2012**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51109		Kleinknecht Electric Company, Inc. 252 West 37th Street, 9th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	452 5th Avenue New York NY	Approved	\$650.00
51110		H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	620 12th Avenue New York NY	Approved	\$650.00
51111		Colony Electric Company Inc. 178 Industrial Loop Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	18 East 16th Street New York NY	Approved	\$650.00
Provide supplemental and ground terminals in service switches. Job finalized 3/26/12.						
51112		E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Mt. Sinai 1425 Madison Avenue New York NY	Approved	\$650.00
51113		E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Petsmart 632 Broadway New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**February 15, 2012**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51114		Integral Electrical Power & Control Corp. 307 7th Avenue, Suite 507 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	145 West 28th Street New York NY	Approved	\$650.00
2 sets of 400MCM overfused, service Switch #1. Job finalized 3/26/12.						
51115		Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	127 East 79th Street New York NY	Approved	\$650.00
TVSS switch in same cubicle that supplies the fire pump. Job finalized 3/26/12. 8/21/14 Swapped A-Rev 5, B-Rev 4 and C-Rev 6.						
51116		Corporate Electric Group, Inc. 14-34 110th Street, Suite 201 College Point NY 11356	Requested approval for the electric service equipment proposed to be installed	510 Madison Avenue New York NY	Approved	\$650.00
1) Verify if new switchgear is rear accessible. 2) Are emergency load feeding life safety or normal loads, ground fault indication or ground fault protection required. Job finalized 3/27/12.						
51117		Kew Electric Inc. 1428 Hylan Blvd. Staten Island NY 10305	Requested approval for the electric service equipment proposed to be installed	Maimonides Cancer Center 4802 Tenth Avenue, 4th Floor New York NY	Approved	\$650.00
51118		Arch Electric Inc. 42-44 Crescent Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	285 Broadway New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**February 15, 2012**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
51119		Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	4 Metrotech Center Brooklyn NY	Approved	\$650.00
11/27/13 Swapped Rev2 A and B.						
51120		Glo Electric LLC 441 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	1951 Park Avenue New York NY	Approved	\$650.00
51121		J. United Electric 651 Willowbrook Road Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	210 West 18th Street New York NY	Approved	\$650.00
51122		Litespeed Electric 135 West 29th Street New York NY 10001	Requesting permission to replace an existing 3000 amp service switch in a existing enclosure without a formal Advisory Board submittal.	Rose Associates 230 Park Avenue South New York NY	Approved	\$0.00
Code: 110.2(B)(1).						
51123		Expert Electric, Inc. 18-71 41st Street Astoria NY 11105	Requesting permission to leave existing electrical equipment mounted to the wall behind a new replacement at 4160V emergency switch gear where the clearances do not comply with Table 110.34A Condition 3 which requires 6' clearance.	26th Ward Water Pollution Control Brooklyn NY	Denied	\$0.00