

ADVISORY BOARD CALENDAR

February 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46054CO	04A0523CO	Robert B. Samuels Inc. 48 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	New Water St. Corp. 55 Water Street New York NY	Approved	\$0.00
Carry over from December 15, 2004 meeting.						
46104CO	04A0517CO	Lutron Electronics Co., Inc. 7200 Suter Road Coopersburg PA 18036	Requested approval for the use in New York City of your Digital Ballast Control.		Approved	\$0.00
Carry over from the December 15, 2004 meeting.						
46125CO	05A0030CO	DM Electric Corporation 150 Mada Avenue Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	Exxon Mobil Terminal 4101 Arthur Kill Road Staten Island NY	Approved	\$0.00
Carry over from January 12, 2005 meeting.						
46143CO	05A0027CO	Dola Electrical Co., Inc. 3044 E. Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	North General Hospital 1979 Madison Avenue New York NY	Approved	\$0.00
Carry over from January 12, 2005 meeting.						
46144CO	05A0034CO	Evergreen Electrical Corp. 133 50th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	84 Front Street Brooklyn NY	Approved	\$0.00
Carry over from January 12, 2005 meeting.						

ADVISORY BOARD CALENDAR

February 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46152	05A0043	CSA Engineering Services 26 Wildlife Drive New Mildford CT 06776	Requested approval for the electric service equipment proposed to be installed	North Shore Towers 272-40 Grand Central Parkway Floral Park NY	Hold	\$650.00
1) Provide primary protection on 3750 KVA XFMR. 2) Provide either Sync-check relays or key INLKS on new 5 KV switchgear.						
46153	05A0042	CSA Engineering Services 26 Wildlife Drive New Mildford CT 06776	Requested approval for the electric service equipment proposed to be installed	Kings Harbor Multicare Ctr. 2000 East Gun Hill Road Bronx NY	Approved	\$650.00
Show available short circuit current at breakers and AIC of each breaker.						
46154	05A0041	CSA Engineering Services 26 Wildlife Drive New Mildford CT 06776	Requested approval for the electric service equipment proposed to be installed	Buena Vida Continuing Care 48 Cedar Street Brooklyn NY	Approved	\$650.00
46155	05A0040	Wade Electric, Inc. 30-91 12th Street Long Island City NY 11102	Requested approval for the electric service equipment proposed to be installed	The NY Botanical Garden 200th Street & Kazimiroff Bronx NY	Approved	\$650.00
46156	05A0064	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Atlas Park 80th Street & Cooper Avenue Glendale NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46157	05A0065	Dal Electrical Corporation 5910 11th Avenue Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	Episcopal Church 815 Second Avenue New York NY	Approved	\$650.00
46158	05A0066	Dean Electric Co., Inc. 7909 Third Avenue Brooklyn NY 11209	Requested approval for the electric service equipment proposed to be installed	Maimonides Medical Center 4802 Tenth Avenue Brooklyn NY	Approved	\$650.00
46159	05A0067	Michael Schondorf, Inc. 450 West 31st Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	224 12th Avenue New York NY	Approved	\$650.00
46160	05A0068	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Parkchester North Apts 1705 Purdy Street Bronx NY	Approved	\$650.00
46161	05A0069	A & M Electrical Service Inc. 5309 2nd Avenue Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	414 Flushing Avenue Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46162	05A0070	GMA Electrical Corporation 201 Edward Curry Avenue, 2nd Floor Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Verizon 355 Forest Avenue Staten Island NY	Approved	\$650.00
Waiting for special permission.						
46163	05A0071	GMA Electrical Corporation 201 Edward Curry Avenue, 2nd Floor Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Verizon 680 Fairview Avenue Brooklyn NY	Approved	\$650.00
Waiting for special permission.						
46164	05A0072	H & L Electric Inc. 41-11 28th Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	Place 455 Madison Avenue New York NY	Approved	\$650.00
Approval for new 2000A switches only must file future equipments. Item finalized 2/23/05.						
46165	05A0073	Inner City Electrical Contractors, Inc. 160 21st Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Burson Marsteller 230 Park Avenue South New York NY	Approved	\$650.00
46166	05A0074	Inner City Electrical Contractors, Inc. 160 21st Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	336 Broadway New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46167	05A0075	Twins Electric Corporation 460 Austin Place Bronx NY 10455	Requested approval for the electric service equipment proposed to be installed	Columbia University 562 West 113th Street New York NY	Approved	\$650.00
46168	05A0076	Hugh O Kane Electric Co., Inc. 30-40 48th Avenue-2nd Floor Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1271 6th Avenue New York NY	Approved	\$650.00
46169	05A0085	CSA Engineering Services 26 Wildlife Drive New Mildford CT 06776	Requested approval for the electric service equipment proposed to be installed	Holliswood Care Center 195-44 Woodhull Avenue Brooklyn NY	Approved	\$650.00
46170	05A0086	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	720 5th Avenue New York NY	Approved	\$650.00
Provide signage for second service room.						
46171	05A0089	Ostroff Electric, Inc. 102-14 159th Road Howard Beach NY 11414	Requested approval for the electric service equipment proposed to be installed	965 Fifth Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46172	05A0090	Jen Electrical Contractors, Inc. 7812 New Utrecht Avenue Brooklyn NY 11214	Requested approval for the electric service equipment proposed to be installed	50 East 13th Street New York NY	Approved	\$650.00
46173	05A0091	Safeco Electrical, Inc. 61-04 Maurice Avenue Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	85 Adams Street Brooklyn NY	Approved	\$650.00
1) Fire pump switch and fuse to be sized 600% FLA 400A switch undersized. 2) Fire pump feeder to be fire rated. Item finalized 2/24/05.						
46174	05A0092	James F. Volpe Electl Contg Corp. 81 Sackett Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	St. John's University 173-04 Union Turnpike Queens NY	Approved	\$650.00
1) Service switch must be ahead of 480 volt C.T. 2) Remove neutral links in 100 and 30 amp service switches.						
46175	05A0093	Reilly Electrical Inc. 3332 Nostrand Avenue Brooklyn NY 11229	Requested approval for the electric service equipment proposed to be installed	113 Mercer Street New York NY	Denied	\$650.00
1) The type of fusing was not provided. 2) Tap box copper detail not provided. 3) The neutrals are bonded in meter pans and 200 amp disconnect switches after the service switch. 4) The 400 amp service switches feeding the roof chiller and elevator are over fused. 5) The end box copper detail shows 8 sets of termination lugs instead of 10 lugs.						
46176	05A0094	A.T.J. Electrical Co., Inc. 33-61 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	21 West 86th Street New York NY	Approved	\$650.00
New 100 amp service switch must be shown in Advisory Board format showing fuse type and neutral bond						

ADVISORY BOARD CALENDAR

February 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46177	05A0095	Tru-Val Electric, Corp. 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	Brooklyn Public Library 1 Grand Army Plaza Brooklyn NY	Approved	\$650.00
46178	05A0096	Adelante Electrical Company, Inc. 137-11 Booth Memorial Avenue Flushing NY 11355	Requested approval for the electric service equipment proposed to be installed	Police Academy 235 East 20th Street New York NY	Approved	\$650.00
46179	05A0097	Klein, Levin Associates 1839 Ocean Parkway Brooklyn NY 11223	Requested approval for the electric service equipment proposed to be installed	24 West 40th Street New York NY	Approved	\$650.00
46180	05A0098	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	New York Post 900 East 132nd Street Bronx NY	Hold	\$650.00
1) Clarify conduit type for 4000A feeders from generator switchgear verify ground wire size. 2) Furnish cuts on ATS's and generators. 3) Provide coordinator study. 4) Do not exceed 360 degree bends in conduit in 3 dimensions. 5) Provide details of underground conduit banks. Show compliance with code required derating. (Annex B).						
46181	05A0037	City Electrical Contractors, Inc. 222-17 Jamaica Avenue Queens NY 11428	Requested approval for the electric service equipment proposed to be installed	160 East 48th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46182	05A0039	D.J. Electrical Contractors, Inc. 217 Fordham Street Bronx NY 10464	Requested approval for the electric service equipment proposed to be installed	27 West 86th Street New York NY	Approved	\$650.00
46183	05A0038	Al s Best Electric Co., Inc. 915 Broadway, Suite #607 New York NY 10010	Requested approval for the electric service equipment proposed to be installed	2320 Eighth Avenue New York NY	Approved	\$650.00
46184	05A0046	Barbaro Electric Co., Inc. 331 38th Street Brooklyn NY	Requested approval for the electric service equipment proposed to be installed	250 West 40th Street New York NY	Denied	\$650.00
1) There is a water meter and piping in front of the service equipment affecting required clearances. 2) Service entrance conductors for service switch #6 are to be encased in concrete.						
46185	05A0047	Brown & Simpson Electrl Contracting Inc. 154 Bristol Street Brooklyn NY 11212	Requested approval for the electric service equipment proposed to be installed	333 West 17th Street New York NY	Approved	\$650.00
46186	05A0048	Brown & Simpson Electrl Contracting Inc. 154 Bristol Street Brooklyn NY 11212	Requested approval for the electric service equipment proposed to be installed	8301 Shore Road Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46187	05A0049	Innovative Client Solutions 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	1 Hoyt Street Brooklyn NY	Approved	\$650.00
46188	05A0050	NJD Wiring & Electric, Inc. 55 Huron Street Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	510 6th Avenue New York NY	Approved	\$650.00
46189	05A0051	Takos & K Electric Inc. 38-58 11th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	140 West 69th Street New York NY	Approved	\$650.00
46190	05A0052	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	11 West 42nd Street New York NY	Approved	\$650.00
46191	05A0053	Hester Electrical Inc. 18 Orchard Street, 1st Floor New York NY 10002	Requested approval for the electric service equipment proposed to be installed	132-03 Sanford Avenue Flushing NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46192	05A0054	Response Electric, Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	1148 5th Avenue New York NY	Approved	\$650.00
46193	05A0055	Salzman Electric Inc. 208-05 35th Avenue Baysided NY 11361	Requested approval for the electric service equipment proposed to be installed	262 Central Park West New York NY	Approved	\$650.00
46194	05A0056	June Electric Corp. 3110 Wilkinson Avenue, Suite 2C Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	Renaissance Estates Bushwick Avenue & Forrest Street Brooklyn NY	Approved	\$650.00
46195	05A0057	Urban Power & Lighting Inc. 24-42 49th Street Astoria NY 11103	Requested approval for the electric service equipment proposed to be installed	1716 Southern Boulevard Bronx NY	Approved	\$650.00
46196	05A0058	TMF Electrical Contractor, Inc. 359 49th Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	31 West 27th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46197	05A0059	H.P. Electrical Designs Inc. 321 West 44th Street, Suite 405 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	310 East 53rd Street New York NY	Approved	\$650.00
46198	05A0060	Marty Dorkin, Licensed Electrician 547 Coney Island Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	5960 59th Street Queens NY	Approved	\$650.00
46199	05A0061	Accurate Electrical Corp. 4319 18th Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	YGS Trade School 74-10 88th Street Queens NY	Approved	\$650.00
46200	05A0062	Gateway Electric Corp. 11-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	400 West 55th Street New York NY	Approved	\$650.00
46201	05A0063	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Montefiore Med. Center 3450 Wayne Avenue Bronx NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

February 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46202	05A0077	OHM Electrical Corp. 39-40 21st Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Pfizer 219 East 42nd Street New York NY	Approved	\$650.00
46203	05A0078	Matros Automated Electrl Constn Corp. 214 West 29th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Howard Johnson Hotel 851 8th Avenue New York NY	Approved	\$650.00
400 and 600 amp fuses shoube 4A2K.						
46204	05A0079	Hugh O Kane Electric Co., Inc. 30-40 48th Avenue-2nd Floor Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	32 Avenue of the Americas New York NY	Approved	\$650.00
46205	05A0080	Hugh O Kane Electric Co., Inc. 30-40 48th Avenue-2nd Floor Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	32 Avenue of the Americas New York NY	Approved	\$650.00
46206	05A0081	Albin Gustafson Company 5 Tudor City Place New York NY 10017	Requested approval for the electric service equipment proposed to be installed	St. Luke's Nulhenberg Bldg. 1111 Amsterdam Avenue New York NY	Hold	\$650.00
1) No coordination between 4000 amp service switch fuses and 2-new 3000 amp switches. 2) Provide size of take off bus to new 3000 amp switch.						

ADVISORY BOARD CALENDAR

February 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46207	05A0082	Compsec Electric Corporation 31-54 12th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	45-02 Ditmars Boulevard Astoria NY	Approved	\$650.00
Change fuse in service switch #2 to 1000 amp or clarify size of transfer switch.						
46208	05A0084	Compsec Electric Corporation 31-54 12th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	41 Broad Street New York NY	Approved	\$650.00
Change fuse in service switch #2 to 1000 amp or clarify size of transfer switch.						
46209	05A0083	Forum Engineering, P.C. 139 Fulton Street New York NY 10038	Requested approval for the electric service equipment proposed to be installed	Westside Supermarket 77 7th Avenue New York NY	Hold	\$650.00
A fused switch must be installed ahead of 3-400 amp disconnect switches.						
46210	05A0087	Pinto & Teger Electric Corp. 32-24 111th Street East Elmhurst NY 11369	Requested approval for the electric service equipment proposed to be installed	107-15 70th Road Queens NY	Approved	\$650.00
Switch for fire alarm to be changed to fuse cut-out. Item finalized 2/23/05.						
46211	05A0088	Jeco Electrical Service Corp. 1162 Intervale Avenue Bronx NY 10459	Requested approval for the electric service equipment proposed to be installed	530 West 27th Street New York NY	Approved	\$650.00
Provide fuses for 800 amp. Item finalized 2/24/05.						

ADVISORY BOARD CALENDAR

February 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46212	-	Atkinson Koven Feinberg Engineers, LLP 1501 Broadway, Suite 700 New York NY 10036	Requesting permission to waive the required coordination between the 3000 amp service switch (3000 amp A4 by fuses) and the 2000 amp disconnect switch (2000 amp A4BQ fuses).	1271 Avenue of the Americas New York NY	Approved	\$0.00
46213	--	Emergency Electrical Contracting Inc. 9202 Avenue M Brooklyn NY 11236	Requesting permission to utilize 220-35 optional calculations for determining existing loads, by using actual maximum demand readings for service loads.	2081 2nd Avenue New York NY	Approved	\$0.00
46214	---	Mage Electrical Contractors 158 Perry Street New York NY 10014	Requesting permission due to lack of space inside of the existing service room, to install a new 600 amp service switch and its associated equipment on a wall outside of the service room. Signage will be provided to indicate that there is existing service equipment in the other room.	800 Second Avenue New York NY	Approved	\$0.00
46215	--	R. Donovan & Son Electric Co., Inc. 198-08 33rd Avenue Flushing NY 11358	Requesting permission to leave as installed weatherproof service equipment on the outside of the building.	Breezy Point Medical Center 204-08 Rockaway Point Blvd. Far Rockaway NY	Approved	\$0.00
46216	----	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requesting permission to install a lighting fixture inside of a shower wall approximately 3 feet off the floor with a gasketed screw on cover.	ABG Hotel 145 West 45th Street New York NY	Approved	\$0.00
With stipulation						

ADVISORY BOARD CALENDAR

February 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46217	-----	Zwicker Electric Co., Inc. 200 Park Avenue South New York NY 10003	Requesting permission to omit the use of ground fault protection on a 2000 amp 120V/208V feeder that will be stepped up to 277V/480 Volts due to compensating for voltage drop, and dropped back down to 120V/208V.	Octagon Park 888 Main Street Roosevelt Island NY	Approved	\$0.00
46218	--	Associated Electrl Contrs of N.Y. Corp. 27 East 233rd Street Bronx NY 10470	Requesting permission to install a seventh service switch where one of the existing service switches powers a fire pump.	2920 West 21st Street Brooklyn NY	Approved	\$0.00
46219	---	Ramdeen s Electrical Contracting Corp. 132-10A Liberty Avenue Richmond Hill NY 11419	Requesting permission to leave as installed service equipment in a 2 family building that is not grouped together due to the building having no common areas.	317 Beach 28th Street Queens NY	Approved	\$0.00
46220	-----	Izzo Electric, Inc. 2522 E. Tremont Avenue Bronx NY 10461	Requesting permission to leave as installed due to hardship to correct kitchen receptacles installed as per the old New York City Electrical Code.	1069 Walton Avenue Bronx NY	Approved	\$0.00
46221	--	Dynamic Electrical 105-15 Jamaica Avenue Richmond Hill NY 11418	Requesting permission to leave as installed in two 5 family buildings without common areas service equipment installed on the outside of the buildings.	31-10 and 31-12 Lewmay Rd Queens NY	Hold	\$0.00
Jobs filed January 30, 2004 . Contractor will send in pictures of the buildings.						

ADVISORY BOARD CALENDAR

February 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46222	-	Atkinson Koven Feinberg Engineers, LLP 1501 Broadway, Suite 700 New York NY 10036	Requesting concept approval for a service room layout totaling over 1000 KVA.	Carnegie Hall 57th Street, Switchgear Room New York NY	Approved	\$0.00
46223	05A0036	Liebert Corporation 1050 Dearborn Drive Columbus OH 43085	Requested approval for use in New York City of your Configurable Output Distribution. Model/Series No. PDXIX and PDX2X.		Hold	\$200.00
Need UL report, wiring diagram and a sample						
46224	05A0044	Associated Electrl Contrs of N.Y. Corp. 27 East 233rd Street Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	2929 West 21st Street Brooklyn NY	Approved	\$650.00
46225	05A0045	Beacon Electric Corp. 266 Jericho Turnpike Floral Park NY 11001	Requested approval for the electric service equipment proposed to be installed	2 Bch St. aka 387-397 Greenwich St New York NY	Ok, but	\$650.00
Decrease 1200 amp service switch fuse or increase conductors off of 1200 amp service switch or increase bus in panelboard.						
46226	-	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requesting permission not to have three (3) feet clearance on both ends of the Free Standing Switchboard.	Parkchester North Apts 1705 Purdy Street Bronx NY	Approved	\$0.00