

# ADVISORY BOARD CALENDAR

**February 21, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55262	18A0004	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Comply sec 230.43 for FP &amp; FA service entrance conductor installation. 2) Comply sec 230.42(A) for vertical bus inn MLD section of SS # 1,2,3 switchboard. 3) Show "Future Retail" tap conductor length from SS# 3 4) Provide bonding &amp; grounding for SS # 1,2 &amp; 3 4/5/18 - 1) Comply sec 408.60(A) and relocate bonding &amp; grounding to the line side of N.D.L. 2) Provide bonding &amp; grounding to "Future retail #2" remote SS# comment #4 partially addressed 4/30/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/21/18- Provide the correct Rev-2 for drawing #1 of 3. Include new contractor info. 1/30/19 Swap dwg # 1 of 3 Rev-2 2 of 3 Rev-0 3 of 3 Rev-1</p>				
55108	18A0009	Requested approval for use in New York City of your combined utilities box systems Model CUB-WP series. Outdoor receptacle mounted in exterior residential balconies	Approved	\$200.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
	18A0013	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>OR -- 1) Provide asbestos abatement compliance required documents. 2) ATS not accepted to be in service room (Verify if for emergency standby) 3) Show grounding of existing S.SWs</p>				
55089	18A0022	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 10/31/18 Swap dwg #1 of 2-Revision 1</p>				

# ADVISORY BOARD CALENDAR

**February 21, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55655	18A0024	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Service cond feeds F.A. sw is undersized. 2) Provide coordination study signed &amp; sealed by P.E. 3) Verify front of the 750 KVA xfmr on the floor plan 4) Provide NRTL listing to xfms 5) Provide NRTL certification of switch gears used in the project. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 10/12/18 1) Verify #of sets of Vitalink MC cables feed 60HP fire pump. 2) Coordination between "X-Swd-R" secondary OCPD and downstream fuses are not included within coordination study. 11/21/18- GEC of fire pumps- emergency side, undersized- T250.66. 1/10/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55408	18A0049	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Comply with 700.9 (B)(5) 2) Comply with 408.60(E)(B) - parallel switchboard main bus bar undersized. 3) Provided TCC to be signed and sealed by P.E. &amp; provide coordination between 2000A Br &amp; the rest of downstream breakers. 4) Asbestos abatement required. 5) Show OCPD valve &amp; type of Existing 'SDP' # 3 of 8 &amp; 'SDP' # 14R # 20 with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/3/18 - 1) Item # 3 not addressed &amp; provide coordination between 800A KRPC &amp; existing ECN fuse (downstream). 6/7/18 1) 1200A C.B. type in 'Swbd-GEN' doesn't match the coordination study. 7/27/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55951	18A0051	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Asbestos abatement compliance required. 2) Verify complying with 695.6(B)(1) &amp; 760.4B 3) Fix typo in "EPP-LS". 9/20/18 1) Remove bonding from new F.A. &amp; F.P. switches-emergency side. 2) Fix typo of "EPP-LS" Panel-verify if the panel is M.L.O. and provide main vertical bus bar size. 3) F.P. cond-normal side is undersized. 4) Verify cond. Size feeds smoke control system. ATS-emergency side-for dwg #C doesn't match dwg #D. 11/23/18. 1) Item #4 from Revision 9/20/18 is not addressed. 5/23/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

# ADVISORY BOARD CALENDAR

**February 21, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55206	18A0054	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Show FA service entrance conductor size with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>2) Provide cutsheet for meter bank # 1 &amp; 2 3/23/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/10/19 Swap dwgs A&amp;D rev 2 and B&amp;C rev3</p>				
55167	18A0055	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Tap cond. (# 10 AWG) of 30A fuses are undersized 2) Jockey pump tap is undersized. 3) Provide supplemental grounding to all remote S.Sws (F.A, F.P, &amp; SS # 3) 4) Asbestos abatement compliance required. 5) Fix typo for incoming of 'DP-R' Panel. 6) Verify that service swboard # 2 neutral is connected to the bonded s.swboard # 1 neutral &amp; the ground bar is connected as well. 7) Verify tap length of 60A SW off 200A wiring trough. Verify complying with 695.6 (B)(1) - 2hr fire rated required. 8) Verify main switchboard listing with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/22/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/10/18 Swap Dwg A-Revision 5 and Dwg B-Revision 5. 10/16/2020 Amended Plan #A &amp; B Rev-6. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55074	18A0063	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/30/19 Swap A-Revision 1. 12/19/19 Swap dwg A-Revision 2. 6/29/2020 Amended Plan # A Rev-3, B &amp; C Rev- 0                      Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				

# ADVISORY BOARD CALENDAR

**February 21, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55198	18A0086	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide coordination between "4000A" breaker &amp; downstream "800A" breaker sign &amp; sealed by P.E. 3/29/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/30/19 Swap Dwg 1, 2 &amp; 3 rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55177	18A0087	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR - Please provide license number on cover letter. 3/26/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/31/2018- 1) Swap dwg #A Rev-1. 4/18/19 Swap dwg #A-Revision 2.</p>				
55159	18A0088	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR - 1) Provide existing bus size of SS# 1 3/19/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/16/18 - Swag drawing A rev2 4/1/19 Swap dwg #A Rev-3 7/18/2019 Swap Dwg # D-1801-29848-A Rev-4</p>				
	18A0090	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>1) Comply sec 230.42 (A) for service entrance conductor between 'SEB' &amp; 'MSG-G &amp; MSB-G' switchboard 2) Comply sec 230.6 for service entrance conductor between "SEB" &amp; "MSG-G &amp; MSB" switchboard. 3) Relocate FA &amp; FP neutral conductor tap before N.D.L. 4) Remove grounding &amp; bonding for "DS-C1" &amp; "DS-C2" disconnect switch. 5) Comply sec 230.42(A) vertical bus for SS # 5 undersize. 6) Verify "DP-C1" &amp; "DP-C2" is service switch or not. No more than six SS# is permitted for one service. If it's not service equipment update note on floor plan &amp; remove panic hardware. 7) Verify EM side FA switch size 8) Provide coordination between "2000A" breaker on generator panel &amp; "600 LPN-RK" fuse on downstream "ESB-R" switchboard with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>9) Provide ground fault protection for "DS-C3" not indication 10) Show SEB on floor plan. 11) Show the available fault current at meter boards. 12/5/18 Retyping the comments 1) Sheet 5 of 5 not included in the resubmission- sheet 4 of 4 in original submission which has typo 4000A switch for ss#6 in Section #7 in physical drawings not matching one line. 12/6/18 2) . Item #7 from last revision is not addressed-fix typo of F.A. switch amperage rating. 3) Clarify signage on the electric service room door. 4) Follow recommended settings for short circuit study-provide equipment with adequate AIC rating.</p>				

# ADVISORY BOARD CALENDAR

**February 21, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55174	18A0092	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Comply sec 240.21 (B) (2) Tap conductor undersize for both 900A switch. 3/26/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55076	18A0093	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/9/18 - swap dwg with Rev 1				
55073	18A0094	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55092	18A0095	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55080	18A0096	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**February 21, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55175	18A0099	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide asbestos abatement compliance documents 2) Provide coordination between "1600A KRP-C" fuse &amp; down stream 400A breaker in "MDP" switchboard sign &amp; seal by P.E. 3) Show FP x'mer location on one-line with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/26/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/30/2019 1) Address undersize bus bar in "MDP". 9/17/19 Swap Dwg # D-1801-29867-D Rev 7 and Dwg # D-1801-29867-C Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55255	18A0100	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide asbestos abatement compliance required document 2) Verify room 2 hr fire rated &amp; mechanical ventilation (34-05.6(1)(E)(M). 4/25/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55166	18A0102	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Confirm complying with 760.48 2) Provide full size coordination one line with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/22/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/6/19 Swap Dwg # D-1710-29196-A Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55098	18A0103	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/11/18 Swap dwg #17-2735-Revision 1. 8/21/18 - swap dwg Rev 2</p>				

# ADVISORY BOARD CALENDAR

**February 21, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55116	18A0104	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/11/18 Swap Dwg #17-2735-Revision. 8/21/18 - swap dwg Rev 2				
55085	18A0105	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/14/18 - swap dwg 17-2735 Rev 1 8/21/18 - swap dwg Rev 2				
55095	18A0106	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR-Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/17/18 - swap dwg # 1 Rev 1 8/21/18 - swap dwg Rev 2				
55111	18A0107	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/15/18 Swap dwg #1-Revision 1. 8/21/18 - swap dwg Rev 2				
55077	18A0108	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/17/18 - swap dwg # 1 Rev 1 8/21/18 - swap dwg Rev 2				

# ADVISORY BOARD CALENDAR

**February 21, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55099	18A0109	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/14/18 - swap dwg 1 Rev 1 8/22/18 - swap dwg Rev 2				
55112	18A0110	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/14/18 - swap dwg 1 Rev 1. 9/21/18 Swap dwg #1-Revision 2.				
55179	18A0111	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Comply 230.64(B) and provide 7' (ft) working clearance for SS # 5 3/26/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/14/18 - swap dwg 1 Rev 2. 9/25/18 Swap dwg #1-Revision 3.				
55100	18A0112	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/14/18 Swap dwg 1-Revision 1. 8/14/18 Swap dwg #1-Revision 2. 9/27/18 Swap dwg #1-Revision 3. 12/6/18 Swap Dwg #1-Revision 4. NO MORE SWAPS.				
55113	18A0113	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/14/18 Swap dwg #17-2735-Revision 1. 9/21/18 Swap dwg #1-Revision 2. 12/6/18 Swap dwg #1-Revision 3. NO MORE SWAPS.				



# ADVISORY BOARD CALENDAR

**February 21, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55086	18A0114	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/14/18 Swap dwg #17-2735-Revision 1. 10/10/18 Swap dwg Revision 2				
55101	18A0115	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/17/18 - swap dwg # 1 Rev 1. 9/27/18 Swap dwg #1-Revision 1				
55114	18A0116	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/15/18 Swap dwg 1-Rev 1. 9/21/18 Swap dwg #1-Revision 2.				
55087	18A0117	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/15/18 Swap dwg #1-Revision 1. 8/22/18 - swap dwg Rev 2				
55102	18A0118	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/15/18 Swap dwg #1-Revision 1. 8/3/18 Swap dwg-Revision 2. 9/24/18 Swap dwg #1-Revision 3. No more swaps.				

# ADVISORY BOARD CALENDAR

**February 21, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55115	18A0119	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/15/18 Swap dwg #1-Revision 1. 10/10/18 Swap dwg -Revision 2				
55088	18A0120	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/15/18 Swap dwg #1-Revision 1. 9/24/18 Swap dwg #1-Revision 2				
55183	18A0121	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide 1500 KW generator room layout 2) Show EM side FA switches &amp; x'mer on floor plan with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3/26/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/19/19 Swap A-Revision 1 and Dwg B-Revision 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55293	18A0122	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide fuse coordination bet "2000A KRP-C (SS# A1)" and downstream "1200A KRP-C" fuse sign &amp; sealed by P.E. 2) Comply sec 695.4(B)(3)(4) for FP SS # and maintain 12" separation from FA SS# 3) Update typo for laundry SS # designation on service-B one line and physical views. 4) Confirm NRTL listing for Xfmrs 5) Provide 2nd level in service B for S.SW# B1&amp; B2. 5/18/18. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/21/18 Swap dwgs 1,2, 3,4,5 and Revision 2. 10/16/18 Swap dwgs 1,2,3,4 and 5-Revision 3.</p>				

# ADVISORY BOARD CALENDAR

**February 21, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55327	18A0123	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide 7' clearance for SS # 1 &amp; F.A sw and verify F.A. sw 30A or 60A (fix typo) 2) Verify complying with 230.6 to incoming service cond from S.E.B - encased in concrete 3) Verify supplemental grounding to all remote S.Sws 4) comply with 230.72(A) 5) S.E.B. bus bar &amp; rating are undersized . 5/23/18 - 1) Item # 2 is partially addressed - verify service entrance cond to 400A combo Trans-S is concrete encased. 6/19/18 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/18/19 Swap Dwg # sheet 1 Rev.3, sheet 2 Rev.3, sheet 3 Rev.0 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 9/2/2020 Amended Dwgs # 1, 2, &amp; 3 Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55541	18A0125	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Remove FA-SW 2-E switch 2) Verify that FP1-SW-N is rated for in-rush current and verify type of switch is a fuse and shall be locked in the on position. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.                      The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.                      NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 5/22/18 - 1) Verify 5' clearance for FP1-SW-N &amp; FA-SW-N 8/1/18 - 1) F.P. conductor is undersized - normal side 2) Remove bonding from "FP2-SW-E" 3) Remove secondary disconnecting means of FP2 transformer -Sec 695.5(A)(2). 9/21/18 1) Item #from revision 8/1/18 not addressed -F.P. cond of FP1 Is undersized. 10/26/18 Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55107	18A0126	Special Permission	Approved	\$0.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

# ADVISORY BOARD CALENDAR

**February 21, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55268	18A0127	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide one of required documents for Asbestos abatement compliance or add note to submitted drawing. 2) Drawings are not legible (34-05.c(1)(E)(A) 3) Provide available short ct at fire pump controller. 4) Provide sizes type of C.B in panel SP &amp; HP 5) 2000A KRPC &amp; 600A FRS not coordinated. 6) Confirm 10 feet run of service bus &amp; correct code reference on floor plan. 4/30/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/27/18 1) Provide available s.c. current at 2000A "G.E." busway connected to ss#1 and at "HP" panel. 2) Verify GFP to ss# 2 and 3 -230.95. 10/2/19 Swap dwg #1-Revision 3 and dwg 2-Revision 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55271	18A0128	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Update the asbestos note to match the standard EAB note. 2) Service entrance conductor undersize for SS # 3 3) Provide supplemental connection to FA SS# 3 4) Show available short circuit current at panel HP. 5/3/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/9/2019 Swap Dwg #16346 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55309	18A0129	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide supplemental grounding to F.A. S.SW 2) Confirm 110.26(A)(3) is maintained for PNL"LP" &amp; F.A SW/TRX 5/3/18 - 1) EGC to watermain &amp; supplemental ground for SS# 3 are undersized - sec 250.66 2) Provided TCC doesn't match one line - trip size for SS# 2 is different 5/25/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/9/19 Swap Dwg #16347 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55075	18A0130	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55082	18A0132	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

# ADVISORY BOARD CALENDAR

**February 21, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55068	18A0133	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55211	18A0134	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Verify that 3000A energizing 750 KVA is rated for in rush current 2) Verify that DPH-CP1 SW is equipped with trip unit not just a sensing relay. 3) Provide physical for DPRT-W 3/26/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/1/19 Swap dwgs 1 & 2 rev 2.				
55261	18A0135	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide correct series rated CBK documentations between SS# 4 & MDP with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/2/18 - 1) Provide coordination between SS# 4 & fuse downstream breakers signed and sealed by P.E. 2) Provide revised "MDP" panel cut sheets 4/30/18 Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/18/19 1) Provide signed and sealed coordination study to all fuses. 10/29/19 Swap Dwg # AB-17278-A.3 Rev 3. 3/2/2020 Dwg #A.4-Revision 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55202	18A0139	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Show existing bus bar values in switchboard 4 2) Verify new temp 1600A SW is after 2nd fuse 3) Verify if SWB\$ is a new service or replacing existing. 4) Verify termination box new or existing & show on floor plan. 4/2/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**February 21, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55105	18A0140	Special Permission	Approved	\$0.00
With Stipulation of installing required signage Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	18A0141	Special Permission	Denied	\$350.00
55246	18A0144	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Service bus feeds SS # 1 is undersized. 2) ACP-5 form not attached. 4/24/18 - Job finalized With Stip: to Add a signage on SS# 1 "Fuse not to exceed 1600A" Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55743	18A0147	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Provide asbestos abatement compliance required document "Please refer to April 2017 notice (Control # is required) 1/25/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55103	18A0150	Special Permission	Approved	\$0.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/10/18 - swap the dwg attached to SP dwg# 17-2735 Rev 1				
55210	18A0151	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Verify complying with 700.6(G) 3/30/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.. 6/3/19 Swap dwg 1-Revision 2 9/20/19 Swap Dwg 1 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				

# ADVISORY BOARD CALENDAR

**February 21, 2018**

Approval #	Submission #	Type of Request	Status	Fee
	18A0152	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
OR - Not a 1000 KVA job.				
55165	18A0154	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Show grounding to existing SS # 3 & F.P.S.W and verify supplemental grounding. 2) Asbestos abatement compliance required. 3) Verify available S.C. current at "MDB" is less than 65K AIC 3/22/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55178	18A0155	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide 5' clearance in front of F.A. S.S.W (slide sw to clear col.) 2) Verify EM panel rating. 3/26/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55263	18A0156	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Verify that there are no splices in the 90° corner bus section. 2) Provide asbestos abatement compliance required documents. 4/26/18 - job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55267	18A0157	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide asbestos abatement compliance required document signed and sealed with control # 2) Verify that FA S.sw not in front of S.sw # 1 4/3/18 - verify 5' clearance for F.A. S.S.W. 5/1/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55358	18A0158	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
OR - 1) Asbestos abatement compliance required. 3/26/18 - 1) Service cond feeds existing 4000A SS# 2 undersized. 7/3/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**February 21, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55096	18A0159	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide asbestos abatement compliance document ACP-5 2/26/18 - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/19/18 Swap dwg-Revision 1.				
55156	18A0160	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Show all new work with cloud on the one-line 2) Supplemental ground conductor undersize for FP SS # 5 3) Verify FP & JP load side conductor is new or existing. If JP tap is new comply 430.28 for tap rule. 4) Show main bus size for new service switchboard and vertical bus size for SS # 3 5) Section bus for SS # 1 & 2 is undersize. 6) comply sec 408.60(A) 7 provide N.D.L for SS# 2 3/12/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/8/19 Swap dwg #1-Revision 2				
55065	18A0162	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55067	18A0163	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55083	18A0164	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/21/18 Swap Dwg #ACS-D-13121-Revision.				



# ADVISORY BOARD CALENDAR

**February 21, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55249	18A0165	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Asbestos compliance document required. 2) Provide coordination between 1200A C.B &amp; down stream breakers. 3) Verify compliance with 695.6(B)(1) with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/24/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55069	18A0166	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/28/18 Swap drawing with Rev. 1. 5/3/18 - swap dwg 1 Rev 2</p>				
55078	18A0167	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/18/19 Swap dwg-Revision 1</p>				
55162	18A0168	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide Co-Gen cut sheet 3/20/18 - Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/6/18 Swap dwgs 1 and 2-Revision 1</p>				

# ADVISORY BOARD CALENDAR

**February 21, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55328	18A0170	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide 4000AMP SW physical &amp; details 2) Show size and type of GEN set connection to 4000A SW 3) Show detail of load bank, F.A switches and locations. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/4/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/25/18 1) Comply with 408.60(E)(2)-Dwg. #3. 10/26/18 Swap Dwg #1,2,3 and 4-Revision 3</p>				
55513	18A0171	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide asbestos abatement compliance documents 2) Comply sec 230.42(A) service entrance conductor undersize. 3) Comply sec 230.42(A) main bus undersize for service switchboard. 4) Section bus for SS # 1,2, &amp; 3 is undersize 5) Provide fuse coordination between "SS# 5 900A KRP-C" &amp; downstream "400A FRN" fuse. 6) Show emergency side FA fuse or breaker type &amp; confirm generator is separately derived or not 7) Verify door swing for life safety closet. 9/26/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55161	18A0172	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR - 1) 400 A2D fuse does not coordinate with upstream fuse. 3/20/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55071	18A0173	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
55062	18A0174	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

# ADVISORY BOARD CALENDAR

**February 21, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55084	18A0175	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55251	18A0176	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Verify supplemental ground 2) Provide asbestos abatement compliance required document. 4/24/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55079	18A0177	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Hurricane Sandy Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	18A0178	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
OR - 1) Asbestos abatement compliance document.				
55070	18A0179	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55063	18A0180	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/19/18 Swap Dwg 1-Revision 1.				

# ADVISORY BOARD CALENDAR

**February 21, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55072	18A0181	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/4/18 Swap drawing 1, Revision 1.				
55173	18A0182	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Verify size of lab bus duct 4000A on line side of ATS # 93 2) Explain how MRF SWGR will be accessed for maintenance and there would be no maintenance on the bus joints during the life of EQ 3/22/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55213	18A0185	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Provide asbestos abatement compliance documents 2) Update typo in special permission note for "Meeting of Oct 18, 2017" 4/4/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55200	18A0186	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Update fuse & breakers type in main service switchboard A to match short circuit study mainline. 3/30/18 - Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/11/19 Swap Dwg A Rev 2. 8/13/19 1) Add conductors and bus-bars layer to the plans (it's missing). 2) Clearly label and note the changes for this swap. 8/23/19 Swap Dwg #A121601 Rev.3 and Dwg#A121602 Rev.1 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55212	18A0187	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Asbestos abatement document required 2) Verify splicing inside service switchboard 3) Confirm fuse protection for voltage tap to beck with relay 3/22/18 - 1) Verify complying with 312.8 4/4/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/6/18 Swap dwg #A011807-Revision 1. 1/23/19 Swap dwg 06 rev3				

# ADVISORY BOARD CALENDAR

**February 21, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55104	18A0190	Special Permission	Approved	\$0.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55106	18a0192	Special Permission	Approved	\$0.00
With stipulation that the installation and inspection shall be in accordance with 2014 NEC. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	18A0193	Requested approval for the electric service equipment proposed to be installed	Rejected	\$650.00
OR - 1) Asbestos abatement compliance required 2) Show cond. size from cell dist. system. 3/20/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/1/18 - cond. Connected to new 800A sw is undersized				
55176	18A0194	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) License # is missing in cover letter. 2) Provide asbestos abatement compliance document .3) Show conductor size from fuel cell distribution system. 3/26/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	18A0195	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
1) Provide asbestos abatement compliance documents 2) verify water main & supplemental ground connection to service switchboard.				
55205	18A0197	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide asbestos abatement compliance document ACP-5 3/23/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**February 21, 2018**

Approval #	Submission #	Type of Request	Status	Fee
	18A0198	Special Permission	Denied	\$0.00
55066	18A0208	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/27/18 Swap dwg #ME114-Revision 1.				
55094	18A0210	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				