

# ADVISORY BOARD CALENDAR

**February 29, 2020**

Approval #	Submission #	Type of Request	Status	Fee
BK00187A	BK00187	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
2/27/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
BK00207A	BK00207	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
3/12/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
BK00302A2	BK00302	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
3/9/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 7/24/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 1/12/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
BK00306A	BK00306	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
3/3/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
BK00324A	BK00324	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
3/12/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
BK00329A1	BK00329	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
3/10/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 11/29/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				

# ADVISORY BOARD CALENDAR

**February 29, 2020**

Approval #	Submission #	Type of Request	Status	Fee
BK00348A1	BK00348	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
3/9/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 9/20/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
BK00371A2	BK00371	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
3/17/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 11/4/2020 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 1/5/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
BX00092A1	BX00092	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
3/9/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 6/16/2021 Job finalized. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
BX00206A1	BX00206	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
4/22/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
BX00259A1	BX00259	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
3/6/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 8/5/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				

# ADVISORY BOARD CALENDAR

**February 29, 2020**

Approval #	Submission #	Type of Request	Status	Fee
BX00303A1	BX00303	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
2/25/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 1/14/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 3/11/2021 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
BX00310A2	BX00310	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
2/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 12/14/2020 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 12/1/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
BX00349A	BX00349	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
2/28/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00086A	MN00086	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>3/6/2020 1. The engineering single line plan shall be submitted based on new NYC § 4000-01 <a href="https://www1.nyc.gov/assets/buildings/rules/1_RCNY_4000-01.pdf">https://www1.nyc.gov/assets/buildings/rules/1_RCNY_4000-01.pdf</a>:                      The §4000-01 Rule includes but not limited to the following:</p> <ol style="list-style-type: none"> <li>a. Provide available Short circuit current (on the plans) at the POE - Confirm that all new equipment is adequately rated for the maximum available calculated fault current.</li> <li>2. Provide asbestos abatement compliance document; ACP5 or ACP21 includes area of the new work.</li> <li>3. Confirm compliance with 215.10- Provide GFP to 2500A switch at 480 Volt.</li> <li>4. Comply with 110.26(C) (3) - door to open outwards in service electrical room "BOBST T-9"</li> <li>5. Substations "SS-WSV-1/2" &amp; "SS-WSV-3/4" amperage rating is undersized.. 8/17/2020 1. Substations "SS-WSV-1/2" &amp; "SS-WSV-3/4" amperage rating still undersized- load calculation signed and sealed by P.E. shall be submitted.</li> <li>2. Confirm grounding and bonding of all transformers. 9/28/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work</li> </ol>				

# ADVISORY BOARD CALENDAR

**February 29, 2020**

Approval #	Submission #	Type of Request	Status	Fee
MN00088A1	MN00088	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
3/10/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00186A1	MN00186	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
3/23/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00189A1	MN00189	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
6/22/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00190A	MN00190	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
2/18/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00255A1	MN00255	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
3/16/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00262A	MN00262	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
2/19/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				

# ADVISORY BOARD CALENDAR

**February 29, 2020**

Approval #	Submission #	Type of Request	Status	Fee
	MN00287	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>12/23/2020 1. Conductors off 1200A SSW#1 are undersized.                      2. Comply with 240.21B- tap conductors are undersized                      3. Provide Asbestos abatement required document includes the area of new work (ACP#5 or ACP21).</p>				
MN00300A1	MN00300	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>3/9/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 1/13/2022 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
MN00320A1	MN00320	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>4/1/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
MN00323A1	MN00323	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>3/5/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.</p>				
	MN00335	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
<p>3/3/2020 1. Confirm compliance with 110.26C (2) (b) - provide Panic hard ware to electrical room door.                      2. Conductors feed the 1600A Circuit breakers in SWGR6001 are undersized.                      3. Provide the ampacity of the medium voltage cable off 125A fuse.                      4. Comply with 430.22 – conductor feeds the 300HP motors is undersized.                      5. Confirm 2 HR fire rated construction and room Ventilation to electrical room.                      6. Combine all plans in one.                      7. Clearly show the number of sets and the size of all cables.</p>				

# ADVISORY BOARD CALENDAR

**February 29, 2020**

Approval #	Submission #	Type of Request	Status	Fee
	MN00335	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
4/13/2020 1. Provide service room lay out and confirm compliance with 110.26C (2) (b) - provide Panic hard ware to electrical room door. 2. Conductors feed the 1600A Circuit breakers in SWGR6001 are undersized. 3. Confirm compliance with 240.100( C) 4. Clearly show the number of sets and the size of all cables.				
MN00342A	MN00342	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
3/2/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00372A1	MN00372	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
3/30/2020Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
MN00373A	MN00373	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
3/20/;2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work				
QN00226A	QN00226	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
3/3/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
QN00235A1	QN00235	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
4/1/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				

# ADVISORY BOARD CALENDAR

February 29, 2020

Approval #	Submission #	Type of Request	Status	Fee
QN00266A	QN00266A	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
2/18/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work				
QN00335	QN00335	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
5/12/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
QN00343A	QN00343	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
3/9/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
QN00347A	QN00347	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
3/11/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				
SI00374A1	SI00374	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
6/12/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work.				