

# ADVISORY BOARD CALENDAR

**March 9, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53577	15A0518CO	Robert S. Covello Electric 51-20 35th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	400 Lafayette Street New York NY	Approved	\$0.00
Carry over from August 12, 2015 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
	15A0588CO2	E-J Electric Installation co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	63 Flushing Avenue, Bldg #77 Brooklyn NY	On Hold	\$0.00
Carry over from January 13, 2016 meeting. 1) Show paralleling bus sizes.. 2) Provide coordination study addressing items discussed at meeting.						
53586	15A0651CO	Gilston Electrical Contracting Corporation 338 East 95th Street New York NY 10128	Requested approval for the electric service equipment proposed to be installed	NYU MSB Infrastructure Proj. 435 East 30th Street New York NY	Approved	\$0.00
Carry over from October 21, 2015 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	15A0774CO	Reliable Electrical Contractors 41 Clinton Avenue Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	3 Mitchell Place New York NY	Denied	\$0.00
Carry over from November 18, 2015 meeting. 1) 1000 KVA installation to comply with Section 230.64(B)(1) through (5). 2) show clearances in service room to comply with 230.64(B) and 110.26(A)(3). 3) Service room door to open outwards.						
53601	15A0842CO	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	104 Broad Street New York NY	Approved	\$0.00
Carry over from December 16, 2015 meeting. 1)Load bank breaker bay to be listed. 2) Load bank breaker bay to be provided with main 25' tap. 3/17/16 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/17/16 Job finalized Ok, with the stipulation that the bus supplying the 4000 amp circuit breaker in the breaker bay switchboard is field evaluated by a NRTL and the NRTL approval and testing report is available at inspection .Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

# ADVISORY BOARD CALENDAR

**March 9, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0020	Jemco Electrical Contractors, Inc. 271 42nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Woodhull Medical Center 760 Broadway Brooklyn NY	On Hold	\$650.00
<p>1. ATS &amp; feeders not protected, normal &amp; emergency sides. 2. Service switches over fused. 3. Put bus duct manufacture's bud density notes on 1 line for 200k series rating. 4. Show short circuit current at switchboards and all other equipment up to 3rd level. 5. Designer to appear at meeting when revised drawings are submitted. *If 1000 KVA temporary switch boards will be used a submittal is required</p>						
	16A0025CO	DeFalco Electric 25-54 22nd Street Astoria NY 11102	Requested approval for the electric service equipment proposed to be installed	111 West 57th Street New York NY	Denied	\$0.00
<p>Carry over from January 13, 2016 meeting. 1) Provide physical for substations 1 and 2. 2) Secondaries of transformers not bonded and grounded. 2) Coordination study not provided. 3) Is fire pump #4, explain GFS (typo) in service switch. 4) Fire pump service entrance conductors and feeders to fire pump transformers are undersized. 5) Provide barriers behind 120/208 switchboards. 6) Clearance behind medium voltage switchgears to comply with Table 110.34. 7) Verify that 750 KVA transformer connections are on the left side of the transformer on room layout. 8) Explain what 2" EPR is.</p>						
53575	16A0043	All Bright Electric 8 Johnson Street Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	Watermark 27-10 44th Drive Queens NY	Approved	\$650.00
<p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>						
53558	16A0056	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	33 Maiden Lane New York NY	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/22/16 Swapped Drawing A-Revision. No more as built.</p>						

# ADVISORY BOARD CALENDAR

**March 9, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53557	16A0057	Kleinknect Electric Company, Inc. 252 West 37th Street, Suite 1402 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	452 5th Avenue, 8-10th Fls New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0066CO	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	33 Bond Street Brooklyn NY	On Hold	\$0.00
Full detailed reduced neutral and voltage calculations not provided from Con Ed box to last panelboard, 4% to last distribution board and 1% to last branch circuit panel.						
53819	16A0075	Sopot Electric Corp. 115 Dobbin Street Booklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	22 East 14th Street New York NY	Approved	\$650.00
1) Provide manufacturer's cut sheet of new 800 amp panel. 2) show wiring method from 800 amp service switch to new panel. 3) Show fuse type in 800 amp switch. 5/16/16 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/1/16 Swapped drawing1-Revision 2.						
53579	16A0116	Arcadia Electrical Co., Inc. 1005 Wyckoff Avenue Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	150-15 Raleigh Street Queens NY	Approved	\$650.00
with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

# ADVISORY BOARD CALENDAR

**March 9, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53823	16A0125	Lippolis Electric, Inc. 3396 East Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	688 Broadway New York NY	Approved	\$650.00
<p>1) Rear of switchboard to comply with 230.64(B)(4). 2) Where is the service entrance box located in relation with the service room? 3) Only first and second fusing to be shown on drawing, put a note under the generator indicating whether 3 or 4 pole ATS' will be installed. 4) Feeders undersized to and from 800 amp emergency with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 5/17/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
	16A0130	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	787 11th Avenue New York NY	Pending	\$650.00
<p>OR Drawing not complete, length of tapped conductor not shown and undersized. With the stipulation: Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> <li>1. A P.E. or R.A. must file a PWI as an AIT 3.</li> <li>2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.</li> <li>3. The fire proofing must be performed by a certified fire proofing installer.</li> </ol>						
53576	16A0144	Robert B. Samuels Inc. 253 West 35th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	50 West 57th Street New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						

# ADVISORY BOARD CALENDAR

**March 9, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53939	16A0157	Genmar Electrical Contracting Corp. 98-19 103rd Avenue Ozone Park NY 11417	Requested approval for the electric service equipment proposed to be installed	4813 Ninth Avenue Brooklyn NY	Approved	\$650.00
<p>1) Verify oversized bus bars in switchboards. 2) Emergency side equipment grounding conductor to 100 amp disconnect switch is undersized. 3) Verify that neutral conductor in generator is bonded to the enclosure. 4) Provide short circuit curves generator circuit breaker to distribution panel with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/27/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53582	16A0168	Didonato and Sons Electrical Corp. 85 Industrial Loop Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	2361 Nostrand Avenue Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53591	16A0173	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	NYU School of Medicine 550 First Avenue New York NY	Approved	\$650.00
<p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53580	16A0175	Innovative Electrical Services 3346 Provost Avenue Bronx NY 10475	Requested approval for the electric service equipment proposed to be installed	55 East 59th Street New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

# ADVISORY BOARD CALENDAR

**March 9, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53581	16A0177	Delco Electrical Corp. 241 West 37th Street, Suite 700 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	200 East 59th Street New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0181	Pinnacle Electric 130-45 91st Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	210 Livingston Street Brooklyn NY	On Hold	\$650.00
1) Short circuit study not provided, signed, sealed, by a PE. 2) Section #12 section bus undersized. 3) Equipment grounding conductors undersized.						
53583	16A0183	A Tech Electrical Enterprise, Inc. 30-40 48th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	P.S. 316 90-01 101st Avenue Queens NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0184	Patriot Electric Corp. 58-71 57th Road Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	Roosevelt Surgery Center 619 West 54th Street New York NY	On Hold	\$650.00
<p>Coordination study indicates that OCPD not coordinated with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>						
53584	16A0188	M.R. Electrical Service LLC 204 Walworth Street Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	755 Kent Avenue Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

# ADVISORY BOARD CALENDAR

**March 9, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53585	16A0189	M.R. Electrical Service LLC 204 Walworth Street Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	44-41 Purves Street Queens NY	Approved	\$650.00
<p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53828	16A0190	CSA Engineering Services, LLC 15 Trowbridge Drive Bethel CT 06801	Requested approval for the electric service equipment proposed to be installed	200 Central Park South New York NY	Approved	\$650.00
<p>1) Length of taps not shown. 2) Equipment grounding conductors undersized. 3) Verify that the Bollards don't interfere with transformer access. 5/20/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>						
53571	16A0191	Net Power Electric Corp. 1568 62nd Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	4515 New Utrecht Avenue Brooklyn NY	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>						
	16A0192	Twig Consulting Engineers, P.C. 7 Penn Plaza, Suite New York NY 10001	Requested approval for the electric service equipment proposed to be installed	135-137 Spring Street New York NY	Denied	\$650.00
<p>1) Drawing not in Advisory Board format. 2) Drawings too small to read. 3) 1 Line does not match room layout 600 amp service switch not shown in service room. 4) 600 amp fuses to coordinate with 300 amp fuses fuse types not shown. 5) Bonding and grounding of existing service equipment not shown on 1 Line.</p>						

# ADVISORY BOARD CALENDAR

**March 9, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53919	16A0193	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	370 Jay Street Brooklyn NY	Approved	\$650.00

1) Emergency "EMSWB" section bus undersized middle section. 2) Address ATS:-LS#5 in short circuit study. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.

The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.

NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.

With the stipulation:

Fire Rated Enclosure's must comply with the following:

1. A P.E. or R.A. must file a PWI as an AIT 3.
2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.
3. The fire proofing must be performed by a certified fire proofing installer.. Note: Look ate the generator damage curve. 6/20/16 Job finalized. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.

The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.

NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.

With the stipulation:

Fire Rated Enclosure's must comply with the following:

1. A P.E. or R.A. must file a PWI as an AIT 3.
2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.
3. The fire proofing must be performed by a certified fire proofing installer. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/3/16 Swapped drawing 3-Revision . This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.

The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.

NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.

With the stipulation:

Wednesday, November 30, 2016

# ADVISORY BOARD CALENDAR

**March 9, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
<p>Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> <li>1. A P.E. or R.A. must file a PWI as an AIT 3.</li> <li>2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.</li> <li>3. The fire proofing must be performed by a certified fire proofing installer.</li> </ol>						
53587	16A0194	Lizardos Engineering Associates, P.C. 200 Old Country Road Mineola NY 11501	Requested approval for the electric service equipment proposed to be installed	14 Washington Place New York NY	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53560	16A0195	Net Power Electric Corp. 1568 62nd Street Brooklyn NY 11219	Requested approval for the electric service equipment proposed to be installed	191 Bradley Avenue Staten Island NY	Approved	\$650.00
<p>OR This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>						
53559	16A0197	M.F. Electric Service Co., Inc. 3323 Merritt Avenue Bronx NY 10475	Requested approval for the electric service equipment proposed to be installed	459 East 149th Street Bronx NY	Approved	\$650.00
<p>OR With the stipulation the new 600 amp disconnect switch complies with 110.26 (A)(3). Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>						
53825	16A0199	H Electric Corp. d/b/a Mage Electrical Co. 156 Flushing Avenue Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	364 6th Avenue New York NY	Approved	\$650.00
<p>1., TAP conductor #2. 500 KCM. 5/18/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements</p>						

# ADVISORY BOARD CALENDAR

**March 9, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53818	16A0200	alvatore Campisi & Sons Electl Contrs, Inc 1831 Decatur Street Ridgewood NY 11385	Requested approval for the electric service equipment proposed to be installed	45 West 27th Street New York NY	Approved	\$650.00
1. Provide barrier behind switchboard. 5/16/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/28/16 Swapped drawings 1 and 2-Revision 2.						
	16A0201	Folks Electrical Inc. 670 Broadway New York NY 10012	Requested approval for the electric service equipment proposed to be installed	257 West 39th Street New York NY	On Hold	\$650.00
1) Scope of new work not clear on drawings, new 3000 amp service switch #2 and distribution board not shown on 1 line. 2) All new work to be bubbled. 3) Notes cut off of drawing.						
53562	16A0202	Mac Electrical Contracting Inc. 2807 Flatbush Avenue Brooklyn NY 11234	Requested approval for the electric service equipment proposed to be installed	318 West 52nd Street New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53588	16A0203	H & L Electric, Inc. 41-11 28th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	37 West 28th Street New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/2/16 Swapped drawing A and B-Revision 1.						
53589	16A0205	Campisano Electric, Inc. 355 Food Center Drive Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	Baldor 155 Food Center Drive Bronx NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

# ADVISORY BOARD CALENDAR

**March 9, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53578	16A0206	Bigman Brothers, Inc. 43-40 34th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	882 Third Avenue Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53608	16A0207	Anthony G. Ferry, Inc. 1916 Park Avenue, Suite 520 New York 1 10037	Requested approval for the electric service equipment proposed to be installed	2040 Frederick Douglass Blvd. New York NY	Approved	\$650.00
1) Show short circuit current at circuit breaker panel PP-6, PP-CR, NB-1 and NB-2. 2) Provide cut sheets for circuit breakers or provide coordination study.. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
53826	16A0208	Patriot Electric Corp. 58-71 57th Road Maspeth NY 11378	Requested approval for the electric service equipment proposed to be installed	Vernon Towers 31-43 Vernon Blvd. Queens NY	Approved	\$650.00
Manufacturer's cut sheet of serve equipment does not match bus on 1 Line. 5/18/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0209	Hellman Electric Corporation 855 Brush Avenue Bronx NY 10465	Requested approval for the electric service equipment proposed to be installed	1024-1036 White Plains Road Bronx NY	Pending	\$650.00
1) Grounded conductor to be brought to fire pump service switch. 2) fire pump verify Vita Link cable installed in conduit. 3) Verify that ATS' EDP "C-EM-1" and C-STS-1 normal sides are 3rd fused. 4) Fire pump switch provide physical with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.						
	16A0211	Hellman Electric Corporation 855 Brush Avenue Bronx NY 10465	Requested approval for the electric service equipment proposed to be installed	50-51 98th Street Queens NY	Pending	\$650.00
1 Line does not match physical and room layout of service equipment (1 Line is in reverse).						

# ADVISORY BOARD CALENDAR

**March 9, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53592	16A0214	Reliant Electrical Contracting, Inc. 628 Classon Avenue Brooklyn NY 11238	Requested approval for the electric service equipment proposed to be installed	265 Worthman Avenue, Bldg. D Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53593	16A0215	Nova Star Electric Inc. 28-10 38th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	38-11 31st Street Long Island City NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53573	16A0218	T. McCaffrey-T. McGovern Electrical Inc. 27 East 233rd Street Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	1045 Park Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53568	16A0219	OM Electric, Inc. 262 West 38th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	189 Berry Street Brooklyn NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53565	16A0220	Linhill Electrical Contractors, Inc. 97-07 Horace Harding Expressway Corona NY 11368	Requested approval for the electric service equipment proposed to be installed	126-06 Queens Blvd. Queens NY	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						

# ADVISORY BOARD CALENDAR

**March 9, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53566	16A0221	Linphill Electrical Contractors, Inc. 97-07 Horace Harding Expressway Corona NY 11368	Requested approval for the electric service equipment proposed to be installed	1395 Lexington Avenue New York NY	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53567	16A0222	Bass Electrical Corp. 10-17 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	120 Jewell Street Brooklyn NY	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53922	16A0223	Bayside Electrical Contr. Corp. 40-18 31st Avenue Astoria NY 11103	Requested approval for the electric service equipment proposed to be installed	70 West 139th Street New York NY	Approved	\$650.00
1. Will a new generator be installed? If so, indicate on drawing. Fire Alarm, indicate if it will be a separately derived system and show types of ATS. 6/21/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53594	16A0224	Response Electric Inc. 680 Lorimer Street Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	210 Central Park Avenue South New York NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/28/16 Swapped drawing 1-Revision 1.						
53572	16A0225	Chaim Electric 2920 Avenue J Brooklyn NY 11210	Requested approval for the electric service equipment proposed to be installed	411 West 35th Street New York NY	Approved	\$650.00
OR With the stipulation that the rear of the switchboard is blocked off. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 6/15/16 Swapped drawings 1,2,3-Revision 1.						

# ADVISORY BOARD CALENDAR

**March 9, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53610	16A0226	Cogen Electrical Services Inc. 528 Craven Street Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	27 East 62nd Street New York NY	Approved	\$650.00

This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.

The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.

NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.

With the stipulation:

Fire Rated Enclosure's must comply with the following:

1. A P.E. or R.A. must file a PWI as an AIT 3.
  2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation.
- The fire proofing must be performed by a certified fire proofing installer.

\* Note: UL 2200 is for the engine only. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements

53570	16A0227	M.O.S. Electrical Contracting Corp. 4340B Katonah Avenue Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	29-35 9th Avenue New York NY	Approved	\$650.00
-------	---------	-------------------------------------------------------------------------------	--------------------------------------------------------------------------------	---------------------------------	----------	----------

OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements

53569	16A0228	PM Electrical Maintenance 90 Verdi Street Farmingdale NY 11735	Requested approval for the electric service equipment proposed to be installed	136-35 37th Avenue Flushing NY	Approved	\$650.00
-------	---------	----------------------------------------------------------------------	--------------------------------------------------------------------------------	-----------------------------------	----------	----------

OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements

# ADVISORY BOARD CALENDAR

**March 9, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53564	16A0229	Royal Electrical and Wiring Corp, 2558 Marion Avenue Bronx NY 10458	Requested approval for the electric service equipment proposed to be installed	385 First Avenue New York NY	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53595	16A0230	A & R Electrical Maintenance, Inc. 85-47 Grand Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	828 East 149th Street Bronx NY	Approved	\$650.00
This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53561	16A0231	Allran Electric of NY 120 Broadway, 36th Floor New York NY 10271	Requested approval for the electric service equipment proposed to be installed	285 Madison Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53920	16A0233	I.K.E. Electrical Corp. 601 West 26th Street, Suite 2M New York NY 10001	Requested approval for the electric service equipment proposed to be installed	93 Worth Street New York NY	Approved	\$650.00
Bond neutral to enclosure in 1600 amp service switch and install neutral link. 6/20/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
	16A0234	Centrifugal Electric, LLC 7 West 36th Street, 6th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	310 West 40th Street New York NY	Denied	\$650.00
1) Where is the service end box located in relation to service room, what floor is the service room located on 16 sets of SEC's. 2) Emergency side fire alarm disconnect switch bonded and grounded on non separately derived system. 3) Transformer secondary's not bonded and grounded. 4) Equipment grounding conductor undersized load side of 1600 amp switch. 5) "MDP" explain feeders in twin panel "by others". 6) Fire pump emergency feeder not fire rated. 7) Where is the fire pump transformer located? 8 Manufacturer's cut sheet of equipment not provided. 9) Fire alarm ATS to be 4-poles. 10) SS 3000A and 1600A to have 5' clearance. 11) 1 Line does not match room layout or physical. 12) Verify 12" separation for fire pump service switch.						

# ADVISORY BOARD CALENDAR

**March 9, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
	16A0235	Glo Electric LLC 441 Wild Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	1524-1544 Boone Avenue Bronx NY		\$650.00
Not Reviewed						
53596	16A0236	ECS Electrical Contracting Services, Inc. 435 Austin Place Bronx NY 10455	Requested approval for the electric service equipment proposed to be installed	109 South 5th Street Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53590	16A0237	John Michael Electrical Contracting Corp. 1067 Post Avenue Staten Island NY 10309	Requested approval for the electric service equipment proposed to be installed	360 Neptune Avenue Brooklyn NY	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53563	16A0238	Wise Electric Services 307 West 38th Street, Suite 1501 New York NY 10018	Requested approval for the electric service equipment proposed to be installed	148 Madison Avenue New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/30/16 Swapped drawing 1-Revision 2.						
	16A0239	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	Brooklyn Navy Yard 63 Flushing Avenue, Bldg, 293 Brooklyn NY	Denied	\$650.00
1) 1-Line drawing not in Advisory board format. 2) Provide cut sheets of 1000 volt PV equipment showing their listing. 3) Service room layout does not show clearances.						

# ADVISORY BOARD CALENDAR

**March 9, 2016**

Approval #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
53820	16A0240	Roma Electric Corp. 30-75 14th Street Astoria NY 11102	Requested approval for the electric service equipment proposed to be installed	524 East 14th Street New York NY	Approved	\$650.00
1. BUS feeding service switch #2 undersized..5/16/16 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.5/16/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.						
53650	16A0241	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	2800 West 5th Street Brooklyn NY	Approved	\$650.00
1) Drawings not in Advisory Board format. 2) Scope of work not clear. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						
	16A0242	Ark Systems Electric Corp, 27-08 42nd Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	CCNY Marshak Hall 181 Convent Avenue New York NY	Denied	\$650.00
1. 1 line does not match room layout, 1 line shows 3 service switches and room layout shows 5 services switches. 2. Clarify scope of work. 3. Add note to drawing on what will be installed. Drawings are very confusing to follow.						
	16A0243	Goldman Copeland Consulting Engineers 229 West 36th Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	55 Fifth Avenue New York NY	Denied	\$650.00
1) Water damaged electrical equipment to be replaced or 2) Water damaged electrical equipment to be recommissioned by the original manufacturer of the electrical equipment, or 3) Water damaged electrical equipment to be tested and evaluated by a NETA certified testing agency witnessed by a PE and the NETA report to be signed and sealed by the PE along with a letter from the PE that the PE witnessed all testing.						
53574	16A0251	Gilston Electrical Contracting Corp. 336 East 95th Street New York NY 10128	Requested approval for the electric service equipment proposed to be installed	40 Irving Place New York NY	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements						