

ADVISORY BOARD CALENDAR

March 10, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50203CO3	10A0245CO3	I.K.E. Electrical Corp. 601 West 26th Street, Suite 7M New York NY 10001	Requested approval for the electric service equipment proposed to be installed	11 Fifth Avenue New York NY	Hold	\$0.00
Carry over from February 18, 2011 meeting. Engineer to appear						
50242CO2	10A0280CO2	B & G Electl Contrs of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Lehman College 2990 Goulden Avenue Bronx NY	Approved	\$0.00
Carry over from February 18, 2011 meeting. 1) 2500 amp feeder not GFP protected 2) Where is sprinkler buster pump located? 3)Sprinkler pump tapped from same cubicle that contains OCPD. 4) 1-Line does not match room layout. Job finalized 12/7/11.						
50345CO	10A0366CO	T & R Alarm and Electrical Systems, Inc. 4175 Park Avenue Bronx NY 10457	Requested approval for the electric service equipment proposed to be installed	Lehman College 250 Bedford Park Blvd. West Bronx NY	Hold	\$0.00
Carry over from October 13, 2010 meeting. 3' clearance required around corner of switchboard.						
50382CO3	10A0400CO3	Jordan Daniels Electrical Contractors, Inc. 151 West 25th Street, 7th Floor New York NY 10001	Requested approval for the electric service equipment proposed to be installed	Sprint 60 Hudson Street New York NY	Hold	\$0.00
Carry over from February 18, 2011 meeting. 1) Engineer to appear. 2) GFP in gen.breakers will mis-operatedue to neutral ground in paralleling switchboard.. 3) What is manual operation? 4) Gen# designations inconsistent 1-Line and key Intlk instructions.						
50407CO2	10A0425CO2	Sajiun Electric Inc. 105 West 27th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	18 Richmond Terrace Staten Island NY	Hold	\$0.00
Carry over from February 18, 2011 meeting.						

ADVISORY BOARD CALENDAR

March 10, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50415CO3	10A0433CO3	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Mt. Sinai Ctr for Science and Med 1470 Madison Avenue New York NY	Approved	\$0.00
Carry over from February 18, 2011 meeting.						
50565CO		E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requesting permission for a variance from the requirements of the NYC Electrical Code Amendment Section 408.51, (c), (2). This code section creates a hardship because the GE Switchgear is not Density rated under UL 1558 testing procedures but carries a continuous 5000Amp heat rise rating[Data previously submitted]. By accepting the request to use the breaker trip rating, under Article 240.6, (c), (1), which can allow the ampere rating of the breaker frame to equal the adjusted current setting, than the proposed equipment would meet the condition of 408.51, (c), (1) where bus bars shall be sized at 800Amps per square inch. The current density of the proposed Switchgear with the breaker's Long Item Pick-up Setting, at 4750Amps is 791.66 Amps per square inch, based on 6 Sq. Inches of Bus [2-8x3/8]. The Pickup setting will be secured, on the frame itself, with a tamperproof guard and a seal over the adjusting means with appropriate nameplate designations.	Mt. Sinai School of Medicine 101st Street and Madison Avenue New York NY	Approved	\$0.00
Carry over from February 18, 2011 meeting.						
50568	11A0075	Allstate Electric Corp. 555 Eighth Avenue New York NY 10018	Requested approval for the electric service equipment proposed to be installed	600 Third Avenue New York NY	Approved	\$650.00
1) Equipment grounding conductors undersized. 2) Provide GFP on new 1200A SWS. Job finalized 4/19/11.						

ADVISORY BOARD CALENDAR

March 10, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50569	11/A0076	Genmar Electrical Contracting Corp. 98-19 103rd Avenue Ozone Park NY 11417	Requested approval for the electric service equipment proposed to be installed	130 Court Street Brooklyn NY	Approved	\$650.00
Neutral bonded after disconnect link. Job finalized 4/19/11.						
50570	11A0077	Justan Electrical Contracting Inc. 148 Bowery New York NY 10013	Requested approval for the electric service equipment proposed to be installed	CP Radiology 155 Canal Street New York NY	Approved	\$650.00
Title block to have contractors name in it.(All drawings). Job finalized 4/19/11.						
50571	11A0078	Fred Geller Electrical, Inc. 54-15 38th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	St. Mary's Hospital for Children 29-01 216th Street Bayside NY	Hold	\$650.00
1) Service room to be mechanically ventilated. 2) Secondary of transformer not bonded and grounded. 3) Section bus sizes not shown. 4) Service switches not bonded and grounded. 5) 240 volt equipment used for 277-480 volt service. 6) Equipment grounding conductors undersized. 7) Conductor sizes raceways not shown. 9) Cannot tap jockey pump in F.P. controller.						
50572	11A0079	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Jamaica Water Pollution Control 150-20 134th Street Queens NY	Hold	\$650.00
1) Bus not properly identified. 2) Drawings indicate page 1 of 8 and submittal does not have all drawings. 3) Designer to appear to explain job. 4) Provide section views and busway details. 5) Show dims on floor plan and doors. 6) Floor plan shows transformers remote 1-Line shows close-coupled. 7) Identify notes on short circuit study results. Some equipment note as "inadequate".						
50573	11A0080	Team Electric, Inc. 20 West 36th Street, 10th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	284 Livingston Street Brooklyn NY	Hold	\$650.00
1) Drawings not submitted in Advisory Board format. 2) Is this an 1000 KVA service?						

ADVISORY BOARD CALENDAR

March 10, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50574	11A0081	Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Manhattanville Slurry Plant Serv 637 West 125th Street New York NY	Approved	\$650.00
50575	11A0082	Nunez Electric, Inc. 32-14 Greenpoint Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	26 Broadway New York NY	Approved	\$650.00
50576	11A0083	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	P.S. 160K Annex 1057 52nd Street Brooklyn NY	Approved	\$650.00
Change 800 fu to 1200A in service switch #4. Job finalized 3/29/11.						
50577	11A0084	H.P. Electrical Designs Inc. 321 West 44th Street, Suite 405 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	Fordham Law School 150 West 62nd Street New York NY	Approved	\$650.00
6/26/15 Swapped Drawings 1,2, 3 & 4, Revision 3s.						
50578	11A0085	L.E.A. Electric Corp. 1001 Sixth Avenue, 11th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	136 Madison Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

March 10, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50579	11A0086	Maximum Electric Corp. 34-17 Broadway Astoria NY 11106	Requested approval for the electric service equipment proposed to be installed	33 East 70th Street New York NY	Approved	\$650.00
50580	11A0087	Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	Aloft W Hotels 216 Duffield Street Brooklyn NY	Approved	\$650.00
50581	11A0088	Riverdale Electric Corp. 4215 Peter Pl. Bronx NY 10470	Requested approval for the electric service equipment proposed to be installed	50 East 153rd Street Bronx NY	Approved	\$650.00
50582	11A0089	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	1 Chase Manhattan Plaza New York NY	Approved	\$650.00
Through bus undersized. Job finalized 4/7/11.						
50583	11A0090	Cogen Electrical Services, Inc. 528 Craven Street Bron x NY 10474	Requested approval for the electric service equipment proposed to be installed	175 West 89th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

March 10, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50584	11A0091	Litespeed Electric 135 West 29th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	111 West 57th Street New York NY	Approved	\$650.00
Provide the length of the tap. Job finalized 4/19/11.						
50585	11A0092	Ark systems Electric Corp. 27-08 42nd Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Bronx Community College 200 Hall of Fame Terrace Bronx NY	Approved	\$650.00
1) FA switch on emergency side bonded after generator bond and ground. 2) Remove bond after neutral link. 3) Show EDP panel. 4) Verify primary switch can handle the transformer in rush current. Job finalized 4/19/11.						
50586	11A0093	Atlas-Acon Electric Service Corp. 283 Hudson Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	Trinity Real Estate 200 Hudson Street New York NY	Approved	\$650.00
Provide mechanical ventilation in service room. Job finalized 4/19/11.						
50587	11A0094	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	NYU 58 Washington Square South New York NY	Denied	\$650.00
1) Service room to be mechanically ventilated. 2) Service rooms to have two means of egress. 3) Verify that emergency feeders are not ran through the service rooms. 4) Service entrance conductors are undersized. 5) Is service pull box a copper detail box? How are taps being made? 6) Service switch neutrals not bonded or grounded. 7) Fire pump service switch not bonded and grounded and not fused at 600%. 8) Confirm that ATS room doesn't contain anything but life safety.						
50588	11A0095	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	TelX-Phase 1, 6th Floor 111 Eighth Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

March 10, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50589	11A0096	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	CB Richard Ellis 787 7th Avenue New York NY	Approved	\$650.00
Equipment grounding conductors undersized to new chiller #3. Job finalized 5/2/11.						
50590	11A0097	Gilston Electrical Contracting Corporation 338 East 95th Street New York NY 10128	Requested approval for the electric service equipment proposed to be installed	Whittman Ingersoll Houses 55-110 Monument Walk Brooklyn NY	Denied	\$650.00
Service entrance conductors are undersized.						
50591	11A0098	Circle D Electrical Contracting Inc. 3916 Dyre Avenue Bronx NY 10466	Requested approval for the electric service equipment proposed to be installed	410 Park Avenue New York NY	Approved	\$650.00
Line and load in same cubicle.n Job finalized 5/2/11.						
50592	11A0099	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Maspeth Campus IS/HS 585Q 54-70 74th Street Maspeth NY	Denied	\$650.00
1) Service entrance conductors feeding both services undersized. 2) Fire alarm cut outs installed instead of switches.						
50593	11A0100	Dorkin Electric 555 Coney Island Avenue Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	454 Lavonia Avenue Brooklyn NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

March 10, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50594	11A0101	Samson Electric Corp. 3300 Northern Blvd., Basement Level Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Worldwide Plaza 825 8th Avenue New York NY	Approved	\$650.00
50595	11A0102	Nidetch Electric Co., Inc. 2337 McDonald Avenue Brooklyn NY 11223	Requested approval for the electric service equipment proposed to be installed	1 East 70th Street New York NY	Approved	\$650.00
50596	11A0103	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10018	Requested approval for the electric service equipment proposed to be installed	New York University Data Ctr 32 Avenue of the Americas New York NY	Approved	\$650.00
Trough bus undersized on left side of bus second cubicle. Job finalized 4/19/11.						
50597	11A0104	Meco Electric Co., Inc. 56 West Street Staten Island NY 10310	Requested approval for the electric service equipment proposed to be installed	NYCDEP Pumping Station 84 West 11th Street Brooklyn NY	Denied	\$650.00
1) Submittal is not in Advisory Board format. 2) Which work is new?						
50598		AKF Engineers 1501 Broadway, Suite 700 New York NY 10036	Requesting special permission on a one-time-one location basis to install the fire pump ATS at the fire pump location in accordance with Rule 12.01 (h)(2)(ii) due to unique space and layout conditions in this building which results in a shared equipment room with the main electric service.	7 West 54th Street New York NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

March 10, 2011

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
50599		Arcadia Electrical Company, Inc. 1005 Wyckoff Avenue Ridgewood NY 11385	Requesting permission to locate a service switch and panel directly across from an existing switchboard without providing a second means of egress in a service room	I.S. 117K 300 Willoughby Street Brooklyn NY	Denied	\$0.00
50600		altPower, Inc. 125 Maiden Lane, Suite 309 New York NY 10038	Requesting permission to allow the use of 48 custom sized photovoltaic panels that will be installed on the entrance lobby and roof where the PV panels will be built in a listed shop but will not be labeled due to the expense of testing and listing.	Battery Park City Site 2b 55 Battery Place New York NY	Approved	\$0.00
50601		Corporate Electric Group, Inc. 14-34 110th Street, Suite 201 College Point NY 11356	Requesting permission due to relocating electrical equipment to comply with Section 110.26(c)(2)(A) and (b) to leave one means of egress in a 1000 KVA service room.	PS29Q 125-10 23rd Avenue College Point NY	Approved	\$0.00
With the stipulation that the fuse C/OS is relocated to comply with the requirements of Section 110.26 and 2 copies of revised drawings are forwarded to the Advisory Board.						