

# ADVISORY BOARD CALENDAR

**March 14, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47529CO	06A0524CO	Double D Electric Inc. 33 2nd Avenue Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	176-60 Union Turnpike Queens NY	Denied	\$0.00
Carry over from November 15, 2006 meeting. 1) The submitted drawing is not in the correct Advisory Board format. 2) The tap detail is not clearly shown or drawing. 3) Manufacturer's cut sheets of equipment not provided. 4) The 2nd fuses were not shown on drawing. 5) The neutral in the 200 amp service switch not properly bonded. 6) Conductor size from meter to the service switch not shown on drawing.						
47696CO	07A0078CO	Fas Electric, Inc. 10 Jefferson Blvd. Staten Island NY 10312	Requested approval for the electric service equipment proposed to be installed	1479 Beach Channel Drive Far Rockaway NY	Approved	\$0.00
Carry over from February 14, 2007 meeting. 1) Provide manufacturer's cut sheets of end box and meter banks. 2) Get approval from Con-ed to install 3 phase meter banks. Job finalized 3/26/07.						
47703CO	07A0085CO	Shorr Electric Contracting Inc. 34-13 10th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Macy's 422 Fulton Street Brooklyn NY	Approved	\$0.00
Carry over from February 14, 2007 meeting.						
47734	07A0141	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	CitiGroup 44-47 23rd Street Long Island City NY	Hold	\$650.00
No drawings.						
47735	07A0112	Network Electrical Contracting Corp. 35-43 37th Street, Unit C Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Jewish Home & Hospital 100 West Kingsbridge Road Bronx NY	Approved	\$650.00
1) Verify sizing of fire alarm XFMR & FCO on emergency side. 2) Relocate barrier in exist. service room to prevent access behind switchboard. Job finalized 4/24/07.						

# ADVISORY BOARD CALENDAR

**March 14, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47736	07A0108	Sage Electrical Contracting Inc. 651 Willowbrook Road, Suite 201 Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	229 West 60th St., Bldgs. "B" & "C" New York NY	Approved	\$650.00
1) Verify primary sw/fu size for 750 KVA XFMR. 2) Install barrier to block access behind 750 KVA XFMR. Job finalized 4/24/07.						
47737	07A0109	Sage Electrical Contracting Inc. 651 Willowbrook Road, Suite 201 Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	243 West 60th Street, Building "A" New York NY	Approved	\$650.00
47738	07A0110	Royal Electrical & Wiring Corp. 27-07 BQE West Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Hanac 24-70 Hoyt Avenue South Astoria NY	Approved	\$650.00
47739	07A0106	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Citigroup 44-47 23rd Street Long Island City NY	Hold	\$650.00
1) Generator room layout not complete. 2) Fire pump service switch not tapped from load side of CT cabinet. 3) Resubmit for expanded system. 4) Correct typo- norm FDR to ATS #3 should be 10 sets 600 KCM.						
47740	07A0105	Star-Delta Electric Inc. 17 Battery Place-Suite 701 New York NY 10004	Requested approval for the electric service equipment proposed to be installed	40 Wall Street New York NY	Hold	\$650.00
1) 26th Floor elect. room, 2nd door? 2) Is 2000 amp service new or existing. 3) Block access behind DP-26-A.						

# ADVISORY BOARD CALENDAR

**March 14, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47741	07A0138	Tru-Val Electric Corp. 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	PS 262 95-16 89th Avenue Woodhaven NY	Approved	\$650.00
47742	07A0135	Jeco Electrical Service Corp. 1162 Intervale Avenue Bronx NY 10459	Requested approval for the electric service equipment proposed to be installed	756 Myrtle Avenue Brooklyn NY	Approved	\$650.00
Tap detail in trough not shown on drawing. Job finalized 4/26/07.						
47743	07A0131	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	40 West 53rd Street New York NY	Ok, but	\$650.00
1) Overlay curves and coordination not provided. 2) Type of 1200 amp fuse not shown on drawing. 3) Type of 200 amp circuit breaker not shown on drawing. 4) Verify AIC rating or new bkr CB. 5) Indicate available s.c. current.						
47744	07A0117	Hugh O Kane Electric Company, Inc. 90 White Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	1271 6th Avenue, 36th Fl. New York NY	Approved	\$650.00
1) Increase service entrance conductors to 800 amp service switches. 2) Provide drawings of Lincoln switches. Job finalized 4/26/07.						
47745	07A0132	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	Queens West Building #6 47-20 Center Blvd. Long Island City NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**March 14, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47746	07A0128	Fred Geller Electrical, Inc. 37-32 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	1155 6th Avenue New York NY	Approved	\$650.00
47747	07A0126	Izzo Electric Inc. 2522 E. Tremont Avenue Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	837 Washington Avenue Bronx NY	Approved	\$650.00
47748	07A0125	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	311 West Broadway New York NY	Approved	\$650.00
47749	07A0123	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Mt. Sinai 5 East 102nd Street New York NY	Approved	\$650.00
47750	07A0142	Essential Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Atria Assisted Living 3718-3726 Henry Hudson Parkway Bronx NY	Hold	\$650.00
1) Front of switchboards need 7' clearance. 2) Fire alarm switch installed in front of equipment. 3) Generator cut sheets not provided. 4) Fire pump FLA not provided. 5) Generator neutral not properly bonded. 6) Explain mixing of 3 and 4 pole ATS. 7) Step down transformers not shown on drawing. 8) Neutral in 480 volt service switch for fire alarm not bonded to enclosure. 9) 3000A ATS and feeders undersized for 4000A service fuse. 10) 4-wire loads require 4-pole ATS's. 11) Confirm 2 means of egress.						

# ADVISORY BOARD CALENDAR

**March 14, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47751	07A0140	CSA Engineering Services 37 Miry Brook Road Danbury CT 06810	Requested approval for the electric service equipment proposed to be installed	Grand Manor Nursing Home and 700 White Plains Road Bronx NY	Approved	\$650.00
47752	07A0101	Coastal Electric Construction Corp. 232 Madison Avenue, Suite 200 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Sunset Park H.S. 156 34th Street Brooklyn NY	Approved	\$650.00
Provide 3 ft clearance on both sides of rear access switchboards provide walking room at the point of entry. Job finalized 4/24/07.						
47753	07A0146- cancelled	Flack + Kurtz Inc. 475 Fifth Avenue New York NY 10017	Requested concept approval	New York Times Building 620 8th Avenue New York NY	Hold	\$0.00
1) Indicate method of physical support for "Artwork Junction Box". 2) Provide wattage of screens and confirm #16 AWG wire sufficient. 3) Indicate purpose of pulley system. 4) Per 400.8 flexible cord not permitted in hung ceiling. 5) Indicate grounding.						
47754	07A0145	Flack + Kurtz Inc. 475 Fifth Avenue New York NY 10017	Requested approval for the electric service equipment proposed to be installed	N. Shore L.I.J Hospital 265-25 76th Avenue New Hyde Park NY	Approved	\$650.00
1) Indicate location of tap to congen. in Asco drawings, emergency power distribution switchgear. 2) Conform to code required clearances. 3) Indicate fire alarm tap on Asco drawings. 4) Show future ext. provision on emergency distribution switchgear. 5) Show elec. Interlocks on Asco breakers w/ seq. of operations. Job finalized 12/10/08.						
47755	07A0119	Dorion Norton Electrical Contracting Corp 218 Clifton Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	Willetts Points Asphalt 37-02 College Point Blvd. Flushing NY	Approved	\$650.00
1) Show load side of 6000 amp disconnect switch. 2) Secondary fuse oversized on 1-line (6000AS/6000AF) floor plan show 2500AS? 3) Barrier access to sides of transformer. Job finalized 3/26/07.						

# ADVISORY BOARD CALENDAR

**March 14, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47756	07A0143	Gallagher Electrical Contractors 116 John Street, Suite 503 New York NY 10038	Requested approval for the electric service equipment proposed to be installed	Hermes 55 Exchange Pl. and 15 Broad Street New York NY	Approved	\$650.00
47757	07A0111	A.S.R. Electrical Contracting, Inc. 177-04 93rd Street Jamaica NY 11433	Requested approval for the electric service equipment proposed to be installed	216 West 18th Street New York NY	Approved	\$650.00
47758	07A0113	Integral Electrical Power & Control Corp 307 7th Avenue, Suite 507 New York NY 10001	Requested approval for the electric service equipment proposed to be installed	111 Fulton Street New York NY	Ok, but	\$650.00
1) Provide load calculations for apts. 2) Fire pump wiring not on one line.						
47759	07A0114	Bigman Brothers, Inc. 43-40 34th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	333 East 38th Street, 5th Floor New York NY	Approved	\$650.00
1600 amp tap bus duct aluminum to copper undersized. Job finalized 9/5/07.						
47760	07A0115	ECS Electrical Contracting Services, Inc. 351 Kent Avenue Brooklyn NY 11211	Requested approval for the electric service equipment proposed to be installed	Parkchester Houses 81 Metropolitan Oval Bronx NY	Approved	\$650.00
Bus in new distribution panel undersized. Job finalized 3/27/07.						

# ADVISORY BOARD CALENDAR

**March 14, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47761	07A0107	Applied Electric Corporation 63 Flushing Avenue, Unit 223 Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	Queen of Peace Residence 110-30 221st Street Queens NY	Approved	\$650.00
<p>1) Bond neutral to building steel on secondary of step down transformer. 2) Clarify if 3 or 4 pole ATS are being used drawing says 4 pole cut sheets are 3 pole. 4) Show load off of transformer secondary for life safety.</p>						
47762	07A0103	Fred Geller Electrical, Inc. 54-15 38th Avenue Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Henry Miller Theater 1111 6th Avenue New York NY	Hold	\$650.00
<p>1) Fuse cutout must be used on 120/208 volt side for fire alarm system. 2) Emergency side of fire alarm system must be tapped ahead of generator main switch. 3) Line fuse feeding ATS #4 must be 100 amps. 4) Generator neutral must be properly bonded. Job finalized 4/26/07.</p>						
47763	07A0139	Millennium Maint. & Electl Contractors, Inc. 201 Franklin Street Brooklyn NY 11222	Requested approval for the electric service equipment proposed to be installed	Lincoln Center 132 W. 65th Street New York NY	Approved	\$650.00
<p>1) No double lugging allowed in meter pan. 2) Verify if RHH conductor is fire rated. 3) Drawing not clear on what work in existing and new.</p>						
47764	07A0136	Jay Helfgott Electric Corp. 2970 Fulton Street Brooklyn NY 11208	Requested approval for the electric service equipment proposed to be installed	205 Rockaway Parkway Brooklyn NY	Hold	\$650.00
<p>1) Verify if 10 HP motor is a fire pump, if it is service switch is undersized and conductors must be fire rated. 2) Generator neutral must be bonded properly 4 pole ATS is used. 4) Verify if room is fire rated. 4) Service room door to open out. 5) Show location of service switch #3. 6) Service equipment chart does not match room layout.</p>						
47765	07A0137	Essential Electric Corp. 32 East 31st Street, 8th Floor New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Towers at Hutchinson Metro Ctr. 1250 Waters Place Bronx NY	Hold	\$650.00

# ADVISORY BOARD CALENDAR

**March 14, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47766	07A0130	Lowy & Donnath, Inc. 10-37 49th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	31 West 52nd Street New York NY	Approved	\$650.00
Job finalized 4/26/07.						
47767	07A0116	Tru-Val Electric Corp. 2550 Park Avenue Bronx NY 10451	Requested approval for the electric service equipment proposed to be installed	Bronx Studio School 928 Simpson Street Bronx NY	Approved	\$650.00
47768	07A0133	BT Electrical, Inc. 85-02 67th Drive Rego Park NY 11374	Requested approval for the electric service equipment proposed to be installed	Baum Residence 575 Park Avenue, Apt. 1501 & 1502 New York NY	Approved	\$650.00
47769	07A0129	York Electrical Contractors Inc. 163-10 Crocheron Avenue Flushing NY 11358	Requested approval for the electric service equipment proposed to be installed	Eagle Building 24th Avenue and 21st Street Astoria NY	Approved	\$650.00
47770	07A0127	Sigma Electric, Inc. 52-32 83rd Street, Suite 1-M Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	157 West 47th Street New York NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**March 14, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47771	07A0124	Gateway Electric Group, LLC 11-02 37th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	39-45 East 29th Street New York NY	Approved	\$650.00
47772	07A0122	NJS Electrical Services Corp. 36-16 13th Street Long Island City NY 11106	Requested approval for the electric service equipment proposed to be installed	Ruby Tuesday 7 Times Square New York NY	Approved	\$650.00
47773	07A0121	Hara Electric Corp. 24-61 47th Street Astoria NY 11103	Requested approval for the electric service equipment proposed to be installed	P.S. 5 564 Jackson Avenue Bronx NY	Approved	\$650.00
47774	07A0104	Egg Electric Inc. 24 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	NYU 550 First Avenue New York NY	Approved	\$650.00
Neutral in 2500 amp disconnect switches bonded after service switch. Job finalized June 18, 2007.						
47775	07A0102	Tru-Val Electric Corp. 218 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	JHS 218 James P. Sinnott 370 Blake Avenue Brooklyn NY	Approved	\$650.00

# ADVISORY BOARD CALENDAR

**March 14, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47776	07A0100	Inter-Connection Electric, Inc. 6821 8th Avenue Brooklyn Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	1211 Southern Blvd. Bronx NY	Hold	\$650.00
1) Verify conductor size to fire pumps. 2) Branch circuit to fire pump must be fire rated. 3) Tap for fire pump made in same switch section. 4) Provide short circuit calculations for panel UPC. 5) Provide type of branch circuit breaker being used.						
47777	07A0147	AARCO Electric Inc. 5902 Avenue N Brooklyn NY 11234	Requested approval for the electric service equipment proposed to be installed	incoln Medical and Mental Health Cl 234 E. 149th Street Bronx NY	Approved	\$650.00
Fire pump feed in same cubicle as service switch, verify if this is a one for one replacement.. Job finalized 3/27/07.						
47778	07A0118	AA Reale Electric Inc. 4223 1st Avenue Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	80 Bridgewater Street Brooklyn NY	Approved	\$650.00
47779	07A099	Lizardos Engineering Associates P.C. Two Penn Plaza, Suite 1500 New York NY 10121	Requested approval for the electric service equipment proposed to be installed	New York University 334 E. 26th Street New York NY	Approved	\$650.00
47780	07A0144	C.B. Electric, Inc. 130-43 92nd Avenue Richmond Hill NY 11418	Requested approval for the electric service equipment proposed to be installed	Acme Smoked Fish Corp. 30 Gem Street Brooklyn NY	Approved	\$650.00
Show where feed from 1st building is coming from and wire size of feeder. Job finalized 4/24/07.						

# ADVISORY BOARD CALENDAR

**March 14, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47781	07A0134	Washington Electric Co., Inc. 140 58th Street, Suite 8F Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	B & H Photo 420 9th Avenue New York NY	Hold	\$650.00
Drawing not in Advisory Board format.						
47782	07A0120	Paradise Electrical Contractors Inc. 50-24 71st Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Condominium Conversion 15 East 26th Street New York NY	Hold	\$650.00
1) Jockey pump tap made in controller. 2) The 2000 amp bus can't be fused at 3000 amp.						
47783		Joseph R. Loring & Associates, Inc. 21 Penn Plaza, 14th Floor New York NY 10001	Requesting permission to leave as installed underground concrete encased service entrance conductors in Schedule 40 non-metallic conduits that will run approximately 130 feet to a school building.	IS/HS 43R 100 Essex Drive Staten Island NY	Approved	\$0.00
47784	[[	STV Incorporated 225 Park Avenue South New York NY 10003	Requesting permission to install underground service entrance conductors in Schedule 40 non metallic conduit or FRE conduit that will feed a school building.	PS 102Q  Elmhurst ny	Approved	\$0.00
47785	[[[	STV Incorporated 225 Park Avenue South New York NY 10003	Requesting permission to install underground service entrance conductors in Schedule 40 non metallic conduit or FRE conduit that will feed a school building.	Metropolitan Schools  Forest Hills NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

**March 14, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47786	[[[[[	APS Electric Inc. 2614 West 13th Street Brooklyn NY 11223	Requesting permission due to corrosive area Far Rockaway, Queens to install overhead rigid non metallic service entrance conductor conduits for 4 two family buildings.	4113, 4117, 4119 Rockaway Bch E Queens NY	Approved	\$0.00
With the stipulation that Schedule 80 rigid non metallic conduits are used and not subject to mechanical injury.						
47787	[[[[[	ASP Electric, Inc. 68-01 Myrtle Avenue Glendale NY 11385	Requesting permission to run service entrance conductors in electrical metallic tubing approximately 30 feet into a 4 family building that does not have a basement.	324 East 4 Street New York NY	Approved	\$0.00
With the stipulation that the installation conforms with Article 230.6 and the correct listed connectors are installed.						
47788	[[[[[[	Penguin/Broadway Electrical Maintenance 26 West Street Brooklyn NY 11222	Requesting permission not to group together service equipment where the owner is adding a PLP service and there is no room next to the existing equipment in a two family building.	141 York Avenue Staten Island NY	Approved	\$0.00
With the stipulation that the installation conforms with Article 230.2(E).						
47789	[[[[[[[	Powerhouse Electrical Contractors Inc. 57 Beach Street Staten Island NY 10304	Requesting permission to install an additional 30 amp overhead outdoor service on a one family building that will provide power to site lighting for the condo parking area, the new service will be located next to the existing service equipment.	Cypress Crest Condo III 18 Peter Street Staten Island NY	Approved	\$0.00
47790	[[[[[[[[	Network Electrical Contracting Corp. 35-43 37th Street Unit C Long Island City NY 11101	Requesting permission due to lack of space inside of the existing service room to install a new 3000 amp service switch in an adjacent room where signage will be provided.	Jewish Home & Hospital 100 West Kingsbridge Road Bronx NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

**March 14, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47791	[ ]	Dotroneo & Marino's United Elec. Co., Inc. 58-15 Fresh Pond Road Maspeth NY 11378	Requesting permission to leave as installed a circuit breaker panel that is mounted with a height of 7'2" from the floor to the top circuit breaker on a job where the existing fuse panel was originally installed	153 West 80th Street New York NY	Approved	\$0.00
47792	[ ]	Chaim Electric Corporation 2920 Avenue J Brooklyn NY 11210	Requesting permission to leave as installed kitchen hood exhaust fans that are connected to the two or more small appliance branch circuits that supply kitchen countertop receptacles.	1904 Vyse Avenue Bronx NY	Approved	\$0.00
47793	[ ]	W.T.G. Electric, Inc. 115-14 Beach Channel Drive Rockaway Park NY 11694	Requesting permission to replace existing wiring and install new additional receptacles that won't comply with spacing requirements of 210.52 (A)(1) to preserve existing marble and raised panel wood work inside of a one family building that won't be gutted out.	36 East 67th Street New York NY	Approved	\$0.00
47794	[ ]	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requesting permission on a job that was previously approved to utilize the old New York City code for electrical equipment clearances and approve updated sketches of an electrical closets that meet a minimum of 36" clearances.	425 Park Avenue New York NY	Approved	\$0.00
With the stipulation that the installation is subject to field inspection by the Department of Buildings Electrical Inspection unit.						
47795	[ ]	Shorr Electrical Contracting Inc. 34-13 10th Street Long Island City NY 11106	Requesting permission to install a 400 amp fusible service switch in lieu of an fuse cutout to feed a fire alarm riser.	Macy's 422 Fulton Street Brooklyn NY	Approved	\$0.00

# ADVISORY BOARD CALENDAR

**March 14, 2007**

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47796	[REDACTED]	Zwicker Electric Co. Inc. 360 Park Avenue South New York NY 10010	Requesting permission to support 600 MCM copper conductors 42 feet instead of 40 feet on a vertical run.	Battery Park City Site 26 New York NY	Denied	\$0.00
Approval is subject to obtaining documentation from the manufacturers of both the conductor and chocks that the conductors can withstand the requested 42nd foot support.						
47797	[REDACTED]	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requesting concept approval for the installation of a photovoltaic system.	Ben Heller 254 Warren Street Brooklyn NY	Approved	\$0.00
With the stipulation: 1) The installation of the photovoltaic system must comply with Article 690. 2) The PV system must be tested by a nationally recognized testing laboratory and labeled after the completion of the testing. 3) Section 27-140 of the New York City Building Code requires PW-1 filing by an architect or engineer licensed and registered in New York State. In addition, all electrical work must be installed by an electrician licensed by the New York City Department of Buildings.						
47798	[REDACTED]	Solar Energy Systems 1205 Manhattan Avenue, Suite 1-2-10 Brooklyn NY 11222	Requesting concept approval; for the installation of a photovoltaic system	Ken Schles 378 Vanderbilt Avenue Brooklyn NY	Approved	\$0.00
With the stipulation: 1) The installation of the photovoltaic system must comply with Article 690. 2) The PV system must be tested by a nationally recognized testing laboratory and labeled after the completion of the testing. 3) Section 27-140 of the New York City Building Code requires PW-1 filing by an architect or engineer licensed and registered in New York State. In addition, all electrical work must be installed by an electrician licensed by the New York City Department of Buildings.						
47799	[REDACTED]	altPower, Inc. 125 Maiden Lane, Suite 307 New York NY 10038	Requesting permission to install custom made non listed photovoltaic modules that will be integrated into the buildings facade and to also request concept approval for the wiring of the PV system.	Battery Park City Site 3 70 Little West Street New York NY	Approved	\$0.00
With the stipulation that: 1) The unlisted photovoltaic panels must be field evaluated by a nationally recognized testing laboratory. 2) The installation of the photovoltaic system must comply with Article 690. 3) The PV system must be tested by a nationally recognized testing laboratory and labeled after the completion of the testing. 4) Section 27-140 of the New York City Building Code requires PW-1 filing by an architect or engineer licensed and registered in New York State. In addition, all electrical work must be installed by an electrician licensed by the New York City Department of Buildings.						

