

ADVISORY BOARD CALENDAR

March 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45219CO3	03A0548CO3	GMA Electrical Corporation 201 Edward Curry Avenue, 2nd Floor Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Verizon 89-63 163rd Streete Queens NY	Approved	\$0.00
Carry over from December 15, 2004 meeting.						
46687CO2	05A0483CO2	Danfoss Inc. 7880 Tranmere Drive Toronto ON L5S1L	Requested approval for use in New York City of your Danfoss LX Electrical Radiant Floor Heating Mats complete with Controller (thermostat). Model/Series Number: LX Series 088L.		Approved	\$0.00
Carry over from February 15, 2006 meeting.						
46883CO	06A0035CO	D.J. Electrical Contractors, Inc. 217 Fordham Street Bronx NY 10464	Requested approval for the electric service equipment proposed to be installed	60 Sutton Place South New York NY	Approved	\$0.00
Carry over from January 25, 2006 meeting.						
46915CO1	06A0031CO1	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	375 Park Avenue New York NY	Hold	\$0.00
Carry over from January 25, 2006 meeting. See Items 2, 3 & 5 on the January 25, 2006 calendar.						
46950CO	06A0063CO	Stasi/Dallas Electrical Contracting, Inc. 6908 Eighth Avenue Brooklyn NY 11228	Requested approval for the electric service equipment proposed to be installed	Elmhurst Cancer Care Center 77-11 Broadway Elmhurst NY	Approved	\$0.00
Carry over from February 15, 2006 meeting. Egress doors must comply with 110.26 (C) (2). Job finalized April 10, 2006						

ADVISORY BOARD CALENDAR

March 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46956CO	06A0075CO	A.S.R. Electrical Contracting, Inc. 177-04 93rd Avenue Jamaica NY 11433	Requested approval for the electric service equipment proposed to be installed	1072 Havemeyer Avenue Bronx NY	Approved	\$0.00
Carry over from February 15, 2006 meeting.						
46964CO	06A0090CO	Electrical & Mechanical Contractors, Co 26 Delavan Street Brooklyn NY 11231	Requested approval for the electric service equipment proposed to be installed	110 Livingston Street Brooklyn NY	Approved	\$0.00
Carry over from February 15, 2006 meeting. The bonding conductors on the load side of the 4000 amp service switch fuses are undersized should be 500 MCM. Job finalized April 10, 2006.						
46970CO	06A0096CO	The Electric Connection Inc. 410 West 127th Street New York NY 10027	Requested approval for the electric service equipment proposed to be installed	New York Hotel New York NY	Hold	\$0.00
Carry over from February 15, 2006 meeting.						
46973CO	06A0102CO	Mazza Electric Corp. 494 Eighth Avenue New York NY 10001	Requested approval for the electric service equipment proposed to be installed	330 5th Avenue New York NY	Approved	\$0.00
Carry over from February 15, 2006 meeting.						
46976CO	*	Tetra Tech 5 Penn Plaza, 15th Floor New York NY 10001	Requesting permission due to elevator hardship, to install 61 new feeders in elevator shaftways that will power elevators and controllers in 27 low rise buildings.	NYCHA Whitman/Houses Brooklyn NY	Approved	\$0.00
Carry over from February 15, 2006 meeting.						

ADVISORY BOARD CALENDAR

March 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46988CO	***	Atkinson Koven Feinberg Engineers, LLP 1501 Broadway, Suite 700 New York NY 10036	Requesting permission to not comply with Section 110.26 (c) (2) in a service room where the egress would interfere with mechanical and laboratory equipment in adjacent spaces, and also interfere with the egress corridor.	89 Convent Avenue New York NY	Approved	\$0.00
Carry over from February 15, 2006 meeting.						
46991CO	****	Absolute Advanced Electric, Inc. 135-15 37th Avenue, 4th Fl Flushing NY 11354	Requesting permission to run service entrance conductors approximately 12 feet into a 3 family building in electrical metallic tubing.	Amber Street Brooklyn NY	Approved	\$0.00
Carry over from February 15, 2006 meeting. Amendment 230.6.						
46995	06A0105	Highland Associates 228 East 45th Street New York NY 10017	Requested approval for the electric service equipment proposed to be installed	485 Lexington Avenue New York NY	Approved	\$650.00
46996	06A0107	W.T.G. Electric, Inc. 115-14 Beach Channel Drive Rockaway Park NY 11694	Requested approval for the electric service equipment proposed to be installed	Apartment House 435 East 79th Street New York NY	Approved	\$650.00
46997	06A0108	Universal Electric Corp. 290 East 132nd Street Bronx NY 10454	Requested approval for the electric service equipment proposed to be installed	Con Edison Ave. Yards 221 First Street Brooklyn NY	Approved	\$650.00
1200 amp 480 volt switch does not have ground fault protection. Job finalized 2/8/08.						

ADVISORY BOARD CALENDAR

March 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46998	06A0110	Highland Associates 228 East 45th Street New York NY 10017	Requested approval for the electric service equipment proposed to be installed	183 Madison Avenue New York NY	Hold	\$650.00
Submit in Advisory Board format.						
46999	06A0111	W.T.G. Electric, Inc. 115-14 Beach Channel Drive Rockaway Park NY 11694	Requested approval for the electric service equipment proposed to be installed	15 West 20th Street New York NY	Approved	\$650.00
47000	06A0113	CSA Engineering Services 37 Miry Brook Road Danbury CT 06810	Requested approval for the electric service equipment proposed to be installed	Einstein School of Medicine 1300 Morris Park Avenue Bronx NY	Approved	\$650.00
1) Service conductors to new 1600A switch undersized. 2) Clarify generator neutral grounding. 3) Confirm proper XFMR sizing for 125HP motor. Job finalized 5/1/06.						
47001	06A0124	Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	10 East 39th Street New York NY	Approved	\$650.00
1) Remove neutral ground in new 800A switch. 2) Clarify tap location 1-line vs floor plan. Job finalized April 10, 2006.						
47002	06A0125	Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	920 Broadway New York NY	Hold	\$650.00
1) Exiting service bus and cable undersized. Provide historical max Con Ed demand data. 2) Provide series rating for new store panel 3) Provide detail of trough tap; 2-sets to 1-set.						

ADVISORY BOARD CALENDAR

March 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47003	06A0128	Prospect Electric Service, Inc. 699 Prospect Place Brooklyn NY 11216	Requested approval for the electric service equipment proposed to be installed	Haven Manor Nursing Home 1441 Gateway Boulevard Far Rockaway NY	Approved	\$650.00
47004	06A0131	Mackey Reed Electric, Inc. 197-25 Jamaica Avenue Hollies NY 11423	Requested approval for the electric service equipment proposed to be installed	51 Fulton St., aka 212 Ashland Place Brooklyn NY	Approved	\$650.00
47005	06A0132	Barbaro Electric Co. Inc. 331 38th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	33 East 70th Street New York NY	Approved	\$650.00
47006	06A0133	z L Electric Installation & Maintenance Co 63 Flushing Ave., Unit 247 Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	Bowery Hotel 4 East 3rd Street New York NY	Approved	\$650.00
47007	06A0136	Kleinknecht Electric Company, Inc. 940 Eighth Avenue New York NY 10019	Requested approval for the electric service equipment proposed to be installed	Citigroup 787 7th Avenue New York NY	Approved	\$650.00
1) Provide GFI on gen. Mcb (Art. 702 standby gen.) 2) Provide bonding/gnde/dis link in MS F-2. Job finalized April 10, 2006.						

ADVISORY BOARD CALENDAR

March 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47008	06A0137	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	Lehman Brothers Chiller Upgrade 85 10th Avenue-7th Floor & Roof New York NY	Ok, but	\$650.00
Paralleling switchboard main bus should be 700A/sq. in.						
47009	06A0139	Genergy Electric Services Co., LLC 353 West 48th Street New York NY 10036	Requested approval for the electric service equipment proposed to be installed	20 Exchange Place New York NY	Approved	\$650.00
47010	06A0140	Star-Delta Electric Inc. 17 Battery Place-Suite 701 New York NY 10004	Requested approval for the electric service equipment proposed to be installed	D.E. Shaw & Co. 120 West 45th Street New York NY	Approved	\$650.00
47011	06A0142	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	40 Bond Street New York NY	Approved	\$650.00
47012	06A0144	Accu-Glo Electric of New York, Inc. 38-26 30th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	575 Madison Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

March 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47013	06A0146	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	Atlas Park-Building #8 80th Street & Cooper Avenue Glendale NY	Approved	\$650.00
47014	06A0147	L.K. Comstock & Company, Inc. 1560 Broadway-Suite 1214 New York NY 10036	Requested approval for the electric service equipment proposed to be installed	New York Life 51 Madison Avenue New York NY	Approved	\$650.00
47015	06A0149	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	JP Morgan Chase 245 Park Avenue New York NY	Approved	\$650.00
Confirm ground fault tripping on standby gen. mob. Job finalized 3/27/06.						
47016	06A0152	Urban Power and Lighting, Inc. 227 49th Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	Brooklyn Renaissance Plaza 335 Adams Street Brooklyn NY	Approved	\$650.00
1) Confirm GFI on switches 1000A @ 480V. 2) Provide gen. & gen mcb cuts. 3) Adjoining room should not exit into switchboard room. Job finalized 8/22.						
47017	06A0153	GMA Electrical Corporation 201 Edward Curry Avenue, 2nd Floor Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Bronx Lighthouse Charter School 1001 Intervale Avenue Bronx NY	Approved	\$650.00
Provide drawings from equipment manufacturer(GE) . Job finalized 6/9/06.						

ADVISORY BOARD CALENDAR

March 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47018	06A0154	Mar-Kam Electrical Contracting Inc. 153 32nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	UPS Store 5 Hanover Square New York NY	Approved	\$650.00
47019	06A0156	Kroger Electric Company Inc. 1514 Bronxdale Avenue Bronx NY 10462	Requested approval for the electric service equipment proposed to be installed	Verizon 860 Broadway New York NY	Approved	#Error
Provide cuts of new Square D panel. Job finalized April 10, 2006.						
47020	06A0157	Kroger Electric Company Inc. 1514 Bronxdale Avenue Bronx NY 10462	Requested approval for the electric service equipment proposed to be installed	Verizon 45 Main Street Brooklyn NY	Approved	\$650.00
47021	06A0159	Red Wing Electric of New York 261-10 East Williston Avenue Floral Park NY 11001	Requested approval for the electric service equipment proposed to be installed	Yeshiva University 500 West 185 St.-Belfer Hall 214 New York NY	Approved	\$650.00
Clarify Job location.						
47022	06A0160	Royal Electric and Wiring Corp. 27-07 BQE West Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	Silver Leaf 480 East 176 Street Bronx NY	Hold	\$650.00
1) Meterbank feeder undersized. 2) 1-Line too small can't read. 3) Provide heavy duty/service rated safety switch for fire pump. 4) Run neutral to fire pump service switch and bond.						

ADVISORY BOARD CALENDAR

March 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47023	06A0165	Gallant Electric Co. 141 Beach 116th Street Rockaway Park NY 11694	Requested approval for the electric service equipment proposed to be installed	568 Broadway New York NY	Hold	\$650.00
7 Service switches.						
47024	06A0104	Michael Mazzeo Electric Corp. 41-24 24th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	BJW Realty 111 Fifth Avenue New York NY	Ok, but	\$650.00
47025	06A0106	Zwicker Electric Co. Inc. 360 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Extell/Orion 350 West 42nd Street New York NY	Approved	\$650.00
47026	06A0109	Spieler & Ricca Electrical Co. Inc. 52-09 Van Dam Street Long Island City NY	Requested approval for the electric service equipment proposed to be installed	425 Main Street, Bldg. #4 Roosevelt NY	Approved	\$650.00
47027	06A0112	Accountable Electrical Corporation 10 Cebra Avenue Staten Island NY 10301	Requested approval for the electric service equipment proposed to be installed	32 West 18th Street New York NY	Ok, but	\$650.00
1) Egress doors must open out. 2) Fire pump service to be barriered off.						

ADVISORY BOARD CALENDAR

March 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47028	06A0114	Adco Electrical Corporation 201 Edward Curry Avenue Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Morgan Stanley 1 NYP-1st Floor New York NY	Hold	\$650.00
Need additional explanation.						
47029	06A0115	Roz-A-Lite Electrical Contracting, Inc. 163 20th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Riverton Houses 2255-2265 Fifth Ave. Bldg. #2 New York NY	Approved	\$650.00
1) Provide barrier between line and load conductors. 2) Line conductors to 200 amp service switch are undersized. Job finalized 1/19/07.						
47030	06A0116	Roz-A-Lite Electrical Contracting, Inc. 163 20th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Riverton Houses 2225-2235 Fifth Avenue. Bldg. #4 New York NY	Approved	\$650.00
1) Provide barrier between line and load conductors. 2) Line conductors to 200 amp service switch are undersized. Job finalized 1/19/07.						
47031	06A0117	Roz-A-Lite Electrical Contracting, Inc. 163 20th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Riverston Houses 160-2170 Madison Avenue Bldg. #: New York NY	Approved	\$650.00
1) Provide barrier between line and load conductors. 2) Feeders to 800 amp service switch undersized. Job finalized 1/19/07.						
47032	06A0118	Enterprise Electrical Contractors Inc. 41 Terrace Place Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	Riverton Houses 2190 Madison Avenue. Bldg. #3 New York NY	Approved	\$650.00
Provide barrier between line and load conductors. Job finalized 1/19/07.						

ADVISORY BOARD CALENDAR

March 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47033	06A0119	Enterprise Electrical Contractors Inc. 41 Terrace Place Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	Riverton Houses 2171 Madison Avenue. Bldg. #6 New York NY	Approved	\$650.00
Provide barrier between line and load conductors. Job finalized 1/19/07.						
47034	06A0120	Falcon Electrical Contracting Corp. 159 20th Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	PS 3 50-80 South Golf Avenue Staten Island NY	Approved	\$650.00
1) Fuse type in 800 amp service switch not provided. 2) Bonding and grounding of service switches not provided. 3) Service conductors to 800 amp service switch are undersized. 6/12/06 job finalized.						
47035	06A0121	Hugh O Kane Electric Company, Inc. 30-40 48th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1271 6th Avenue New York NY	Hold	\$650.00
1. Manufacturer's cut sheets of bus ducts, tap boxes not provided. 2) Verify if service switches are GF protected.						
47036	06A0122	Selectric Electrical Contracting Co., Inc. 78-14 46th Avenue Elmhurst NY 11373	Requested approval for the electric service equipment proposed to be installed	J.H.S. 13 1573 Madison Avenue New York NY	Approved	\$650.00
47037	06A0123	Hugh O Kane Electric Company, Inc. 30-40 48th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	75 Broad Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

March 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47038	06A0126	Mage Electrical Contractors 158 Perry Street New York NY 10014	Requested approval for the electric service equipment proposed to be installed	450 West 15th Street New York NY	Approved	\$650.00
47039	06A0127	Five Star Electric Corp. 101-32 101st Street Ozone Park NY 11416	Requested approval for the electric service equipment proposed to be installed	37 Wall Street New York NY	Approved	\$650.00
47040	06A0129	Innovative Client Solution 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	250 Park Avenue New York NY	Approved	\$650.00
47041	06A0130	Innovative Client Solution 1144 Hooper Avenue, Suite 205 Toms River NJ 08753	Requested approval for the electric service equipment proposed to be installed	162-31 Cross Bay Blvd. Queens NY	Approved	\$650.00
47042	06A0134	Forest Electric Corp. Two Pennsylvania Plaza, 4th Floor New York NY 10121	Requested approval for the electric service equipment proposed to be installed	New York University 140 East 14th Street New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

March 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47043	06A0135	Arc Electrical Construction Co., Inc. 739 Second Avenue New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Rudin Management 32 Avenue of the Americas New York NY	Approved	\$650.00
Provide GFP on service switch on 1200 amp feeder. Job finalized April 10, 2006.						
47044	06A0138	Unity Electric Co., Inc. 65-45 Fresh Meadow Lane Flushing NY 11365	Requested approval for the electric service equipment proposed to be installed	American Red Cross 514 West 49th Street New York NY	Approved	\$650.00
47045	06A0141	Robert B. Samuels Inc. 48 West 25th Street New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Emigrant Savings Bank 6 East 43rd Street New York NY	Approved	\$650.00
47046	06A0143	B & G Electrical Contractors of NY, Inc. 38-22 55th Street Woodside NY 11377	Requested approval for the electric service equipment proposed to be installed	139 Wooster Street New York NY	Approved	\$650.00
47047	06A0145	P.E. Stone, Inc. 50 Watts Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	New York University 19 West 4th Street-Bsmt , Floors 2-8 New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

March 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47048	06A0148	Lakhani & Jordan Engineers, P.C. 50 East 42nd Street, Suite 1001 New York NY 10017	Requested approval for the electric service equipment proposed to be installed	AIG 72 Wall Street New York NY	Approved	\$650.00
47049	06A0150	J.A. Lee Electric, Inc. 32-30 50th Avenue Long Island City NY 11101	Requested approval for for concept approval	133 East 55th Street New York NY	Approved	\$650.00
47050	06A0151	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	606 West 120th Street New York NY	Approved	\$650.00
47051	06A0155	Mar-Kam Electrical Contracting Inc. 153 32nd Street Brooklyn NY 11232	Requested approval for the electric service equipment proposed to be installed	Harry Truman HS 750 Baychester Avenue Bronx NY	Approved	\$650.00
47052	06A0158	Coastal Electric Construction Corp. 232 Madison Avenue, Suite 200 New York NY 10016	Requested approval for the electric service equipment proposed to be installed	Columbia University 615 West 131st Street New York NY	Hold	\$650.00
1) 1200 amp disc is not shown in service room layout. 2) Are tap conductors under 10' or 25' foot rule? 3) To clarify many switches ahead of fire alarm panel.						

ADVISORY BOARD CALENDAR

March 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47053	06A0162	P.E. Stone, Inc. 50 Watts Street New York NY 10013	Requested approval for the electric service equipment proposed to be installed	AIG-American Int'l Realty 70 Pine Street New York NY	Approved	\$650.00
Remove 1/0 ground or increase it to 4/0. Job finalized 3/27/06.						
47054	06A0161	Promax Electrical Contracting Corp. 112-08 101 Avenue Richmond Hill NY 11419	Requested approval for the electric service equipment proposed to be installed	490 West End Avenue New York NY	Approved	\$650.00
47055	06A0163	Jordan Daniels Electrical Contractors, Inc. 252 West 38th Street, 7th Floor New York NY 10018	Requested approval for the electric service equipment proposed to be installed	Sprint PCS 3250 Hunters Point Avenue Long Island City NY	Ok, but	\$650.00
1) Verify if pull box is the proper size. 2) Provide GFP on 2000 amp emergency feeder.						
47056	06A0164	J.A. Lee Electric, Inc. 25-30 50th Avenue Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	35 Park Avenue New York NY	Approved	\$650.00
47057	=	otroneo & Marinos United Electric Co., In 58-15 Fresh Pond Rd. Maspeth NY 11378	Requesting permission to install non metalli conduit standpipes on 6 two family buildings located in a highly corrosive area, Far Rockaway Queens	183, 185, 187, 189 and 191 Bch 26th Queens NY	Approved	\$0.00

ADVISORY BOARD CALENDAR

March 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47058	==	Robco Electric Corp. 2630 Chesbrough Avenue Bronx NY 10461	Requesting permission to install Schedule 40 non metallic conduit outdoors exposed under a trailer that will be attached to 8 other trailers, the installation will be removed in approximately 8 weeks.	Stadium Lot #15 164th Street & River Avenue Bronx NY	Approved	\$0.00
with the stipulation that Schedule 80 PVC is used as the wiring method and is not subject to mechanical injury.						
47059	=== -	Midland Electrical Co. + NY 11377	Requesting permission to replace service and distribution equipment in a area where the ceiling height is 5'9" instead of 6 1/2 feet.	4 East 2nd Street-Basement New York NY	Approved	\$0.00
47060	==	Valentis Electric Inc. 32-21 58th Street Woodside NY 11377	Requesting permission to leave as installed due to a hardship to replace BX cable without an insulated equipment grounding conductor in a place of public assembly with a occupancy of more than 75 people	44 9th Avenue New York NY	Approved	\$350.00
with the stipulation that ground fault circuit breakers are installed on all circuits.						
47061	===	J.A. Lee Electric, Inc. 23-30 50th Avenue Long Island City NY 11101	Requesting permission to install a outdoor service on a commercial building that will provide power to a cell site.	Cingular Wireless 163 Exterior St Bronx NY	Approved	\$0.00
47062	====	Konsker Electric Corp. 32-15 36th Avenue Long Island City NY 11106	Requesting permission to leave as installed six sets of 600 MCM service entrance conductors to feed a 3000 amp service switch fused at 2000 amps, 2-400 and 4 200 amp service switches due to the existing property line box not being able to accommodate the additional 3 sets of 600 MCM. See attached KW demand provided by Con-Ed	Kings Harbor Multicare Center 2000 East Gun Hill Road Bronx NY	Approved	\$0.00
with the stipulation that the 3000 amp service switch is provided with a permanent label stating fusing in this switch not exceed 2000 amps.						

ADVISORY BOARD CALENDAR

March 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47063	===	Jay Helfgott Electric Corp. 2970 Fulton Street Brooklyn NY 11208	Requesting permission to leave as installed one commercial service switch installed on the outside of a building and the rest of the service switches installed inside of the building and not grouped together	758 Arthur Kill Road Staten Island NY	Approved	\$350.00
with the stipulation that signage is provided out each service indicating where the other services are located as per Article 230.2(E) of the 2002 NEC.						
47064	=====	Lina Electric Corp. 32-41 56th Street Woodside NY 11377	Requesting permission to re-route part of an existing fire pump feeder without installing a two hour fire rated assembly around the conduit	420 E. 54th Street New York NY	Approved	\$0.00
47065	=====	rtford Steam Boiler Inspection and Insurar 188 Mount Airy Road Basking Ridge NJ 07920	Requesting concept approval to replace one for one five defective 480 volt bus duct's and associated equipment inside of old existing electrical closets that do not have updated code clearances and also contain telephone risers that feed through the closets in a building that had an electrical fire.	425 Park Avenue New York NY	Approved	\$0.00
with the stipulation:1) That a formal submission is submitted to the Advisory Board for a final approval. 2) That all clearance issues inside of the electrical closets can not be less than 36". 3) The telephone risers running through the electrical closets must be boxed in.						
47066	06A0166	Byrne Electrical Specialists, Inc. 320 Byrne Industrial Dr. Rockford MI 49341	Requested approval for use in New York City of your Multi-Outlet Assemblies, Model/Series Numbers: BEO80010 Series BEO80011-M Series BEO80011-M2 Series		Approved	\$200.00
47067	06A0167	Lutron Electronics Co., Inc. 7200 Suter Road Coopersburg PA 18036	Requested approval for use in New York City of your Digital Ballast Control System. Model/Series Numbers: CE3T514C2772-CPB1071; C5-BMF-2A; CXPxx-277Mxxx-xD-20-CGP1663		Approved	\$200.00

ADVISORY BOARD CALENDAR

March 15, 2006

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
47068	06A0168	Herman Miller, Inc. P.O. Box 302 Zeeland MI 49464	Requested approval for use in New York City of your Modular Systems Office Furnishings. Model/Series: Frame: NT110, Harness NT 170 & 171, Power Entries NT174 + 175, Receptacles NT 176 + 177.		Approved	\$200.00