

ADVISORY BOARD CALENDAR

March 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
45925CO	04A0423CO	MI Electric Inc. 18-38 119th Street College Point Ny 11356	Requested approval for the electric service equipment proposed to be installed	136-21 Roosevelt Avenue Flushing NY	Approved	\$0.00
Carry over from September 15, 2004 meeting.						
46152CO	05A0043CO	CSA Engineering Services 26 Wildlife Drive New Mildford CT 06776	Requested approval for the electric service equipment proposed to be installed	North Shore Towers 272-40 Grand Central Parkway Floral Park NY	Approved	\$0.00
Carry over from February 16, 2005 meeting.						
46162CO	05A0070CO	GMA Electrical Corporation 201 Edward Curry Avenue, 2nd Floor Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Verizon 355 Forest Avenue Staten Island NY	Approved	\$0.00
Carry over from February 16, 2005 meeting. Subject to Fire Department jurisdiction.						
46163CO	05A0071CO	GMA Electrical Corporation 201 Edward Curry Avenue, 2nd Floor Staten Island NY 10314	Requested approval for the electric service equipment proposed to be installed	Verizon 680 Fairview Avenue Brooklyn NY	Approved	\$0.00
Carry over from February 16, 2005 meeting. Subject to Fire Department jurisdiction.						
46180CO	05A0098CO	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requested approval for the electric service equipment proposed to be installed	New York Post 900 East 132nd Street Bronx NY	Approved	\$0.00
Carry over from February 16, 2005 meeting.						

ADVISORY BOARD CALENDAR

March 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46206CO	05A0081CO	Albin Gustafson Company 5 Tudor City Place New York NY 10017	Requested approval for the electric service equipment proposed to be installed	St. Luke's Nulhenberg Bldg. 1111 Amsterdam Avenue New York NY	Approved	\$0.00
Carry over from February 16, 2005 meeting.						
46209CO	05A0083CO	Forum Engineering, P.C. 139 Fulton Street New York NY 10038	Requested approval for the electric service equipment proposed to be installed	Westside Supermarket 77 7th Avenue New York NY	Approved	\$0.00
Carry over from February 16, 2005 meeting.						
46221CO	*****	Dynamic Electrical 105-15 Jamaica Avenue Richmond Hill NY 11418	Requesting permission to leave as installed in two 5 family buildings without common areas service equipment installed on the outside of the buildings.	31-10 and 31-12 Lewmay Rd Queens ny	Approved	\$0.00
Carry over from February 16, 2005 meeting.						
46227	05A0099	Enterprise Electrical Contractors Inc. 41 Terrace Place Brooklyn NY 11218	Requested approval for the electric service equipment proposed to be installed	121 West 19th Street New York NY	Approved	\$650.00
Feeders undersized (500 KCM=380A).						
46228	05A0103	R S Covello Electric 51-20 35th Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	1604 Broadway New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

March 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46229	05A0105	Justan Electrical Contracting Inc. 17 West 24th Street, 3rd Floor New York NY 10010	Requested approval for the electric service equipment proposed to be installed	227-15 North Conduit Avenue Queens NY	Approved	\$650.00
46230	05A0107	Zwicker Electric Co., Inc. 200 Park Avenue South New York NY 10003	Requested approval for the electric service equipment proposed to be installed	888 Main Street Roosevelt Island NY	Ok, but	\$650.00
1) Provide delta to delta (ungrounded secondary) for 1500 KVA step-up XFMR. 2) Feed existing pump loads from separate delta-Y XFMR. 3) Provide 6'-6" min. Headroom behind switchboard.						
46231	05A0108	CSA Engineering Services 26 Wildlife Drive New Mildford CT 06776	Requested approval for the electric service equipment proposed to be installed	Bronx Ctr for Rehabilitation 1010 Underhill Blvd Bronx NY	Hold	\$650.00
1) Provide short circuit overcurrent protection at new generators. 2) Provide details of autotransformer connections.(480-208V?)						
46232	05A0109	Edwards & Zuck, P.C. Consulting Engs 315 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Tishman-Speyer 50 Rockefeller Plaza New York NY	Approved	\$650.00
Close off access to rear of Switchboard #3.						
46233	05A0110	A.S.R. Electrical Contracting, Inc. 177-04 93rd Avenue Jamaica NY 11433	Requested approval for the electric service equipment proposed to be installed	Office of Emergency Mgmt 165 Cadman Plaza Brooklyn NY	Approved	\$650.00
1) Emergency feed to fire pump must be ahead of generator main switch. 2) No coordination. Can reconfigure and eliminate DP-EM.						

ADVISORY BOARD CALENDAR

March 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46234	05A0125	J.A. Lee Electric, Inc. 10-18 47th Road Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	421 7th Avenue New York NY	Approved	\$650.00
46235	05A0126	Jim Electric Corp. 223 52nd Street Brooklyn NY 11220	Requested approval for the electric service equipment proposed to be installed	16 West 19th Street New York NY	Approved	\$650.00
46236	05A0128	Zwicker Electric Co., Inc. 360 Park Avenue South New York NY 10010	Requested approval for the electric service equipment proposed to be installed	Intell Management 350 West 42nd Street New York NY	Hold	\$650.00
Incorrect drawings.						
46237	05A0129	S.P.B. Electrical Contractors, Inc. 55 John Street, 14th Floor New York NY 10038	Requested approval for the electric service equipment proposed to be installed	Flat Iron Building 175 Fifth Avenue New York NY	Approved	\$650.00
46238	05A0130	AL-Lectric Electrical Corp. 137 Chrystie Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	Surface Hotel 109 Rivington Street New York NY	Hold	\$650.00
1) Fuse too large for feeder in 600A switch. 2) Indicate ratings of ATS feeding distribution B. 3) Submit floor plan.						

ADVISORY BOARD CALENDAR

March 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46239	05A0131	Cogen Electrical Services Inc. 528 Craven Street Bronx NY 10474	Requested approval for the electric service equipment proposed to be installed	2 Tudor City Place New York NY	Ok, but	\$650.00
Relocate 400A switch mounted to Switchboard #1 due to clearance concerns.						
46240	05A0132	Absolute Electrical Contracting Inc. One Cross Island Plaza, Suite 109 Rosedale NY 11422	Requested approval for the electric service equipment proposed to be installed	830 Third Avenue New York NY	Approved	\$650.00
46241	05A0133	Amp-Rite Electric Co., Inc. 1535 Broadway New York NY 10036	Requested approval for the electric service equipment proposed to be installed	525 Lexington Avenue New York NY	Approved	\$650.00
1) Bond neutral on 2500 amp service switch. 2) Add supplemental ground to 2500 amp service switch. Item finalized on March 18, 2005.						
46242	05A0100	AL-Lectric Electrical Corp. 137 Chrystie Street New York NY 10002	Requested approval for the electric service equipment proposed to be installed	180 Livingston Street Brooklyn NY	Hold	\$650.00
Drawings cannot be read.						
46243	05A0101	E-J Electric Installation Co. 46-41 Vernon Blvd. Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	52 Vanderbilt Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

March 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46244	05A0102	Linco Electrical Contracting, Inc. 5442 Arthur Kill Road Staten Island NY 10307	Requested approval for the electric service equipment proposed to be installed	Bricktown Shopping Center Staten Island NY	Approved	\$650.00
46245	05A0104	Spieler & Ricca Electrical Co., Inc. 52-09 Van Dam Street Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	627 West 42nd Street New York NY	Approved	\$650.00
1) Supplemental grounds must be installed ahead of neutral disconnect link. 2) Panel DP-A/B bus is undersized. Item finalized on March 18, 2005.						
46246	05A0106	Infinity Electric Co., Inc. 132-10 Cross Bay Boulevard Ozone Park NY 11417	Requested approval for the electric service equipment proposed to be installed	Max Medical 2211 Emmons Avenue Brooklyn NY	Hold	\$650.00
1) Size of feeders to 600 amp service switch must be provided. 2) Clarify location of sprinkler booster pump. 3) Show 2nd fusing from 600 amp service switch. 4) Show series ratings of circuit breakers in panel LP1.						
46247	05A0111	Tikvah Electric Co., Inc. 1731 West Farms Road Bronx NY 10460	Requested approval for the electric service equipment proposed to be installed	151 West 56th Street New York NY	Approved	\$650.00
46248	05A0112	Stonehill Electric Corp. 33-00 Northern Blvd.-Lobby Long Island City NY 11101	Requested approval for the electric service equipment proposed to be installed	75 9th Avenue New York NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

March 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46249	05A0113	Gilston Electrical Maint. Corp. 453 East 175th Street Bronx NY 10457	Requested approval for the electric service equipment proposed to be installed	2432 Grand Concourse Bronx NY	Approved	\$650.00
46250	05A0114	June Electric Corp. 3110 Wilkinson Avenue, Suite 2C Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	951 Hoe Avenue Bronx NY	Approved	\$650.00
46251	05A0115	June Electric Corp. 3110 Wilkinson Avenue, Suite 2C Bronx NY 10461	Requested approval for the electric service equipment proposed to be installed	941 Hoe Avenue Bronx NY	Approved	\$650.00
46252	05A0116	Action Light & Power, Inc. 383 Willoughby Avenue Brooklyn NY 11205	Requested approval for the electric service equipment proposed to be installed	212 Wilson Street Brooklyn NY	Approved	\$650.00
46253	05A0117	Livingston Electrical Assoc., Inc. 162-20 77th Road Flushing NY 11366	Requested approval for the electric service equipment proposed to be installed	The Stephen Gaynor School 148 West 90th Street New York NY	Approved	\$650.00
1) Show normal connection to fuse cutout. 2) Move sections DP-C sections 1 and 2 to right side of wall.						

ADVISORY BOARD CALENDAR

March 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46254	05A0118	K & G Electric Co., Inc. 3925 Broadway New York NY 10032	Requested approval for the electric service equipment proposed to be installed	530 East 86th Street New York NY	Approved	\$650.00
Change 600 amp 2nd fuses to type A2D.						
46255	05A0119	Champion Electric, Inc. 33-70 Prince Street, Suite #C4 Flushing NY 11354	Requested approval for the electric service equipment proposed to be installed	14 East 90th Street New York NY	Approved	\$650.00
46256	05A0120	Pulsar Electric, Inc. 51 Atlantic Avenue Floral Park NY 11001	Requested approval for the electric service equipment proposed to be installed	11 East Broadway New York NY	Approved	\$650.00
Move CT cabinet over to allow for barrier to block off rear of switchboard.						
46257	05A0121	Power Tech Electric Corp. 245 West 29th Street New York NY 10001	Requested approval for the electric service equipment proposed to be installed	200 Lexington Avenue New York NY	Approved	\$650.00
46258	05A0122	Elmac Electric Inc. 61-20 Cooper Avenue Glendale NY 11385	Requested approval for the electric service equipment proposed to be installed	388 Richmond Terrace Staten Island NY	Approved	\$650.00

ADVISORY BOARD CALENDAR

March 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46259	05A0123	S.J. Electric, Inc. 601 Union Street Brooklyn NY 11215	Requested approval for the electric service equipment proposed to be installed	272 West 107th Street New York NY	Approved	\$650.00
46260	05A0124	Reilly Electrical Inc. 3332 Nostrand Avenue Brooklyn NY 11229	Requested approval for the electric service equipment proposed to be installed	113 Mercer Street New York NY	Hold	\$650.00
1) Clarify feeder termination to two 200 amp disconnect switches. 2) Vertical service entrance bus is undersized. 3) Clarify 25 foot tap to 2nd panel. 4) No coordination between 700 and 200 amp fuses. 5) Provide marking of service switches or one line and room layout.						
46261	05A0127	Mage Electrical Contractors 158 Perry Street New York NY 10014	Requested approval for the electric service equipment proposed to be installed	1359 Broadway New York NY	Approved	\$650.00
46263	--	Cosentini Associate Consulting Engineers Two Pennsylvania Plaza New York NY 10121	Requesting permission to use the old New York City Electrical Code to design an Health Care Building in which a building permit was issued on 10/3/2002.	160 East 34th Street New York NY	Approved	\$0.00
46264	--	AMA Consulting Engineer 250 West 30th Street New York NY 10018	Requesting concept approval to separate feeders that originate from different sources by re-routing conductors from the bottom of the switchgear by shortening the switchgear door and adding a barrier. The conductors will run from the slab through the barriered bottom of the switchgear to a custom made splice box that will be installed on the switchgear back.	520 Madison Avenue New York NY	Ok, but	\$0.00

More information needed.

ADVISORY BOARD CALENDAR

March 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46265	---	Nead Electric, Inc. 500 5th Avenue, Suite B-15 New York NY 10110	Requesting permission to add an raceway bonding conductor on the end of the conduits that will terminate onto building steel where the conduits are not continuous to the building steel.	Dresdner Kleinwort Wasserstien 1301 Ave. of the Americas, 10 & 42 flrs. New York, NY	Approved	\$350.00
with the stipulation that the equipment bonding jumper is properly sized for the transformer.						
46266	--- ---	Emtec Consulting Engineers 3555 Veterans Memorial Hwy, Suite M Ronkonkoma NY 11779	Requesting special permission to 1) Enclose the life safety ATS in a separate two hour fire rated room inside of the service room. 2) to install a fireman's lock a disconnect switch painted red and labeled fire service. 3)To use the battery back-up system contained within the fire alarm equipment in accordance with RS 17-3B.(Cal. #46162).	Verizon 355 Forest Avenue Staten Island NY	Ok, but	\$0.00
Get approval letter from Fire Department.						
46267	----- -----	Emtec Consulting Engineers 3555 Veterans Memorial Hwy, Suite M Ronkonkoma NY 11779	Requesting special permission to 1) Enclose the life safety ATS in a separate two hour fire rated room inside of the service room. 2) To install a fireman's lock a disconnect switch painted red and labeled fire service. 3) To use the battery back-up system contained within the fire alarm equipment in accordance with RS17-3B. (Cal. #46163)	Verizon 680 Fairview Avenue Brooklyn NY	Ok, but	#Error
Get approval letter from the Fire Department.						
46268	----- ---	WB Engineering Consultants PLLC 110 William Street New York NY 10038	Requesting permission on a previously approved drawing (46210) to change the fire alarm fuse cutout to on 100 amp service switch with a fireman's lock the switch will be painted red and labeled fire service.	Verizon 107-15 70th Road Forest Hills NY	Ok, but	#Error
Get approval letter from the Fire Department.						

ADVISORY BOARD CALENDAR

March 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46269	..	A & A New York Electric Corp. 5224 3rd Avenue Brooklyn NY 11220	Requesting permission to leave as installed 12 kitchen islands without receptacle outlets.	213 West 23rd Street New York NY	Approved	\$350.00
46270	Zwicker Electric Co., Inc. 360 Park Avenue South New York NY 10010	Requesting permission in 40 living rooms to install wall receptacles that will be spaced greater than 6 feet apart due to the building having a glass wall floor to ceiling.	888 Main Street Roosevelt Island NY	Denied	\$0.00
Section 210.52 (A)(1) through (3) requires that wall receptacles be installed so that no point measured horizontally along the floor line in any wall space is more than 6 feet.						
46271	.	Team Electric, Inc. 1261 Broadway, Suite 609 New York NY 10001	Requesting permission not to install receptacle outlets on or in front of interior glass walls inside of a residence.	Private Residence 21 East 79th Street, 9th Floor New York NY	Denied	\$0.00
Section 210.52(A)(1) through (3) requires that wall receptacle be installed so that no point measure horizontally along the floor line in any wall space is more than 6 feet.						
46272	..	WB Engineers Consultants PLLC 110 William Street New York NY 10038	Requesting permission on a previously denied drawings submittal (46123) to install a fireman's lock on a 100 amp service switch painted red and labeled fire service.	608 West 176th Street New York NY	Ok, but	\$0.00
Get approval letter from the Fire Department.						
46273	*	Grand Electric 914 37th Avenue Long Island City NY 11101	Requested permission to leave as installed service equipment that is not grouped together in a building that does not have any common areas.	625 Midland Avenue Staten Island NY	Approved	\$350.00

ADVISORY BOARD CALENDAR

March 16, 2005

Calendar #	Submission #	Applicant Name and Address	Type of Request	Installation Location	Status	Fee
46274	**	City Lights Electric, Inc. 23-88 24th Street Long Island City NY 11105	Requesting permission to install an 8th service switch where two existing switches are for a sprinkler and fire pump and one switch is for fire department antenna.	32-02 Queens Boulevard Long Island City NY	Approved	\$0.00
46275	***	Ensign Engineering, P.C. 3397 East Tremont Avenue Bronx NY 10461	Requesting permission to utilize Article 220-35 New York City Amendment, optional calculations for determining existing loads, by using actual maximum demand readings for service loads.	Public School JHS 67Q 51-60 Marathon Parkway Flushing NY	Denied	\$0.00
Section 230.42(A)(3) of NYC's amendments require the ampacity of the service entrance conductors before the application of any adjustment or correction factors shall not be less than the sum of the maximum ampere settings of the service disconnects. When including fire pump disconnects in the calculation 125 percent of the fire pump full load amperes shall be added.						