

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Type of Request	Status	Fee
52814	13A0599CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from January 15, 2014 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/17/2017 - swap ok- dwg B1 & B2 Rev 3				
52813	14A0594CO	Requesting permission to leave as installed due to a hardship to replace, an open bottomed 3000 amp fused switch feeding an open bottomed 3000 amp switchboard with 11-4 inch conduits containing 5-500 KCM conductors with 1-500 KCM as an equipment grounding conductor connected directly to the enclosures on each side, where 3/0 equipment bonding jumpers are installed on the conduit bonding bushings to the enclosures.	Approved	\$0.00
Carry over from December 17, 2014 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53002	14A0670	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide short circuit and coordination study. 2) Provide site/key plan to indicate the location on Gen Set to the switchgear 3) With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/24/15 Job finalized. With the stipulation as follows: 1) Relays setting to be as per recommendation of coordinatin study. With the stipulation:</p> <p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Type of Request	Status	Fee
	14A0675CO	Requested approval for the electric service equipment proposed to be installed	Denied	\$0.00
Carry over from December 17, 2014 meeting. Fuse type, circuit breaker type not shown, short circuit curve to be provided. 2/19/16 Denied 1) Show fuse types on 1 Line drawing. 2) Show fault current at new circuit breaker panel. 3 Neutral in service switch to be bonded and grounded. 4) Why is cut sheet of 3000 amp fuse attached. 5) Provide full size drawings. 6) Fuse type not shown, short circuit curve to be provided.				
	14A0680	Requesting permission to utilize various lengths of tray cable for the installation of motorized electrical shades	Denied	\$0.00
1) Manufacturer's installation instructions for this installation not provided. 2) Electrical material used is not suitable for the purpose intended 110.2.				
52796	14A0698	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53100	14A0705	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) 500 KVA transformer not shown in service room. How long are transformer secondary taps? 6/19/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/25/16 Swapped drawing 4-Revision 1. 9/26/17 - Provide TCC between 4000A A4BQ & 2500A A4BQ signed and sealed 11/17/17 - swap dwg 1 of 4 rev 2, 4 of 4 rev 2 2/7/18 - swap dwg 1 of 4 Rev 3, 2 of 4 Rev 3 No More Swap				
53152	14A0726CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
Carry over from December 17, 2014 meeting. Requires short circuit and coordination study submittal and review. 8/5/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Type of Request	Status	Fee
52815	15A0016CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from February 18, 2015 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/18/15 Rejected. Show doors on chain link fence. 10/30/15 Swapped drawings 1,2 and 3, Revision 3s. 7/25/16 Swapped drawings 1,2. 7/25/16 Swapped drawings 1,2 & 3-Revision 4s.</p>				
53114	15A0027	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide signage for the location of service. 2) With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/26/15.. Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/30/15 Swapped drawings 1,2,3-Revision 5. 8/29/17 - swap dwgs 1,2, & 3 rev 6 10/3/17 - cond feeds MB # 3 is undersized 12/11/17 - swap dwg # ACS-D-11905-1, 2, & 3 Rev 8 with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				
52816	15A0036CO	Requesting permission to install manufactured wiring systems for receptacles below an accessible hung ceiling or where no finished ceilings exists	Approved	\$0.00
<p>Carry over from January 7, 2015 meeting. With the stipulation that communication cables and the MC cables are installed as per code and this approval is subject to field inspection. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
	15A0044	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Verify there are neutral conductors feeding paralleling switchboards from the generators. 2) Be bus duct shows between paralleling boards show 3-6"x1/4" on one side and 4-5"x1/4" on the other side. 3) Show where neutral is bonded in paralleling boards as note says above generators. 4) Remove typo for feeder size to swbd-62 off of generator 2 set 500. 5) Provide interlock between the pair breakers. 6) Provide short circuit/coordination study.. Verify that normal main CBS have GFCI upstream. 7) Provide gen room layout.</p>				

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Type of Request	Status	Fee
	15A0046	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Verify that switchboards comply with 230.64(B)(4) or 408.60(F). 2) Where is the end box located? Show incoming room. 3) EGCs in service entrance conduits not required but neutral is to be bonded to enclosure in the end boxes 250.4(A)(4). 4) Provide ground fault protection on disconnect switch feeding panel PP-H63. 5) AB50-1, and 2 of 3, show splicing or copper detail of how taps will be made in splice-tap boxes and verify compliance with 250.122(B). 6) Transformers T, 3 and 4 show length of secondary conductors. 7) Transformer T7, secondary conductors not protected exceeds tap rules. 8) Show conductors connecting Sections in DP-H6en. 9) Emergency side 2 fusing ahead of fire alarm transformer. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 10) Disc link must be relocated after the f.p. tap.</p>				
52797	15A0047	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/21/16 Swapped drawing FP,AB-Revision 1.</p>				
	15A0049	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Verify feeder connection to 1-1/4"x2" bus in 1200 amp pnl "RDB" and show conductor size for connection between panels. 2) Show fuse type in Navtech 800 amp Trans s. 3) Remove neutral bond and ground in fire alarm emergency disconnect switch. 4) Show lengths of taps feeding 4-60 amp circuit breaker panels, show feeder size to pnl "EM-LP-9". 5) Show method of tapping in the trough. 6) Show type of fire rated assembly that will be installed for the fire pump. 7) General notes and incoming fault current not shown. 8) With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Type of Request	Status	Fee
52817	15A0050	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>This submittal supercedes Approval #51500. This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
52963	15A0051	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Verify neutral connection in c.t. cabinet connect to phase log. 4/7/15 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 8/1/17 - 1) Verify that F.A. tap is ahead of neutral disconnect link. 2) Reflect changes in "RDP" 'EDP-Roof' ; "CS-1"; CS-2" & CS-3 to physical dwg-dwg # A 11/27/17 - swap dwg A-Rev 2, B-Rev 1, C-Rev 3</p>				
52818	15A0053	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
53105	15A0067	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Show full electrical room layout including egress 6/23/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/26/16 Drawing swap Drawing 1, 2-Revision 3.</p>				

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Type of Request	Status	Fee
	15A0068	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
1) Incoming fault current not shown. 2) Fire pump feeder not fire rated, correct FLA.				

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Type of Request	Status	Fee
52988	15A0075	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Fire pump service switch and 800A transformer secondary switch #1 to have proper front clearances. 2) Show service bus size feeding 2000 amp service switches. 3) Show lengths of transformer secondary taps on 1 line. 4) Verify HP size of limited service fire pump. 5) With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>With the stipulation: Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> 1. A P.E. or R.A. must file a PW1 as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. 4/21/15 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>With the stipulation: Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> 1. A P.E. or R.A. must file a PW1 as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements 6/23/15 Swapped drawing 1, Revision #2. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p> <p>With the stipulation: Fire Rated Enclosure's must comply with the following:</p> <ol style="list-style-type: none"> 1. A P.E. or R.A. must file a PW1 as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. 8/24/15 Swapped Drawing 3-Revision 3. 				

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Type of Request	Status	Fee
52800	15A0082	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52897	15A0084	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2) Relocate neutral disconnect link after all taps. 3/27/15 With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing Laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/11/16 Swap drawing 1 and 2, Revision 1 5/2/2017 - swap dwg # 2 of 2 Rev - 2. 7/27/17 Swap drawing with Rev. 3. No more swaps.</p>				
52819	15A0086CO	Requested approval for the electric service equipment proposed to be installed	Approved	\$0.00
<p>Carry over from February 18, 2015 meeting. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/27/16 Swapped drawing A-Revision 2; Drawing D-Revision 2; Drawing F-Revision 1; Drawing H-Revision 1 and Drawing I-Revision 1. 12/27/17 - 1) Remove N.D.L. before FA & FP tap in "service & distribution switchboard" in "North Service Room" and in "Building C" 2) Show tap length for "Time Warner" from commercial tenant trough 3) Emergency feeder for 50 HP FP is over fused. 3/23/18 - swap all dwgs. 5/1/19 Swap Dwgs H-Revision 4 and dwg I-Revision 3. 11/9/2020 Amended Dwgs # A Rev 4. D Rev 6. E Rev 4, G Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 1/25/2021 Amended Plan # H Rev- 6. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
52795	15A0091	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Type of Request	Status	Fee
53060	15A0104	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1)With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. Fire Rated Enclosure's must comply with the following:</p> <p>1)A P.E. or R.A. must file a PW1 as an ALT 3. 2)A Special Inspection TR1 form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3)The fire proofing must be performed by a certified fire proofing installer. 2) Coordination study not submitted. 6/1/15 Job finalized. Drawing approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. Fire Rated Enclosure's must comply with the following:</p> <p>1)A P.E. or R.A. must file a PW1 as an ALT 3. 2)A Special Inspection TR1 form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3)The fire proofing must be performed by a certified fire proofing installer. 9/21/15 Swapped drawings 1, 2, 3 and 4, Revision 6's. 2/17/16 Swapped drawings 1,2,3 and 4, Revision 7s. 6/20/16 Swapped drawings 1,2,3 and 4-Revision 8s. No more swaps for this submittal.</p>				
53063	15A0111	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Service rooms in both building marked 1B. 2) 1200 amp feeder requires a main disconnect switch at point of entry to building and supplemental ground to enclosure. 3) Grounding electrode conductors for fire pump 1A not ran with service entrance conductors to remote Building, GEC to be brought back to building where the service entrance conductors come in. 6/1/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/21/16 Swapped drawings 1,2 and 3-Revision 2s.</p>				

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Type of Request	Status	Fee
52820	15A0114	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	15A0119	Requesting permission to allow the primary feeders on the load side of the micro grid breakers to be run in R65 conduit.	On Hold	\$350.00
1) Clarify interim system and how it will be protected. 2) Spliced service entrance conductors not allowed. 3) Protection scheme and sequence of operation to be submitted. 4) Provide the length of time the temp will be in service. 5) Review color scheme provided on the drawings.				
53056	15A0124	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Tap conductors to (2) 200A meters are undersized. 5/29/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 3/25/16 Swapped Drawing 1-Revision 2				
52821	15A0125	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 7/14/16 Swapped Drawing 1-Revision 1.				
52822	15A0126	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/15/2017 - dwg A rev 3, Dwg B Rev 3, Dwg C rev 4. 9/10/18 Swap dwg B-Revision 4 and dwg C-Revision 5				
52961	15A0127	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
aka 270 Greenwich Street Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/23/15 Swapped drawing B & C, Revision 1s.				

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Type of Request	Status	Fee
52823	15A0128	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/1/16 Swapped Drawings A, B, & F-Revision 2 and drawing E-Revision 1.</p>				
52824	15A0129	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/19/2017 - swap dwg 1 of 2 rev 1				
52964	15A0130	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Parallel conductors to comply with 310.4(B). 4/7/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				
52825	15A0131	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/30/15 Swapped drawing 1-Revision 1, Drawing A-Revision D, Sheet 1 and 2 normal, Drawing A-Revision D, Sheet 1 and 2 Gen. 9/1/16 Swapped drawings AB50-01-Revision 2., A Gen Sh 1 and 2 -Revision E; A Normal SH 1 and 2-Revision E. 2/8/17 1. Not advisory board format 2. New submittal required. 3/23/17 Contractor appeared in office and the swap that was approved on 9/1/17 was correct. Refined drawings on 12/29/16 were sent in by contractor in error and rejected. The drawings swapped on 9/1/16 are the correct ones.</p>				
52826	15A0132	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Type of Request	Status	Fee
	15A0133	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
Tap of a tap not permittd				
53057	15A0136	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Show how generator and co-gen systems are grounded. 2) with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 5/29/15 Job finalized. With the stipulation: This drawing is approved with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/5/16 Rejected Provide new coordination study. 2/13/17 Verify the cable size from generator panel to "brass plate" to "EDP-Gen" switchboard. 3/1/17 - Job finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/2/2017 - swap ok dwg A rev - 2. 9/21/18 1) Comply with 695.6(B)(1) and 760.48-for F.A. & FP conds emergency side. 2) Verify 2 hr fire rated of f.p. conductors-normal side. 3) Remove bonding from F.A. & F.P disconnect switches-emergency side. 10/16/18 Swap dwg #B-Revision 2 and dwg D-Revision 6.</p>				
52827	15A0137	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Type of Request	Status	Fee
	15A0138	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
<p>1) Electrical room off of electrical room 1 to have ventilation and compliance with 110.26(A)(3), What does this room serve? 2) How will 6 sets of 750 KCM conductors terminate to 800 amp switches.(Switch typo). 3) Show length of transformer secondary conductors off or 300 KVA transformer, secondary conductors overfused. 4) Show fuse types, meter banks, fire pump and 400 Trans s. 5) Service board "MS-B" - 200 amp service switch to be bonded and grounded. 6) Feeders off of generator not protected. 7) Verify feeder size to fire alarm service switch. Bond and ground switch. 8) Equipment grounding conductors undersized -2-400 amp disconnect switches tapped off of 3000 amp fuses. 9) 3 and 4 pole ATS mixed. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code.</p>				
52987	15A0139	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Neutral bonded and grounded on load side of neutral link. 2) Equipment grounding conductor on load side of fire pump service switch undersized. 3) Correct contractors name and address in title block. With the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/21/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/26/16 1) Fire pump circuit conductor to fire pump undersized. 2) Equipment grounding conductor to 400 amp CT undersized. 10/26/16 Swapped drawing 1-Revision 3.</p>				
	15A0140	Requested approval for the electric service equipment proposed to be installed	Denied	\$650.00
<p>1) Correct contractors name in title block. 2) Service room, verify that switches above trough comply with 110.26(A)(3). 3) Service equipment on room layout does not indicate switches or distribution equipment, incoming not shown, Is there an overhead trough running across the room? 4) Verify service entrance conductors to fire pump, neutral conductor required. Why MI cable?. Where is the service switch located? Why run EGC's with MI cable? EGC on load side of FP switch undersized. 5) MS-A- bus sizes feeding 2000, 2-1200 and 1600 amp switches not shown. 6) Tap conductors off of 1200 amp feeder undersized. 7) EGC from MS-A to "P65" undersized, where is P65 located? Review stopped. MSB not reviewed.</p>				

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Type of Request	Status	Fee
52812	15A0144	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52828	15A0145	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52829	15A0146	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52830	15A0149	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/11/16 Swapped AB50-01 Revision 2 With the stipulation: Fire Rated Enclosure's must comply with the following: 1. A P.E. or R.A. must file a PWI as an AIT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer.				
	15A0150	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
1) Fire pump emergency side, feeder undersized, underfused. 2) New 75KVA transformer not shown in service room. 3) Gen DLO cable installed as a service conductor (not protected) required to be concrete incased DLO is not an approved wiring method.				

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Type of Request	Status	Fee
52799	15A0151	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52801	15A0152	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52802	15A0153	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52798	15A0154	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52831	15A0155	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	15A0156	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
1) New service switch #4 not shown on room layout drawing. 2) Show listing of rotary docking station. 3) Where will rotary docking station be installed, 700.6(G)? 4) Wrong fuse show on the T.C-C.				

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Type of Request	Status	Fee
52832	15A0157	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52803	15A0158	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52804	15A0159	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/24/15 Swapped Revision 1. 6/19/15 Swapped Revision 2.				
	15A0160	Requested approval for the electric service equipment proposed to be installed	Pending	\$650.00
1) Grounded conductors to supply service switches 250.24(c). 2) Cut sheet of 30 HP fire pump not provided. 3) Show short circuit current at 30 HP fire pump controller.				
52982	15A0161	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Fire pump service switch to be bonded and grounded. 2) Verify if fire pumps are new or existing dotted line. 3) Verify if service entrance conductors to fire pump service switch are new or existing dotted line with relocated switch. 4) Scope of new work not clear. 4/20/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Type of Request	Status	Fee
53203	15A0162	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Equipment grounding conductor on transformer secondary conductors undersized. 2) Provide spec for VFD cables. 3) Provide listing information. 6/18/15 Transformer secondary and equipment grounding conductors undersized as per tap rules 400 KCM rated 335 amps fused at 350 amps. 2) Co-gen to be hard wired. 8/25/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/20/16 Swapped drawings A021501-Revision 3 and A021502-Revision 1. 8/25/16 Swapped 1 Line drawing Revision 4. 8/31/17 - swap 1 line dwg with rev 5 NO MORE SWAPS</p>				
	15A0163	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Show service room verify fire rating, clearances in front of new equipment. 2) Listing documentation for co-gen not provided. 3) 1/0 fused at 250 amps. 4) Transformer secondary not bonded and grounded. 5) Disconnect switches reversed. 6) Equipment grounding conductor undersized from 1500 amp panel to 600 amp disconnect switch. 7) Single line is not consistent with manufacturer's diagram.</p>				
52833	15A0165	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/23/16 1) Maintain the clear working 5ft. (50") in front at ss #5. 2) Maintain the working width in front of "200A F.P. MTR".(working width is 2ft from side of is "distribution section 1 and F.A. switch") 2/9/17 - 1. Comply the section 230.64 (B) for FA sw. 3/15/17 - Item 1 not addressed. Comply section 230.64(B)(2). 5ft(60") working clearance required in front of FA switch. 3/28/2017 - swap dwg 1,2, with rev 1 & 3 of 3 Rev 4 5/23/2017 - swap dwg 1 of 3 rev 2</p>				
52834	15A0166	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
52805	15A0168	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Type of Request	Status	Fee
52807	15A0171	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52835	15A0172	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/17/2017 - 1) Comply section 408.60 (A) for SS# 1 & SS# 2. Relocate neutral disconnect link to downstream of main bonding jumper & grounding electrode conductor terminal.6/14/2017 - swap dwg with rev 2				
52809	15A0173	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52836	15A0174	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 2/1/17swap dwg 1 pf 2				
52837	15A0175	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
aka 87-02 Northern Blvd.-Queens Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52810	15A0176	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/30/16 Swapped drawing 1-Revision 1				

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Type of Request	Status	Fee
52838	15A0177	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52839	15A0178	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52808	15A0179	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52840	15A0180	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/10/2017 - swap dwg 1 & 2 rev 2 6/9/2017 - swap dwg # 2 rev-3, #1 rev-3				
52811	15A0181	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52983	15A0182	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Bus feeding 2000 amp circuit breaker load side of 1250 KVA transformer undersized. 2) Ground fault protection of equipment not shown on 1 Line drawing. 3) Provide 2nd copy of short circuit study. 4/20/15 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Type of Request	Status	Fee
52806	15A0183	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
53602	15A0184	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Bus feeding service switches 2, 3, and 4 undersized. 2) Service switches 2 and 3 to have neutral disconnect link. 3) Neutral not bonded and grounded in service equipment. 4) 1 line does not match physical. 5) 1000 KVA service room to be 2 hour fire rated. 3/17/16 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52841	15A0186	Requested approval for use in New York City of your 2 hour fire rated FPL , UL (FHIT) System 28A.	Approved	\$200.00
With the stipulation that the Radix Wire Fire Resistive cable is installed as per system 28A in entirety. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
52843	15A0187	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/6/17 Swapped drawing #B-Revision 6 and drawing A-Revision 3				
	15A0188	Requested approval for the electric service equipment proposed to be installed	Rejected	\$650.00
1) Show doors on chain link fences and height. 2 Neutral disconnect link to be relocated to load side of bonding and grounding. 3) Verify what(not in Easton contract) means. Is the equipment being installed or not? 4) Verify that manhole rings are bonded with the 3/0 EGC. 5) Provide coordination study. 4/23/15 Rejected. 1) Clearances of service equipment to comply with Table 110.26(A), show complete chain link fence that encloses equipment, not clear on drawing. show all fences, drawing too light to read, show height of fence. 2) Item #4 not addressed. 4/27/15 Rejected. 1) Clearances of service equipment to comply with Table 110.26(A), show complete chain link fence that encloses equipment, not clear on drawing show all fences, drawing too light to read, show height of fence. 2) Item #4 not addressed..				

ADVISORY BOARD CALENDAR

March 18, 2015

Approval #	Submission #	Type of Request	Status	Fee
52876	15A0206	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
3/24/15 Expedited Review. 4/20/15 Swapped Revision 2.				