

# ADVISORY BOARD CALENDAR

**March 28, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55221	18A0005	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provided TCCs to be signed &amp; Sealed by P.E. 2) Add Asbestos note to the DWG. 3) Verify complying with 695.6(B)(1) with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/13/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/5/2021 Amended Plan# 1 of 3 Rev 2, 2 of 3 Rev 0 and 3 of 3 Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55968	18A0008	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) One line dwg # 39316-P-GPS sheet no. 3 doesn't match Dwg # E5.L 2) Show listing of paralleling switchgear 3) Show bus bar size of paralleling switchgear on one line drawing. 4) Coordination study doesn't match the one line and provide short circuit study with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 11/13/18 1) Item #1 from last revision is not addressed verify fram size of CBs in 5K parallel switchgear 1200A or 600A and update coordination accordingly. 2) Item #4 not addressed 4/1/19 1) Provide room layout to parallel switchboard showing all equipment new verses existing &amp; clearly provide the clearances. 6/5/19 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				
	18A0018CO	Special Permission	On Hold	\$0.00
<p>Your documents indicate how many service switches are in this space, we can count up to 11 meters, 7 are clearly Con Ed meters. Indicate all meter types utility or revenue meters and if they come from same service or multiple ones</p>				

# ADVISORY BOARD CALENDAR

**March 28, 2018**

Approval #	Submission #	Type of Request	Status	Fee
	18A0098	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
<p>1) Show breaker size 2 type for new MV cable connected in "M-1", "M-2" &amp; "M-3" switchboard. 2) Primary conductor undersize for all MV transformer. 3) Provide updated, readable and addressing all comment from recommendation with P.E. sign &amp; seal. 4) Update tie breaker typo in "M2B substation" switchboard. 5) Show bus sizes for all "UPS substation switchboard." 6) Comply sec.695.4(B)(3) and relocate .FP service switch remote from "substation M1A" switchboard. 7) Comply Sec 430.28 for JP tap conductor. Tap conductor undersize. 8) Comply Sec. 695.66(c) for FP conductor. Emergency side conductor for both fp is undersized. 9) Show the emergency side OCPD rating. 10) Show fire alarm disconnect switch connection on single line diagram. 11) Show the approval for existing M.V. installation. 7/9/18 1) Item #2, 3, and 7 are not addressed. 2) Verify that F.P. emergency cond. Is 2 hr fire rated.</p>				
55184	18A0137	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/23/19 Swap Dwg A rev3, Dwg B rev2, Dwg C rev3, Dwg D rev4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55629	18A0146	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Sectional bus "C-1" switchboard is undersized. 2) Comply with 760.41(A)(1)-Life safety tap to be ahead of N.D.L. with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 3) Comply with 695.4(B)(1)-OCPD of 100 HP fire pumps are undersized. 4) Coordination between ss#2 2000A KRPC &amp; downstream 1600A KRPC not included within the coordination study. 5) Verify if the generator is SDS or not &amp; using 3 pole automatic transfer switch. 6) Verify complying with 695.6(B)(1). Remove F.A. OCPD out of new site safety board. 7) Provide ventilation to service room and panic bars to doors and verify 2 hr fire rated room. 8) Verify supplemental and water main grounding to service switches. 9) Asbestos Abatement document required. 10) Comply with 2702.1.7.L. 11) Fix typo ss#2 on floor plant physical. 12) Relocate life safety switchboard(F.P. switchboard) outside of the ATS room. 7/16/18 - 1) Remove bonding from F.A. switch emergency side &amp; generator breaker. 2) Ground electrode cond. Of the F.A. SW is undersized - normal side table 250.66. 8/23/18 1) EGC of 1200A F.P. service switch are undersized. 12/24/18 Job finalized. 1) Remove bonding from F.A. switch emergency side and generator breaker. 2) Ground electrode cond of the F.A. switch is undersized. -normal side -Table 250.66. 8/23/18 EGC of 1200A F.P. service switches are undersized. 12/24/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.</p>				

# ADVISORY BOARD CALENDAR

**March 28, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55158	18A0153	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55511	18A0191	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Provide sectional-bus-size in "MDP" "DP-T" &amp; "SDP" switch boards on the one line dwg. 2) Provide coordination between 1200A KRPC &amp; downstream 400A FR&amp;R (In DPT switchboard) 3) Verify complying with 695.6(B)(1) 4) Provide license # 5) Provided cut sheet don't match one line. 6) Verify, neutral &amp; phase connection in 1200A service switchboard "DP-T" with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTI) bearing the listing label prior to DOB electrical inspection, the NRTI field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 6/26 18 1) Sectional bus in "MDP" is undersized. 2) Item #3 and 5 not addressed. 9/7/18 Fire pump OCPD-emergency side-is overfused-Sec 695.4(B)(2)(1). 10/3/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/21/19 Swap Dwg # A091701 Rev 5.1 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.</p>				
55322	18A0200	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Fire pump conductor can't be EMT (&amp; Fire pump controller too) 2) Provide physical for CT section 6/1/18 - Item #1 is not addressed 6/12/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/19/2020 Amended Dwg# 1 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p>				
55153	18A0202	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**March 28, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55215	18A0203	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide coordination study stamped, sealed & performed by P.E. 2) Coordination provided does not coordinate after 0.1 sec 4/9/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55188	18A0204	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/10/19 1) Comply with 695.6(F) fire pump controller shall not be used as a junction box. 2) Confirm by providing documents that 5/8" sheetrock is a listed method of 2 hr fire rated material 2/4/19 1) Item #1 from last revision is not addressed. Fire Rated Enclosure's must comply with the following: 1. A P.E. or R.A. must file a PWI as an ALT 3. 2. A Special Inspection TRI form must be submitted by a licensed fire inspection agency to sign off on the fire proofing installation. 3. The fire proofing must be performed by a certified fire proofing installer. 4/12/19 Swap dwg A-Revision 2.				
55204	18A0206	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
	18A0207	Special Permission	Denied	\$350.00
1) Equipment ground for the tap conductors is undersized. 2) Installation shall be submitted to EAB for review.				
55234	18A0209	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Provide asbestos abatement compliance document 4/19/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/19/19 Swap Dwg -Rev 1				

# ADVISORY BOARD CALENDAR

**March 28, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55437	18A0212	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Verify if F.A. & F.P. taps are replacement for in kind for the same service 2) Verify if conds feed existing fire pumps & F.A are existing or new and show their values on one line dwg. 3) Asbestos abatement compliance doc. Required. 6/22/18 1) Verify bonding and ground to F.A. service switch. 2) Verify supplemental cond. 3) Item #3 not addressed-Asbestos document required. 8/21/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements				
	18A0213	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
1) Verify bonding trans S.SW & DSWs 2) All taps are undersized (show tap length) for all meter banks. 3) Provide coordination study 4) Show available short circuit on MB's- short circuit study 5) Correct typo on RDB on SS# 2 not SS# 1 6) Provide transformer cuts. 7) Provide meter banks cut sheets. 8) Indicate GEC of supplemental & size 9) Correct primary and second rating for T-S C-2 10) Emergency & standby can't be from same board, they shall be separate taps at the gen set. 11) Provide ground fault for 1200A DS 12) Indicate length of taps after 1000KVA transformer 13) Confirm SS# 3 feeding 1000KVA capable of in rush current.				
55217	18A0214	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Provide asbestos abatement compliance documents 4/12/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55187	18A0215	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/10/2020 Amended Plan #D, Rev 2 and Amended Plan #C, Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55401	18A0217	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide correct ACP-5 form for correct address or block number 2) Verify exit doors are opening outwards with panic bar hardware ( as mentioned in note) 3) Fix typo of 2"x8"x4L" 7/26/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**March 28, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55157	18A0218	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55150	18A0219	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55375	18A0222	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Verify 480/277V ratings on ADP & MDP switchboard 2) Verify (2) 200A switches feeding panel HP-R 3) Verify available short ct panel HP-R 4) Fix typo 6x1/4" x 6"cm 5) Provide required clearance by exit door egress 6/12/ 18 - 1) Main service bus bar feed S.sw # 2 is undersized 2) Verify that AIC rating of F.P controller is greater than available short circuit current. 6/28/18. Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55191	18A0223	Special Permission	Approved	\$0.00
with stipulation intallation and inspection shall be in accordance w/ 690 of 2014 NEC Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55265	18A0224	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Verify fire alarm neutral terminated at F.A S.SW with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review. The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review. NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 4/27/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/22/18 Swap dwg #B-Revision 2 and dwg A-Revision 1.				

# ADVISORY BOARD CALENDAR

**March 28, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55299	18A0226	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Show grounding & bonding for existing SS # 2) Existing conductor for SS #6 is undersize 5/21/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55185	18A0227	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/12/19 Swap Dwg A-Rev 1. 7/29/20 - swap dwg# A Rev 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55567	18A0230	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Verify if scope of work to replace equipment for some like & kind ( or adding new S.SWs) 2) Provide available S.C. current at S.SW # 4 3) Verify that available S.C. current at F.P. controller is less than 100KA 4) Vertical bus in "DPH-C" switchboard is undersized & provide the cut sheet. 5) Provide main OCPDE for DPH-C board 6) Comply w. 408.60(EX) at point of DPH-C connection. 7/2/18 - 1) Provide calendar # to previously approved "MSB" switchboard & provide load calcs. 11/13/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55186	18A0232	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55272	18A0233	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Provide coordination between "1200A KLU" (SS#2) fuse and downstream "400A AJT" fuse. Sign and seal by P.E. 5/1/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**March 28, 2018**

Approval #	Submission #	Type of Request	Status	Fee
	18A0235	Special Permission	On Hold	\$0.00
1) Submit floor plans for all floors showing spaces all around the elevator banks to demonstrate lack of space 2) submit a letter from the elevator vendor/servicing company that this proposed installation does not impede the elevator or/and the traveling cable.				
	18A0236	Special Permission	On Hold	\$0.00
1) submit floor plans for all floors showing spaces all around the elevator banks to demonstrate lack of space 2) submit a letter from the elevator vendor/servicing company that this proposed installation does not impede the elevator and/or the traveling cable.				
55300	18A0237	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Show vertical bus sizes from Co-gen connection to "MSS (wing-2) & "SW-1 (wing-1) switchboard 2) Verify neutral is not bonded within the co-gen system dwg E-6.1 AB (generator bonding detail). 5/18/18 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/16/18 Swap Dwg 1,2 and 3-Revision 3. 1/8/19 - Swap dwgs E-1.0AB and E-6.1AB Revision 4.				
	18A0241	Requested approval for the electric service equipment proposed to be installed	On Hold	\$650.00
1) Show "SEB" on the floor plan 2) Fire alarm conductor between "ATS-B-FA1" & FACP-1 and "ATS-B_FA2" & FACP-2" is undersize 3) Tap conductor undersize for "Retail tenant -A" & "Retail tenant - B" from SS#1 4) Remove grounding & bonding from All "Retail tenants" disconnect switches from tap from SS# 1 5) Show tap length for all retail tenant disconnect switch 6) Update fuse type for "SS# 3 2000A " 7) Fire alarm and all other ATS required 4 pole ATS 8) Provide neutral conductor between both FA-ATS and FACP's 9) Provide coordination between "1200A breaker" & downstream fuse in "EDPH-Gen" switchboard sign & seal by P.E. 10) Show electrical service room is mechanical ventilated & 2hr fire rated 11) Provide N.D.L for SS# 3,4 & 5				
55197	18A0242	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/14/2020 Swap Dwg rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				



# ADVISORY BOARD CALENDAR

**March 28, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55181	18A0244	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/30/2019 Swap Dwg # B-1801-29941-C Rev 1. Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55192	18A0245	Special Permission	Approved	\$0.00
with stip installation & inspection shall be in accordance w/ 690 of 2014 NEC Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55270	18A0247	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide asbestos abatement compliance required documents 2) 400A TR-R or FRN no matching in one line diagram on physical & show coordination with upstream fuse. 4/30/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/3/2021 Amended Dwg# A Rev.3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
56081	18A0248	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide cut sheets for new dist. Panel "DP-B" DP-A & DPC-2 2) Service bus bar feeding New 2500A S.SW is undersized 3) Comply with 695.3(A)(1) 4) Provide panic bars for doors & provide signage on the new service switch says " door to be open while working on the service switch" 5/17/18 - 1) Comment # 3 not addressed - Explain the complying with 695.3 (A)(1) for the F.P. tap is in the same enclosure as 3000A service switch. 7/20/18 1) Fire pump EGC is undersized. 2) Verify that service switchboard is not used as a raceway for the F.P. tap cond-comply with UL891. 8/15/18 1) comply with 408.36 for new distribution panel 'DPC-2'. 3/28/19 - 1. Update the coordination to add coordination between 3000A A4BQ & downstream 2000A A4BQ fuse. 2. - Verify if the fire alarm SW is new or existing and bubble if new. 7/29/2019 1) Provide coordination study to be signed & sealed by P.E. 9/18/2019 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 12/20/2021 Amended Plan # 1/1 Rev- 10. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				

# ADVISORY BOARD CALENDAR

**March 28, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55334	18A0249	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Conductor between "800A" service disconnect from "MSB" switchgear & "300KVA " x'mer is undersize. 6/20/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55356	18A0250	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Reference drawings (Bloom cutes) do not match one line dwg 2) Verify supplemental grounding. 6/20/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/16/18 - swap dwg A Rev 5. 9/19/18 Swap dwg #C-Revision 5. 1/2/19 Swap dwg #A-Revision 6.				
55354	18A0252	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Special Permission # 18A0253 pending approval. 2) Verify generator is not separately derived system & fire pump tap comply with NYC EC 2011 sec 695.4(B)(2)(4) 3) Pull Box sufficient working clearance and not blocked by F.P S.S. 6/19/18 - 1) Special permission is denied & adding glastic barrier needs a new special permission approval. 7/2/18 Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/24/18 Swap dwg. #A-Revision 3 and dwg B-Revision 3. Letter provided regarding name change from OHM Electrical to Nead Electric Inc.				
	18A0253	Special Permission	Denied	\$0.00
55406	18A0254	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide grounding & bonding to secondary of 750KVA xfmsr in DPH-6A & DPH-6B 2) Provide missing bus bar size connected to xfmsr 3) Verify the clearance on PPH-71B xfmr rear 4) Physical doesn't match one line or floor plan & fix typo in physical. 5/1/18 - 1) Item # 4 is partially addressed-'DPH-6A' still needs to be fixed. 2) Item # 2 is partially addressed - Bus bar connected to xfmr secondary in (DPH-6A) & (PPH-6B) and xfmr primary in [PPH-71B] & [DPH-71A]. 6/25/18 1) Item #1 from revision date 5/1/18 still not addressed-physical needs to change to match one line of 'DPH-6A'. 8/2/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				

# ADVISORY BOARD CALENDAR

**March 28, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55489	18A0255	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Asbestos abatement compliance required. 9/25/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55314	18A0256	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - 1) Provide asbestos abatement compliance document 6/1/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/28/2021 Amended Plan # 1 of 2 Rev- 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55190	18A0258	Special Permission	Approved	\$350.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55189	18A0259	Special Permission	Approved	\$350.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55410	18A0260	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Request special permission for addition service room 2) Comply sec 230.6 for new service entrance conductor from cellar electrical room to sub-cellar electrical room. 3) Show existing fuse type in "DP-6,7, & 8" switchboard 4) update typo for SS# 5 in new service switchboard B on single line diagram. 5/1/18 - Verify that existing SS# 2 was approved in original submittal in 2nd level room. If not please apply for special permission. 8/3/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 10/11/19 1) Comply with 230.64(A)(1) for the fire alarm location. 12/4/19 Swap Dwg # A rev.3, # B rev.1, # C rev.3 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				

# ADVISORY BOARD CALENDAR

**March 28, 2018**

Approval #	Submission #	Type of Request	Status	Fee
55546	18A0264	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide Asbestos abatement compliance required documents 2) comply with 408.3 - Provide Main OCPD to protect panel boards 7/27/18 - Item # 2 is not addressed. 10/31/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55196	18A0265	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 11/21/19 Swap Dwgs 1, 2 & 3 rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 2/24/2020 Swap dwg 1,2 & 3-Revision 2. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 2/1/2021 Amended dwgs# 1, 2, & 3 Rev 3. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				
55152	18A0266	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR - Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 6/29/18 Swap 1-Revision 1				
55343	18A0267	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Provide asbestos abatement compliance document 2) Indicate location service limited fire pump & compliance with 695.2. 6/25/18				
55520	18A0268	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Asbestos abatement compliance required 2) MDB cut sheet doesn't match one line. 10/9/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/3/19 Swap dwg rev2				

# ADVISORY BOARD CALENDAR

**March 28, 2018**

Approval #	Submission #	Type of Request	Status	Fee
	18A0269	Special Permission	On Hold	\$0.00
1) Provide complete floor plan for space of new installation indicating fire rating of the space and clear clearance in front of new EQ.				
55266	18A0270	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Pending SP approval 2) Provide physical protection & only authorized person can access the SS# 2 & 3. 5/3/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55195	18A0271	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/12/2021 Amended Plan# 1 & 2 Rev 1. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs				
55194	18A0272	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 5/23/18 Swap dwg 1, Revision 1				
55151	18A0273	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
OR -Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements.				
55245	18A0274	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
1) Verify supplemental grounding. 4/24/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 1/22/19 Swap Dwg 1 Rev 1. 4/19/19 Swap Dwg 1-Revision 3. 12/23/19 Swap Dwg # ACS-D-13150-1 Rev 4. Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs.				

# ADVISORY BOARD CALENDAR

**March 28, 2018**

Approval #	Submission #	Type of Request	Status	Fee
	18A0275	Special Permission	Administrative Closure	\$0.00
Why can't the switchboard be installed against the wall at the bus stage? Provide documents for any obstructions. 5/8/18 Void in lieu of 18A0127				
55283	18A0277	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Coordination (selectively) not legible ( scale) work performed signed, and sealed by P.E engineer (27-3018.1) 2) Verify (separately derived system) SDS generator or not &amp; clarify the grounding method with the stipulation that the generator, feeders, switchgear, and enclosure (if installed) are listed as a complete assembly from the manufacturer bearing the listing label, section 110.3, and 110.2. The listing documentation is to be kept on site for inspector's review.</p> <p>The other option is for the equipment to be field evaluated and listed as a complete assembly by an OSHA recognized "Nationally Recognized Testing laboratory" (NRTL) bearing the listing label prior to DOB electrical inspection, the NRTL field evaluation report is to be kept on site for inspector's review.</p> <p>NOTE: Only NRTL authorized manufacturers can build, test, and list the equipment. It is the responsibility of the submitter to ensure compliance with section 110.2(A)(1), 110.2(A)(2), and 110.3 of the 2011 NYC Electrical Code. 5/4/18 - Job Finalized Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 8/21/18 1) Provide coordination between 900A BR &amp; upstream 3000A BR - Generator Board. 10/26/18 Swap Dwg #I-Revision 3 and Dwg G. 3/5/19 Swap Dwgs #I rev 5 and #G No more swaps</p>				
55351	18A0278	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
<p>1) Conductor between "SS# 3 and short trip breaker" "Short trip breaker &amp; junction box" is undersize. 2) New conductor between "junction box: &amp; existing tap" is undersize 3) Show tap conductor length for new 200A panel 4) Remove splice from service switch # 3 enclosure. 6/7/18 Job finalized. Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 9/24/18 Swpa dwg 1-Revision 2 and dwg 2-Revision 1. 10/29/18 Swap Dwg 1-Revision 3.</p>				
55193	18A0283	Requested approval for the electric service equipment proposed to be installed	Approved	\$650.00
Disclaimer: Advisory Board approval is limited to materials received and reviewed by the Board. Contact Con-Edison regarding Blue Book requirements. 4/27/18 Swapped Drawing A, Revision 1.				