

ADVISORY BOARD CALENDAR

March 31, 2020

| Approval # | Submission # | Type of Request | Status | Fee |
|--|--------------|--|----------|----------|
| BK00169A3 | BK00169 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 5/22/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 10/23/2020 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 3/15/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 5/4/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 11/10/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs | | | | |
| BK00270A | BK00270 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 4/3/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |
| BK00297A1 | BK00297 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 5/1/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |
| BK00298A | BK00298 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 4/1/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |
| BK00309A1 | BK00309 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 5/14/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |

ADVISORY BOARD CALENDAR

March 31, 2020

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| BK00315A2 | BK00315 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 3/23/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 4/1/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 4/22/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs | | | | |
| BK00317 | BK00317 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 3/24/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |
| BK00332A3 | BK00332 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 4/28/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 9/8/2020 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 6/9/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs | | | | |
| BK00354A1 | BK00354 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 3/17/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 3/25/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |
| BK00385A2 | BK00385 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 4/8/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 12/22/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs | | | | |

ADVISORY BOARD CALENDAR

March 31, 2020

| Approval # | Submission # | Type of Request | Status | Fee |
|--|--------------|--|----------|----------|
| BK00389A1 | BK00389 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 4/2/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |
| BK00422A1 | BK00422 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 4/3/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 3/17/2021 Job finalized; Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |
| BX00282A2 | BX00282 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 4/24/20 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 3/3/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 3/19/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs | | | | |
| BX00355 | BX00355 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 4/1/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |
| MN00051A1 | MN00051 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 3/23/2020 1. Provide GP AS PER 215.10 on 2500A Gen set Ct Br (Verify why only indication) 2. Provide FP N side 2 hrs fire rated protection 3. FP SW undersized. 10/29/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 11/5/2020 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |

ADVISORY BOARD CALENDAR

March 31, 2020

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| MN00148A2 | MN00148 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 3/25/2020 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 3/26/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 4 | | | | |
| MN00167A | MN00167 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 4/7/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |
| MN00202A1 | MN00202 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 4/13/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 9/1/2020 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work | | | | |
| MN00274A | MN00274 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 3/18/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |
| MN00279A1 | MN00279 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 6/18/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |
| MN00283A1 | MN00283 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 3/20/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 11/5/22020 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |

ADVISORY BOARD CALENDAR

March 31, 2020

| Approval # | Submission # | Type of Request | Status | Fee |
|--|--------------|--|----------|----------|
| MN00285A1 | MN00285 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 3/30/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 12/17/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |
| MN00288A1 | MN00288 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 3/24/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |
| MN00292A | MN00292 | Requested approval for the electric service equipment proposed to be installed | Approved | #Error |
| 4/15/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |
| MN00334A2 | MN00334 | Requested approval for the electric service equipment proposed to be installed | Approved | \$0.00 |
| <p>4/10/2020 1. The engineering single line plan shall be submitted based on new NYC§ 4000-01 https://www1.nyc.gov/assets/buildings/rules/1_RCNY_4000-01.pdf: The §4000-01 Rule includes but not limited to the following: a. A selective coordination report prepared by a professional engineer must be filed with the Department prior to electrical inspection. Such engineer may be different from the applicant. 7/17/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 5/27/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs</p> | | | | |
| MN00375A | MN00375 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 4/14/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |

ADVISORY BOARD CALENDAR

March 31, 2020

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| MN00382A1 | MN00382 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 3/23/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work | | | | |
| MN00386A | MN00386 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 4/10/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |
| MN00392A | MN00392 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 4/6/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |
| MN00399A3 | MN00399 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 7/23/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 3/3/2021 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 6/30/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs. 11/15/2021 Disclaimer: Please note that Swap approval is only for new changes to original approved DWG as noted or marked on the updated DWG. It is the applicant's responsibility to clearly mark and note all changes to original approved DWGs | | | | |
| MN00411A | MN00411 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 4/13/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |
| MN00418A1 | MN00418 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 4/13/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 12/3/2020 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |

ADVISORY BOARD CALENDAR

March 31, 2020

| Approval # | Submission # | Type of Request | Status | Fee |
|---|--------------|--|----------|----------|
| MN00430A1 | MN00430 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 5/8/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |
| | QN00293 | Requested approval for the electric service equipment proposed to be installed | Pending | \$650.00 |
| <p>3/31/2020 1.The engineering single line plan shall be submitted based on new NYC§ 4000-01 https://www1.nyc.gov/assets/buildings/rules/1_RCN_4000-01.pdf: The §4000-01 Rule includes but not limited to the following: a. Confirm that all new equipment are adequately rated for the maximum available calculated fault current- Provide equipment AIC rating and available Short circuit current (on the plans) at the 2. Confirm 2 Hr. fire rated service room. 3. Confirm that the new service switchboard is adequate for the available Short Circuit current. 4. Verify if the building is new and exempt as per the note on the plan or it has an ACP5 control # as the document is submitted</p> | | | | |
| QN00293A | QN00293 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 7/8/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |
| QN00312A1 | QN00312 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 3/17/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |
| QN00339 | QN00339 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 5/13/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |

ADVISORY BOARD CALENDAR

March 31, 2020

| Approval # | Submission # | Type of Request | Status | Fee |
|--|--------------|--|----------|----------|
| QN00350A1 | QN00350 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 3/17/2020 Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. 9/10/20 Job finalized. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |
| SI00381A1 | SI00381 | Requested approval for the electric service equipment proposed to be installed | Approved | \$650.00 |
| 6/12/20 1) CCD1 shall be submitted to use 2014 NEC code for solar installation and inspection for solar equipment above 600V DC. 2) For services less than 1000KVA the job do not require plan review. Disclaimer: Please note that Electrical Plan Review (EPR) approval does not eradicate the applicants' liability to all submitted work. | | | | |